



BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

www.buildingcodeonline.com

Therma-Tru Corp.
118 Industrial Drive
Edgerton, OH 43517

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Component Approval - Plastics - Therma-Tru Fiberglass Door Skin

APPROVAL DOCUMENT: Drawing No. **S-2157-A1**, titled "Fiberglass Skin Component Approval", sheets 1 through 3 of 3, prepared by RW Building Consultants, Inc., dated 8/14/01 with revision "3" dated 03/27/06, prepared by R.W. Building Consultant, Inc., signed and sealed by Wendell Haney, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: None

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **renews NOA # 03-1210.07** and, consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by **Jaime D. Gascon, P.E.**



J. Gascon
6/19/06

NOA No 06-0406.11
Expiration Date: January 18, 2012
Approval Date: July 13, 2006

Therma-Tru Corporation

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Manufacturer's die drawings and sections.
2. Drawing No. **S-2157-A1**, titled "Fiberglass Skin Component Approval", sheets 1 through 3 of 3, dated 8/14/01 with revision "**3**" dated 03/27/06, prepared by RW Building Consultants, Inc., signed and sealed by Wendell Haney, P.E.

B. TESTS

1. Five Year Weathering Test for TCM, BTC, & PVC, prepared by Subtropical Testing Service, signed by Lon Hicks, P.E.
"Submitted under 03-1210.07"
2. 4500 hours Xenon Arch Test for SMC, TCM, & PVC, prepared by Subtropical Testing Service, signed by Lon Hicks, P.E.
"Submitted under 03-1210.07"
3. Tensile Property Test for SMC, TCM, PVC, & RTS, prepared by ETC Laboratories, Test Report No. **ETC-01-741-10921.0**, signed and sealed by Joseph L. Doldan, P.E.
"Submitted under 03-1210.07"
4. Test Reports for "Self Ignition", "Rate of Burning", and "Smoke Density", prepared by ETC Laboratories, Test Report No. **ETC-01-741-11250.0**, signed and sealed by Joseph L. Doldan, P.E.
"Submitted under 03-1210.07"
5. Letter of Explanation of lite frame composition by Therma-Tru, dated by 12/4/01, signed and sealed by Steven P. Kepler, P.E.
"Submitted under 03-1210.07"

C. CALCULATIONS

1. None

D. QUALITY ASSURANCE

1. Miami Dade Building Code Compliance Office (BCCO).

E. MATERIAL CERTIFICATIONS

1. None

F. STATEMENTS

1. None




Jaime D. Gascon, P.E.
Chief, Product Control Division
NOA No 06-0406.11
Expiration Date: January 18, 2012
Approval Date: July 13, 2006

Therma-Tru Corporation

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

G. OTHER

1. Letter stating that the reason for this revision is to show changes due to manufacturing tolerances, dated December 9, 2003, signed by Rick Wright.
"Submitted under 03-1210.07"
2. Notice of Acceptance No. **03-1210.007**, issued to Therma-Tru Corporation for their Plastics Components Approval-Therma-Tru Fiberglass Door, approved on 05/27/04 and expiring on 01/18/07.




Jaime D. Gascon, P.E.
Chief, Product Control Division
NOA No 06-0406.11
Expiration Date: January 18, 2012
Approval Date: July 13, 2006

THERMA-TRU CORPORATION

"PLASTICS LITE FRAME COMPONENT APPROVAL"

118 INDUSTRIAL DRIVE
 EDGERTON, OHIO 43517
 PH. (419) 298-1740

MINIMUM SKIN THICKNESS
 6'8 Door Panel = 0.090" +/- 0.010"
 8'0 Door Panel = 0.125" +/- 0.010"



Classic-Craft Fiberglass Skin

Notes:

1. Type of Door Skin - SMC: Sheet Molding Compound (Therma-Tru's Fiberglass)
2. Color - Oak (Tan)
3. Tensile Strength - 6,000 psi
4. Process - Molded in Grain (Red Oak deep grain)
5. Mfg. Facility - Therma-Tru Indiana, 108 Mutzfeld Road, Butler Indiana 46721

TABLE OF CONTENTS	
SHEET #	DESCRIPTION
1	CLASSIC-CRAFT FIBERGLASS SKIN
2	FIBER-CLASSIC FIBERGLASS SKIN
3	SMOOTH-STAR FIBERGLASS SKIN

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 06-0406.11
 Expiration Date 01/16/12
 By: [Signature]
 Miami Dade Product Control
 Division


DATE: 8/14/01
 SCALE: N.T.S.
 DWG. BY: TJH
 CHK. BY: RW
 DRAWING NO.: S-2157-A1
 SHEET 1 OF 3

RW BUILDING
 CONSULTANTS, INC.
 813.659.9197

NO.	DATE	ADD NOTES	BY
1.	12/17/01		RW
2.	12/08/03	ADD TOLERANCE	RW
3.	03/27/06	DATE RENEWAL	AEM

Documents Prepared By:
 BUILDING CONSULTANTS, INC.
 P.O. Box 230 Valrico FL 33595
 Phone No.: 813.659.9197
 Florida Board of Professional Engineers
 Certificate of Authorization No. 9813
 Wendell W. Horney, P.E. No. 54158
 3-29-06

MINIMUM SKIN THICKNESS
 6'8 Door Panel = 0.065" +/- 0.010"
 8'0 Door Panel = 0.110" +/- 0.010"



Fiber—Classic Fiberglass Skin

Notes:

1. Type of Door Skin - SMC: Sheet Molding Compound (Therma-Tru's Fiberglass)
2. Color - Oak (Tan)
3. Tensile Strength - 6,000 psi
4. Process - Molded in Grain (Red Oak standard grain)
5. Mfg. Facility - Therma-Tru Indiana, 108 Mutzfeld Road, Butler Indiana 46721

PRODUCT RENEWED
 in compliance with the Florida
 Building Code
 Acceptance No. 06-0406-11
 Expiration Date 04/11/12
 By [Signature]
 Minimal Risk Product Control
 Division


DATE: 8/14/01	SCALE: N.T.S.	DWG. BY: TJH	CHK. BY: RW	DRAWING NO.: S-2157-A1
				SHEET <u>2</u> OF <u>3</u>

RW BUILDING CONSULTANTS, INC.
813.659.9197

REVISIONS		
NO	DATE	BY
1.	12/17/01	RW
2.	12/08/03	RW
3.	03/27/06	AEM

Documents Prepared By:
BUILDING CONSULTANTS, INC.
 P.O. Box 230, Valrico FL 33595
 Phone No.: 813.659.9197
 Florida Board of Professional Engineers
 Certificate of Authorization No. 9813
 Wendell W. Hayley, P.E. No. 54158
 3-29-06

MINIMUM SKIN THICKNESS
 6'8 Door Panel = 0.070" +/- 0.010"
 8'0 Door Panel = 0.070" +/- 0.010"



Smooth-Star Fiberglass Skin

Notes:

1. Type of Door Skin - SMC: Sheet Molding Compound (Therma-Tru's Fiberglass)
2. Color - Smooth (White)
3. Tensile Strength - 6,000 psi
4. Process - 80 Grit Brushed (smooth no grain)
5. Mfg. Facility - Therma-Tru Indiana, 108 Mutzfeld Road, Butler Indiana 46721

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 06-0404.11
 Expiration Date 01/13/12
 By: *[Signature]*
 Michael Wade Product Control
 Division

DATE:	8/14/01
SCALE:	N.T.S.
DWG. BY:	TJH
CHK. BY:	RW
DRAWING NO.:	S-2157-A1
SHEET	3 OF 3

RW BUILDING CONSULTANTS, INC.
813.659.9197

REVISIONS	
NO.	DATE
1.	12/17/01
2.	12/08/03
3.	03/27/06

Documents Prepared By: *[Signature]*
 BUILDING CONSULTANTS, INC.
 P.O. Box 230 Valrico FL 33595
 Phone No.: 813.659.9197
 Florida Board of Professional Engineers
 Certificate of Authorization No. 9813
 Wendell W. Honey, P.E. No. 54158
 3-29-06