



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Versico Inc.
1555 Ritner Highway
P.O. Box 1289
Carlisle, PA 17013**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Versico Versiweld Premier Single Ply TPO Roof Systems over Recover Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 05-0613.05 and consists of pages 1 through 15.
The submitted documentation was reviewed by Jorge L. Acebo



**NOA No: 06-0406.18
Expiration Date: 08/31/08
Approval Date: 05/04/06
Page 1 of 15**

ROOFING SYSTEM APPROVAL

<u>Category:</u>	Roofing
<u>Sub-Category:</u>	Single Ply
<u>Material:</u>	TPO
<u>Deck Type:</u>	Recover
<u>Maximum Design Pressure</u>	-67.5 psf
<u>Fire Classification:</u>	See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product Name</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Versiweld Versifleece	various	TAS 131	Reinforced white or colored TPO membrane with fleece backing.
Versiweld Premier, Versiweld Premier Plus	various	TAS 131	Reinforced white or colored TPO membrane.
Versiweld Premier EF	various	TAS 131	Reinforced white or colored FR TPO membrane.
FAST 100 Adhesive	various	TAS 110	Spray Polyurethane Adhesive
FAST 100-P Adhesive	various	TAS 110	Spray Polyurethane Adhesive
FAST 102 Adhesive	various	TAS 110	Spray Polyurethane Adhesive
Versiweld Bonding Adhesive	various	TAS 110	Solvent-based bonding adhesive.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
Foamular Durapink Insulation	Extruded Polystyrene for white or black mechanically fastened roof systems	Owens Corning
Foamular ½" Board	Extruded Polystyrene recovery board	Owens Corning
Foamular 150, 250, 400, 404, 600	Extruded Polystyrene insulation	Owens Corning
Pyrox, White Line	Isocyanurate Insulation	Apache Products Co.
ACFoam Composite	Isocyanurate Insulation with perlite facer	Atlas Roofing Corp.
ACFoam II	Isocyanurate Insulation	Atlas Roofing Corp.
Polyisocyanurate MP, MP-N, MP-H, MP-W	Polyisocyanurate roof insulation.	Versico Inc.
Versico Recovery Board	High Density Wood Fiberboard.	Versico Inc.
Styrofoam	Extruded polystyrene insulation	Dow



NOA No: 06-0406.18
 Expiration Date: 08/31/08
 Approval Date: 05/04/06
 Page 2 of 15

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ISO 95+ GL, 95+ GW	Polyisocyanurate foam insulation	Firestone
Dens Deck	Silicon treated gypsum	G-P Products
Sturdi-Top	Wood fiber insulation board.	G-P Products
Ultra/M-II	Isocyanurate Insulation	Homasote Co.
ENRGY 2, ENERGY 3, PSI-25	Isocyanurate Insulation	Johns Manville
Fesco Foam	Isocyanurate Insulation with perlite facer	Johns Manville
Retro-Fit	High-density perlite roof insulation.	Johns Manville
Wood Fiberboard	Regular wood fiber insulation	Generic
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic
Perlite Insulation Board	Perlite Insulation	Generic
Perlite/Urethane Composite	Perlite/urethane composite insulation board	Generic
Type X Gypsum	Gypsum Wallboard	Generic
XPS	Extruded polystyrene	Generic
EPS	Expanded polystyrene	Generic
Multi-Max, FA	Polyisocyanurate foam insulation	Rmax, Inc.
Fiber Base	Asphalt coated wood fiber insulation	Temple Inland Forest Products Corp.
Structodeck	High Density Wood Fiber insulation board.	Wood Fiber Industries

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Versico HPV or MPV, HPVX, HPV-XL Fasteners	Insulation and membrane fastener	Various	Versico Inc.
2.	Versico CD-10	Insulation and membrane fastener	Various	Versico Inc.
3.	Versico Seam Fastening Plates	Driven fasteners used for insulation and membrane securement in concrete decks.		Versico Inc.



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
4.	Versico NTB	Insulation fastener for cementitious and gypsum decks	Various	Versico Inc.
5.	Versico NTB	Metal plates used for membrane securement with Versico NTB fasteners.	3" dia	Versico Inc.
6.	Versico Insulation Plates	Metal plates used for insulation securement.	2-7/8" dia	Versico Inc.
7.	Versico Polymer Seam Plates	Plastic plates used for membrane securement with Versico fasteners.	2" dia	Versico Inc.
8.	HPVX, HPV-XL Plates	Metal plates used for membrane securement with Versico fasteners.	2-3/8" dia	Versico Inc.
9.	Dekfast Fasteners #14, #15	Insulation and membrane fastener	Various	Construction Fasteners, Inc.
10.	Dekfast Hex Plate	Insulation and membrane fastener	Various	Construction Fasteners, Inc.
11.	#14 Roofgrip	Insulation and membrane fastener	Various	ITW Buildex
12.	Metal Plate	Galvalume AZ50 stress plate	3" square	ITW Buildex
13.	Plastic Plate	Polyethylene stress plate	3.2" round	ITW Buildex
14.	Olympic Fasteners #14	Insulation and membrane fastener	Various	Olympic Mfg. Group
15.	Olympic Stainless Fasteners #14	Stainless steel insulation and membrane fastener	Various	Olympic Mfg. Group
16.	Strap Toggle	Insulation fastener for steel, wood and gypsum decks.	Various	Olympic Mfg. Group
17.	Iron-Lok Toggle	Insulation fastener for steel, wood and gypsum decks.	Various	Olympic Mfg. Group
18.	Lite-Deck Plate	3" round Galvalume AZ55 stress plate	3" round	Olympic Mfg. Group
19.	NTB Plate	3" round Galvalume AZ55 stress plate	3" round	Olympic Mfg. Group
20.	NTB Metal Barbed Stress Plate	2" round Galvalume AZ55 stress plate	2" round	Olympic Mfg. Group
21.	NTB Plastic Plate	Plastic plates for NTB 2" head fasteners.	3" round	Olympic Mfg. Group



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
22.	Olympic Standard	Galvalume AZ55 stress plate	3" round	Olympic Mfg. Group
23.	Olympic Plastic	Plastic plates for fasteners.	3" round	Olympic Mfg. Group
24.	Rawl Fasteners #14	Insulation fastener for steel and wood decks	Various	Powers Fasteners Inc.
25.	Rawl Drive	Insulation fastener for concrete decks		Powers Fasteners Inc.
26.	Rawl Spike	Insulation fastener for concrete decks		Powers Fasteners Inc.
27.	Rawl Speed-Lock Toggle Bolt	Insulation fastener assembly		Powers Fasteners Inc.
28.	Powerlite	Insulation fastener for cementitious and gypsum decks.		Powers Fasteners Inc.
29.	Powerlite	3" round Galvalume AZ55 stress plate	3" round	Powers Fasteners Inc.
30.	Rawl Insulation Plate	3" round Galvalume AZ55 stress plate	3" round	Powers Fasteners Inc.
31.	Insul-Fixx Fastener	Insulation fastener for steel and wood decks	Various	SFS Stadler, Inc.
32.	Isofast Fasteners	Insulation fastener for steel and wood decks	Various	SFS Stadler, Inc.
33.	Insul-Fixx S	3" round Galvalume AZ55 stress plate	3" round	SFS Stadler, Inc.
34.	Insul-Fixx P	3" round polyethylene stress plate	3" round	SFS Stadler, Inc.
35.	Isofast Plate	Square or oblong Galvalume steel plates for use with Isofast fasteners		SFS Stadler, Inc.
36.	Tru-Fast Fasteners	Insulation and membrane fastener	Various	The Tru-Fast Corp.
37.	Tru-Fast Ultra Stainless Fasteners	Stainless steel insulation and membrane fastener	Various	The Tru-Fast Corp.
38.	Tru-Fast MP-3	3.23" round Galvalume AZ50 steel plate	3.23" round	The Tru-Fast Corp.
39.	Tru-Fast Plastic Plate	Polyethylene stress plate	3" round	The Tru-Fast Corp.



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Architectural Testing Inc.	ATI-37050.01	Wind Uplift Classification	3/13/00
Architectural Testing Inc.	ATI-37490.01	Membrane Brittleness Testing	7/7/00
Factory Mutual Research Corp.	303393	Wind Uplift and Fire Classification	3/30/99
Factory Mutual Research Corp.	303393 (Letter Report)	Wind Uplift Classification	3/26/99
Factory Mutual Research Corp.	3001522	Wind Uplift and Fire Classification	3/26/99
Factory Mutual Research Corp.	3001522 (Letter Report)	Wind Uplift Classification	11/3/98
Factory Mutual Research Corp.	3Z9A1.AM	Wind Uplift and Fire Classification	10/15/97
Factory Mutual Research Corp.	Approval Guide Excerpt	Wind Uplift and Fire Classification Listings	5/00
Factory Mutual Research Corp.	Letter	Wind Uplift and Fire Classifications	5/2/00
Celotex Corporation Testing Services	520257	Membrane Physical Property Testing	4/19/00
SGS U.S. Testing Company Incorporated	131248-R2	Membrane Ozone Resistance Testing	1/6/00



APPROVED ASSEMBLIES

- Membrane Type:** Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK
- Deck Type 7I:** Recover
- Deck Description:** Concrete/lightweight concrete/cementitious wood fiber/wood/steel
- System Type A:** All layers of insulation adhered with approved asphalt or FAST Adhesive; membrane fully adhered.

All General and System Limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
One of the following covered with the boards listed in Top Layer or Base or Top Layer.		
Perlite		
Minimum 3/4" thick	N/A	N/A
Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
One or more layers of the following as a Base or Top Layer or over the Base Layer listed above:		
PYROX, AP, ISO 95+ HF, Rhoflex HF, Multi-Max FA, Polyisocyanurate MP, MP-N, MP-H		
Minimum 1.2" thick	N/A	N/A
ENRGY-3, ENRGY-2, PSI-25, UltraGard Gold		
Minimum 1.4" thick	N/A	N/A
ACFoam II, ACFoam Composite, Rhoflex Composite, Fesco Foam, Polyisocyanurate MP-W		
Minimum 1.5" thick	N/A	N/A
Versico Recovery Board, Structodeck		
Minimum 1/2" thick	N/A	N/A
High Density Fiberboard		
Minimum 3/4" thick	N/A	N/A

Note: Existing roof shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the existing roof in full moppings of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down. Insulation layers can be adhered to the deck with Fast Adhesive.

- Vapor Retarder:** (Optional) Vapor retarder may be mopped to deck or base layer of insulation.
- Barrier:** None.



Membrane: Versiweld Premier or Versiweld Premier EF, Reinforced, 45 or 60 mil membranes or Versiweld Premier Plus, 72 or 80 mil membranes fully adhered to the insulation using Versiweld Bonding Adhesive applied at a rate of 1 gal/60 ft.².

or

Versiweld Versifleece 100 or 115 mil membranes fully adhered to the insulation using FAST Adhesive applied to the substrate at a rate of 1 gal/sq.

Maximum Design
Pressure:

-45 psf (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK
Deck Type 7I: Recover
Deck Description: Concrete/lightweight concrete/cementitious wood fiber/wood/steel
System Type C: All layers of insulation simultaneously attached; membrane fully adhered.

All General and System Limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
One of the following covered with the boards listed in Top Layer Extruded Polystyrene, Expanded Polystyrene, Energy-Lok, ACFoam-II Minimum 1" thick	N/A	N/A
Perlite Minimum ¾" thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Ultra/M-II Iso/glas Minimum 1.2" thick	Approved Fastener for Deck Type	1:2 ft ²
WHITELINE, PYROX, AP, ISO 95+ HF, Rhoflex HF, Polyisocyanurate MP, MP-H Minimum 1.4" thick	Approved Fastener for Deck Type	1:2 ft ²
Minimum 2" thick	Approved Fastener for Deck Type	1:4 ft ²
ENRGY-3, ENRGY-2, PSI-25, Polyisocyanurate MP-N Minimum 1.4" thick	Approved Fastener for Deck Type	1:2 ft ²
Minimum 2" thick	Approved Fastener for Deck Type	1:4 ft ²
ACFoam II, ACFoam Composite, Rhoflex Composite, Fesco Foam, Polyisocyanurate MP-W Minimum 1.5" thick	Approved Fastener for Deck Type	1:2 ft ²
Minimum 2" thick	Approved Fastener for Deck Type	1:4 ft ²
Versico Recovery Board Minimum ½" thick	Approved Fastener for Deck Type	1:2 ft ²
Fiber Base (for use over polyisocyanurate, gypsum or perlite), Fiber Base Minimum ½" thick	Approved Fastener for Deck Type	1:2.9 ft ²
Sturdi Top Minimum ½" thick	Approved Fastener for Deck Type	1:8 ft ²
High Density Fiberboard Minimum ¾" thick	Approved Fastener for Deck Type	1:2.67 ft ²
Wood Fiber Minimum 1" thick	Approved Fastener for Deck Type	1:2.67 ft ²



Base or Top Insulation Layer

**Insulation Fasteners
(Table 3)**

**Fastener
Density/ft²**

Required over the insulations listed in Base Layer or optional over any of the insulations listed as Base or Top layer :

Versico Recovery Board (for use over all insulation types)

Minimum 1/2" thick

Approved Fastener for Deck Type 1:2 ft²

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane: Versiweld Premier or Versiweld Premier EF, Reinforced, 45 or 60 mil membranes or Versiweld Premier Plus, 72 or 80 mil membranes fully adhered to the insulation using Versiweld Bonding Adhesive applied at a rate of 1 gal/60 ft.².
or
Versiweld Versifleece 100 or 115 mil membrane fully adhered to the insulation using FAST Adhesive applied to the substrate at a rate of 1 gal/sq.

Maximum Design Pressure: -45 psf (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced
Deck Type 7I: Recover
Deck Description: Concrete/lightweight concrete/cementitious wood fiber/wood/steel
System Type D: Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
One of the following covered with the boards listed in Top Layer or Base or Top Layer.		
Extruded Polystyrene, Expanded Polystyrene, Energy-Lok, ACFoam-II Minimum 1" thick	N/A	N/A
Perlite Minimum ¾" thick	N/A	N/A
Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Polyisocyanurate MP, MP-H, Multi-Max FA, WHITELINE, PYROX, AP, ISO 95+ HF, Rhoflex HF, Ultra/M-II Iso/glas Minimum 1.2" thick	N/A	N/A
UltraGard Gold, Isolite E Minimum 1.3" thick	N/A	N/A
ENRGY-2, PSI-25, ISO 95+GL, GW, Rhoflex GL, GW, Polyisocyanurate MP-N, Polyisocyanurate MP-W, Minimum 1.4" thick	N/A	N/A
ACFoam II, ACFoam Composite, Rhoflex Composite, Fesco Foam Minimum 1.5" thick	N/A	N/A
Versico Recovery Board, Structodeck, Wood Fiber, Fiber Base Minimum ½" thick	N/A	N/A
High Density Fiberboard Minimum ¾" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Required over the insulations listed in Base Layer or optional over any of the insulations listed as Base or Top layer :		
Versico Recovery Board (use over all other insulation types), Fiber Base (use over polyisocyanurate, Gypsum or perlite) Minimum ½" thick	N/A	N/A



Note: All layers of insulation and base sheet shall be simultaneously attached. See base sheet below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. Single and multiple layers of insulation can be attached to the deck with FAST Adhesive.

- Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.
- Barrier: None.
- Deck: Minimum 22 gage ASTM A 446 Grade E Steel deck (unless otherwise noted) fastened to steel support at a maximum span of 6 feet o.c. Steel deck shall be fastened with minimum ITW Buildex Traxx/4 at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex Traxx/1 at a maximum spacing of 30 inches o.c.
- Membrane: Versiweld Premier, Versiweld Premier Plus or Versiweld Premier EF secured through the preliminarily attached insulation as specified below.
- Fastening #1: HPVX Fasteners with HPVX Plates 6" o.c. through the Versiweld Premier or Versiweld Premier Plus Membrane in the lap in rows spaced 7'-7" o.c. **Maximum Design Pressure -68 psf. (See General Limitation #7)**
- Fastening #2: HPVX Fasteners with HPVX Plates 6" o.c. through the Versiweld Premier or Versiweld Premier Plus Membrane in the lap in rows spaced 9'-7" o.c. **Maximum Design Pressure -60 psf. (See General Limitation #7)**
- Fastening #3: HPVX Fasteners with HPVX Plates 9" o.c. through Versiweld Premier or Versiweld Premier Plus Membrane in the lap in rows spaced 9'-7" o.c. **Maximum Design Pressure -52.5 psf. (See General Limitation #7)**
- Fastening #4: HPVX Fasteners with HPVX Plates 6" o.c. through the Versiweld Premier EF Membrane in the lap in rows spaced 9'-7" o.c. **Maximum Design Pressure -52.5 psf. (See General Limitation #7)**
- Fastening #5: HPVX Fasteners with HPVX Plates 9" o.c. through the Versiweld Premier EF Membrane in the lap in rows spaced 9'-7" o.c. **Maximum Design Pressure -45 psf. (See General Limitation #7)**
- Fastening #6: HPVX Fasteners with HPVX Plates 12" o.c. through the Versiweld Premier or Versiweld Premier Plus Membrane in the lap in rows spaced 9'-7" o.c. **Maximum Design Pressure -45 psf. (See General Limitation #7)**
- Fastening #7: HPVX Fasteners with HPVX Plates 6" o.c. through the Versiweld Premier EF Membrane in the lap in rows spaced 7'-7" o.c. **Maximum Design Pressure -60 psf. (See General Limitation #7)**



Fastening #8: **Minimum Grade C steel deck:** HPVX Fasteners with HPVX Plates 6" o.c. through the Versiweld Premier or Versiweld Premier Plus Membrane in the lap in rows spaced 11'-7" o.c. **Maximum Design Pressure -52.5 psf. (See General Limitation #7)**

Fastening #9: **Minimum Grade C steel deck:** HPV-XL Fasteners with HPV-XL Plates 6" o.c. through the Versiweld Premier or Versiweld Premier Plus Membrane in the lap in rows spaced 11'-7" o.c. **Maximum Design Pressure -60 psf. (See General Limitation #7)**

Fastening #10: HPVX Fasteners with HPVX Plates 6" o.c. through the Versiweld Premier or Versiweld Premier Plus Membrane in the lap in rows spaced 11'-7" o.c. **Maximum Design Pressure -60 psf. (See General Limitation #7)**

Maximum Design Pressure: See Previous Fastening Options #1- #10



Membrane Type: Single Ply, Thermoplastic, Reinforced, FleeceBACK

Deck Type 7I: Recover

Deck Description: Concrete/lightweight concrete/cementitious wood fiber/gypsum/wood/steel

System Type F: Membrane fully adhered with FAST Adhesive.

All General and System Limitations apply.

Vapor Retarder: None.

Barrier: None.

Membrane: Versiweld Versifleece 100 or 115 membrane fully adhered to the existing roof using FAST Adhesive applied to the substrate at a rate of 1 gal/sq.

**Maximum
Design Pressure:** -150 psf (See General Limitation #9)



RECOVER SYSTEM LIMITATIONS:

- 1 All System Limitations and General Limitations shall apply. See specific deck type Notice of Acceptance for deck type System Limitations.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

END OF THIS ACCEPTANCE



NOA No: 06-0406.18
Expiration Date: 08/31/08
Approval Date: 05/04/06
Page 15 of 15