



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

**Johns Manville Corporation  
717 17<sup>th</sup> Street  
Denver, CO 80202**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Johns Manville PVC Single Ply Roof Systems over Recover Decks**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 03-0421.09 and consists of pages 1 through 15.  
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 06-0522.13  
Expiration Date: 06/21/11  
Approval Date: 07/27/06  
Page 1 of 15**

## ROOFING SYSTEM APPROVAL

Category: Roofing  
Sub-Category: Single Ply  
Material: PVC  
Deck Type: Recover  
Maximum Design Pressure See Specific deck type  
Fire Classification: See General Limitation #1

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
UltraGard SR-50, SR-60 and SR-80	37.5" - 81" wide	ASTM D 4434	Polyester reinforced PVC membrane 50, 60 or 80 mils thickness used in mechanically fastened and adhered roofing assemblies, and as membrane flashing for walls, curbs, etc.
UltraGard Plus 50 Plus 60	53" - 81" wide	ASTM D 4434	Polyester reinforced PVC membrane 50 mils and 60 mils thick with a 7.5 ounce polyester fleece laminated to the underside. ULTRAGARD Plus may be mechanically attached or adhered to acceptable substrates.
UltraGard V-2/50 and V-2/60	37.5" - 81" wide	ASTM D 4434	Polyester reinforced PVC polymer based, 50 or 60 mil membrane used in mechanically fastened and adhered roofing assemblies, and as membrane flashing for walls, curbs, etc.
Seekure Paper Slipsheet	96" x 300'		A laminated Kraft paper slipsheet with a fiberglass scrim reinforcement intended for use with mechanically attached systems as a separating slipsheet over smooth substrates. It is not intended for use over smooth surface BURs.
CTP Foil Slipsheet	6' - 300'		A laminated foil/Kraft paper slip sheet with a polyethylene coating on both sides of the foil intended for use with mechanically attached systems as a separation layer.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
DN Flameguard Slipsheet	71" x 700'		A laminated aluminum foil/Kraft paper slipsheet with proprietary flame extinguishing adhesive and a fiberglass scrim reinforcement for use with mechanically attached systems as a fire-retardant slipsheet in certain UL and FM assemblies.
Polyester Protection Mat	12' x 100'		A 9 ounce needle-punched polyester fabric that is used as a cushioning layer in certain applications.
Detail Membrane 80	35" x 75'	ASTM D 4434	35" wide, 80 mil thick PVC membrane used in field-formed flashing where heat forming is required. Available in white, grey, pearl or black.
Detail Strip 80	6" x 150'		6" wide 80 mil thick unreinforced PVC membrane strips used to waterproof joints of ULTRAGARD metal. Available in white, grey, pearl and black.
Inside Corner	various		Pre-manufactured corners available in white or grey used to waterproof the corners of walls, parapets, etc..
Outside Corner	various		Pre-manufactured corners available in white or grey used to waterproof the corners of walls, parapets, curbs, pitch pockets, etc.
UltraGard Vinyl Coated Metal Sheets	4' x 8' 4' x 10'		Available in white, grey and black. 4' x 8' and 4' x 10' sheet sizes. UltraGard metal is a laminate of UltraGard PVC membrane and galvanized steel field fabricated into metal base flashings, edge details, and pitch pockets.
UltraGard Vinyl Coated Metal 3" strip	3" x 8' 3" x 10'		Pre-cut UltraGard metal strips are used for base securement and membrane flashing securement in specific details.
7" Round Disk Caps	7" round		Round membrane caps used to waterproof fastening discs in certain applications. Available in white and grey.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
¼" Microfoam	6' x 225'		A multi-ply polypropylene foam intended for use with mechanically attached systems as a cushioning slipsheet over rough, uneven substrates. It is not intended for use over existing gravel surfaced built-up roofs.
Termination Bar	1.35" x 10'		An extruded aluminum (0.93" thick) bar slotted 6" on center used to terminate adhered "SR" and "FAS" membrane flashings in certain details.
Ultrgard PVC Membrane Adhesive (Latex)	5 Gal. Pail	Proprietary	Designed for bonding UltraGard PVC membrane to concrete, cellular concrete, and specific wood fiber roof insulations in horizontal applications only.
Ultrgard PVC Membrane Adhesive (Solvent)	5 Gal. Pail	Proprietary	Designed for bonding UltraGard PVC membrane to metal, wood, concrete, cellular concrete and specific roof insulations in both horizontal and vertical applications.
Ultrgard PVC Membrane One-Step Adhesive	5 Gal. Pail		Designed for bonding UltraGard PVC membrane to various vertical and horizontal surfaces.
UltraGard Sealant	30 Tube box		A single component, gun grade elastomeric polyurethane sealant used to seal UltraGard termination bar, counter flashings, etc.. UltraGard caulk is not used to caulk field seams. UltraGard caulk is available in white and grey.
Ultrgard Pourable Sealer	1 Gal. Can		A two part polyurethane sealant used as a pitch pocket filler.
Ultrgard PVC Round Pitch Pocket	6.5" Round		Rigid PVC flashing with an opening 6.5" in diameter used to waterproof irregularly shaped penetrations.
Ultrgard PVC Sealant	1 Gal.	Proprietary	A liquid PVC compound used to seal non-encapsulated edges of completed seams.
Ultrgard Solvent Welding Solution	1 Gal.		May be used to weld UltraGard PVC membrane to UltraGard metal in certain detail applications.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
UltraGard Roof Systems Membrane Cleaner	1 Gal. Can		May be used to clean small areas of the membrane where asphalt, roofing cement, etc. must be removed.
Type R Tie-in Membrane	24" x 82'		An asphalt compatible PVC membrane used as a tie-in material to existing built-up roofs.
WBP 100 Walkway	48" x 60'		100 mil thick texturized polyester reinforced PVC membrane used as a walkway and protection material. Available in blue or grey.

**APPROVED INSULATIONS:**

**TABLE 2**

<b>Product Name</b>	<b>Product Description</b>	<b>Manufacturer (With Current NOA)</b>
Dens Deck	Silicon treated gypsum	G-P Products
Sturdi-Top	Wood fiber insulation board.	G-P Products
ENRGY 2, ENRGY 3, PSI-25	Isocyanurate Insulation	Johns Manville
Fesco Foam, DuraFoam	Isocyanurate Insulation with perlite facer	Johns Manville
Retro-Fit Board, DuraBoard	A high-density perlite roof insulation.	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
Fiber Glass	Glass fiber roof insulation board.	Johns Manville
Wood Fiberboard	Regular wood fiber insulation	Generic
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic
Perlite Insulation Board	Perlite Insulation	Generic
Type X Gypsum	Gypsum Wallboard	Generic
XPS	Extruded polystyrene	Generic
Multi-Max FA	Polyisocyanurate foam insulation	RMAX
Fiber Base	Asphalt coated wood fiber insulation	Temple Inland Forest Products Corp.
Structodeck	High Density Wood Fiber insulation board.	Wood Fiber Industries



**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	JM HP Lightweight	Insulation fastener for cementitious and gypsum decks	Various	Johns Manville
2.	JM HP Lightweight	Metal plates used for membrane securement with HP fasteners.	3" dia	Johns Manville
3.	JM HP Locking Seam Plates	Metal plates with plastic inserts used for membrane securement with fasteners.	2" dia	Johns Manville
4.	JM Polymer Seam Plates	Plastic plates used for membrane securement with fasteners.	2" dia	Johns Manville
5.	NTB Magnum	Insulation fastener for cementitious and gypsum decks	Various	Johns Manville
6.	NTB Plate	Galvalume AZ55 stress plate	3" round	Johns Manville
7.	NTB Plastic Plate	Plastic plates for NTB 2" head fasteners.	3" round	Johns Manville
8.	UltraGuard AP	Insulation fastener for wood and steel.		Johns Manville
9.	UltraFast	Insulation fastener for wood and steel.		Johns Manville
10.	UltraFast ASAP	Pre-assembled Insulation fastener and plate		Johns Manville
11.	High Load Fasteners	Membrane fastener for wood and steel.		Johns Manville
12.	High Load Metal Plates	Galvalume AZ55 steel plate	2-3/8" round	Johns Manville
13.	APB Metal Plates	Galvalume AZ55 steel plate	2" round	Johns Manville
14.	UltraFast Metal Plate	Galvalume AZ55 steel plate	3" square 3" round	Johns Manville
15.	UltraFast Plastic Plate	High Density Polyolefin round plate	3" round	Johns Manville
16.	Dekfast Fasteners	Insulation and membrane fastener	Various	Construction Fasteners, Inc.



**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
17.	Dekfast Hex Plate	Insulation and membrane fastener	Various	Construction Fasteners, Inc.
18.	#12 & #14 Roofgrip	Insulation and membrane fastener	Various	ITW Buildex
19.	Metal Plate	Galvalume AZ50 stress plate	3" square	ITW Buildex
20.	Plastic Plate	Polyethylene stress plate	3.2" round	ITW Buildex
21.	Olympic Fasteners	Insulation and membrane fastener	Various	Olympic Mfg. Group
22.	Olympic Stainless Fasteners	Stainless steel insulation and membrane fastener	Various	Olympic Mfg. Group
23.	Lite-Deck Fasteners	Insulation fastener for cementitious and gypsum decks	Various	Olympic Mfg. Group
24.	NTB Magnum	Insulation fastener for cementitious and gypsum decks	Various	Olympic Mfg. Group
25.	GTL Fastener	Insulation fastener for cementitious and gypsum decks with a 3" round head plate.	Various	Olympic Mfg. Group
26.	Strap Toggle	Insulation fastener for steel, wood and gypsum decks.	Various	Olympic Mfg. Group
27.	Iron-Lok Toggle	Insulation fastener for steel, wood and gypsum decks.	Various	Olympic Mfg. Group
28.	Lite-Deck Plate	3" round Galvalume AZ55 stress plate	3" round	Olympic Mfg. Group
29.	NTB Plate	3" round Galvalume AZ55 stress plate	3" round	Olympic Mfg. Group
30.	NTB Metal Barbed Stress Plate	2" round Galvalume AZ55 stress plate	2" round	Olympic Mfg. Group
31.	NTB Plastic Plate	Plastic plates for NTB 2" head fasteners.	3" round	Olympic Mfg. Group
32.	Olympic Standard	3" round Galvalume AZ55 stress plate	3" round	Olympic Mfg. Group
33.	Olympic G-2	3.5" round Galvalume AZ55 stress plate	3.5" round	Olympic Mfg. Group
34.	Olympic	Plastic plates for fasteners.	3" round	Olympic Mfg. Group
35.	Rawl Fasteners	Insulation fastener for steel and wood decks	Various	Powers Fasteners Inc.



**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
36.	Powerlite	Insulation fastener for cementitious and gypsum decks	Various	Powers Fasteners Inc.
37.	Powerlite	3" round Galvalume AZ55 stress plate	3" round	Powers Fasteners Inc.
38.	Rawl Insulation Plate	3" round Galvalume AZ55 stress plate	3" round	Powers Fasteners Inc.
39.	Insul-Fixx Fastener	Insulation fastener for steel and wood decks	Various	SFS Stadler, Inc.
40.	HD Insul-Fixx Fastener	Insulation fastener for use in steel and concrete decks	Various	SFS Stadler, Inc.
41.	Insul-Fixx S	3" round Galvalume AZ55 stress plate	3" round	SFS Stadler, Inc.
42.	Insul-Fixx PG	3" round polyethylene stress plate	3" round	SFS Stadler, Inc.
43.	Tru-Fast Fasteners	Insulation and membrane fastener	Various	The Tru-Fast Corp.
44.	Tru-Fast Ultra Stainless Fasteners	Stainless steel insulation and membrane fastener	Various	The Tru-Fast Corp.
45.	Tru-Fast MP-3	3.23" round Galvalume AZ50 steel plate	3.23" round	The Tru-Fast Corp.
46.	Tru-Fast Plastic Plate	3" round polyethylene stress plate	3" round	The Tru-Fast Corp.

**EVIDENCE SUBMITTED:**

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Factory Mutual Research Corp.	J.I. 2W1A3.AM	Wind Uplift	01/03/94
	J.I.3Y6A0.AM	Wind Uplift	11/15/95
	J.I. 4Z0A5.AM	Wind Uplift	02/07/96
	1D6A1.AM	TAS 114	09/04/98
	0D9A8.AM		04/26/99
	3012974	Wind Uplift	06/03/02
	3008869	4470	03/19/01
	3015203	4470	01/15/03
	94.9.27	Wind Uplift	09/28/94
Dynatech Engineering Corp. Exterior Research & Design, LLC	#3705.09.96-1	TAS 114	09/03/96
	#3705.10.97-1	TAS 114	10/17/97
Independent Roof Testing and Consultanting of South Florida, Inc.	IRT # 01-005	TAS 114	03/13/01



**APPROVED ASSEMBLIES:**

**Membrane Type:** Single Ply, Thermoplastic, Adhered PVC  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** wood/steel/concrete/lightweight concrete/cementitious wood fiber/gypsum  
**System Type A:** All layers of insulation fully adhered with approved asphalt.

**All General and System Limitations apply.**

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
<b>ENRGY 2, ENRGY 3, JM ISO-1 Minimum 1.5" thick</b>	N/A	N/A
<b>Esgard Fiberboard, Huebert Fiberboard, Fiberboard, GAFTEMP Fiberboard Minimum 1" thick</b>	N/A	N/A
<b>Dens Deck Minimum ¼" thick</b>	N/A	N/A

**Note:** Existing roof shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup> Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

**Vapor Retarder:** (Optional) An FMRC approved vapor barrier approved for use with hot asphalt may be applied to the deck or base insulation layer.

**Barrier** None.

**Membrane:** UltraGard PVC Roofing Systems SR-50, 60 or 80, Plus 50 or Plus 60 or V-2/50 or V-2/60 installed utilizing UltraGard PVC Membrane Adhesive at a rate of 60 square feet/gallon or UltraGard PVC Latex Adhesive (where acceptable) at a rate of 40 square feet/gallon. Field sheets are to be lapped a minimum of 3" and heat seamed together using hot air equipment, which will give a minimum 1½" weld area. UltraGard Liquid PVC Seam Sealant is to be applied to all cut or non-encapsulated edges. Care shall be taken to avoid getting adhesive in the seam areas.

**Maximum Design Pressure:**

-342.5 psf	(concrete deck / JM ISO-1 / UltraGard PVC Membrane Adhesive / SR-50, 60, 80, V-2/50 or V-2/60 membrane) (See General Limitation #9.)
-130.5 psf	(concrete deck / JM ISO-1 / One-Step Adhesive / SR-50, 60, 80, V-2/50 or V-2/60 membrane) (See General Limitation #9.)
-310 psf	(concrete deck / JM ISO-1 with Dens Deck coverboard / UltraGard PVC Membrane Adhesive / SR-50, 60, 80, V-2/50 or V-2/60 membrane) (See General Limitation #9.)
-45 psf	(all other deck type / insulation / adhesive / membrane combinations). (See General Limitation #9.)



**Membrane Type:** Single Ply, Thermoplastic, Adhered PVC  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** wood/steel/concrete/cementitious wood fiber/gypsum  
**System Type B:** Base layer of insulation mechanically attached, top insulation layer fully adhered with approved asphalt.

**All General and System Limitations apply.**

<b>Base or Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ENRGY 2, ENRGY 3, PSI-25, JM ISO-1</b>		
<b>Minimum 1.5" thick</b>	<b>Fastener For Deck Type</b>	<b>1:2 ft<sup>2</sup></b>
<b>Minimum 2" thick</b>	<b>Fastener For Deck Type</b>	<b>1:2.6 ft<sup>2</sup></b>
<b>Esgard Fiberboard, Huebert Fiberboard, Fiberboard, GAFTEMP Fiberboard</b>		
<b>Minimum 1" thick</b>	<b>Fastener For Deck Type</b>	<b>1:2 ft<sup>2</sup></b>
<b>Dens Deck</b>		
<b>Minimum ¼" thick</b>	<b>Fastener For Deck Type</b>	<b>1:2 ft<sup>2</sup></b>

**Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any of the insulation listed for Base Layer, above.</b>		

**Note: Apply top layer of insulation in a full mopping of any approved mopping asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup> or OlyBond Adhesive Fastener at a rate of 1 gal./100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.**

**Vapor Retarder:** (Optional) An FMRC approved vapor barrier approved for use with hot asphalt may be applied to the deck or perlite base layer.

**Barrier:** None.

**Membrane:** UltraGard PVC Roofing Systems SR-50, 60 or 80, Plus 50 or Plus 60 or V-2/50 or V-2/60 installed utilizing UltraGard PVC Membrane Adhesive at a rate of 60 square feet/gallon or UltraGard PVC Latex Adhesive (where acceptable) at a rate of 40 square feet/gallon. Field sheets are to be lapped a minimum of 3" and heat seamed together using hot air equipment, which will give a minimum 1½" weld area. UltraGard Liquid PVC Seam Sealant is to be applied to all cut or non-encapsulated edges. Care shall be taken to avoid getting adhesive in the seam areas.

**Maximum Design Pressure:** -60 psf (steel and concrete decking) (See General Limitation #9.)  
 -45 psf (wood, cementitious wood fiber and gypsum decking) (See General Limitation #9.)



**Membrane Type:** Single Ply, Thermoplastic, Adhered PVC  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** wood/steel/concrete/cementitious wood fiber/gypsum  
**System Type C:** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
<b>ENRGY 2, ENRGY 3, JM ISO-1</b> Minimum 1.5" thick	N/A	N/A
<b>Esgard Fiberboard, Huebert Fiberboard, Fiberboard, GAFTEMP Fiberboard</b> Minimum 1" thick	N/A	N/A
<b>Dens Deck</b> Minimum ¼" thick	N/A	N/A

**Note: All layers shall be simultaneously fastened. See top layer below for fasteners and density.**

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
<b>ENRGY 2, ENRGY 3, PSI-25, JM ISO-1</b> Minimum 1.5" thick	Fastener For Deck Type	1:2 ft <sup>2</sup>
Minimum 2" thick	Fastener For Deck Type	1:2.6 ft <sup>2</sup>
<b>Esgard Fiberboard, Huebert Fiberboard, Fiberboard, GAFTEMP Fiberboard</b> Minimum 1" thick	Fastener For Deck Type	1:2 ft <sup>2</sup>
<b>Dens Deck</b> Minimum ¼" thick	Fastener For Deck Type	1:2 ft <sup>2</sup>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Vapor Retarder:** (Optional) An FMRC approved vapor barrier approved for use with hot asphalt may be applied to the deck or perlite base layer.

**Barrier:** None.

**Membrane:** UltraGard PVC Roofing Systems SR-50, 60 or 80, Plus 50 or Plus 60 or V-2/50 or V-2/60 installed utilizing UltraGard PVC Membrane Adhesive at a rate of 60 ft<sup>2</sup>/gal or UltraGard PVC Latex Adhesive (where acceptable) at a rate of 40 ft<sup>2</sup>/gal. Field sheets are to be lapped a minimum of 3" and heat seamed together using hot air equipment, which will give a minimum 1½" weld area. UltraGard Liquid PVC Seam Sealant is to be applied to all cut or non-encapsulated edges. Care shall be taken to avoid getting adhesive in the seam areas.

**Maximum Design Pressure:** -60 psf (steel and concrete decking) (See General Limitation #9.)  
-45 psf (wood, cementitious wood fiber and gypsum decking) (See General Limitation #9.)



**Membrane Type:** Single Ply, Thermoplastic, Mechanically Fastened PVC  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** wood/steel/concrete/cementitious wood fiber/gypsum  
**System Type D:** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply.**

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ENRGY 2, ENRGY 3, PSI-25, JM ISO-1 Minimum 1.4" thick</b>	N/A	N/A
<b>Fesco Foam, DuraFoam Minimum 1.5" thick</b>	N/A	N/A
<b>Fiberglas Roof Insulation Minimum 1<sup>5</sup>/<sub>16</sub>" thick</b>	N/A	N/A
<b>Fesco Board, DuraBoard Minimum 1/4" thick</b>	N/A	N/A
<b>Dens Deck Minimum 1/4" thick</b>	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the membrane, at an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See membrane below for fasteners and density.

**Vapor Retarder:** (Optional) An FMRC approved vapor barrier approved for use with hot asphalt may be applied to the deck or perlite base layer.

**Barrier:** None.

**Membrane:**

**Wood, Steel & Concrete Decking:**

**Option #1:** UltraGard PVC Roofing Systems SR-50, 60 or 80, Plus 50 or Plus 60 or V-2/50 or V-2/60 installed in sheets up to 81" wide with a 5" overlap and fastened in the lap 6" o.c. using Tru-Fast HD, AMP-A1P or Rawl fasteners with 2" Trilock or Rawl 2" Membrane Plates, UltraFast #14, Dekfast #14, Dekfast #15 Heavy or TPR fasteners with Dekfast DK Barbed Plates, HD Insul-Fixx or TPR fasteners with ES lap plates, or Isofast IF2 or TPR fasteners with IFC/IW-82x40 Domed Convex Plates. Sheets are then heat seamed together with a minimum 1 1/2" weld area. UltraGard liquid PVC seam sealant is to be applied to all cut or non-encapsulated edges. (1:3.166 ft<sup>2</sup>)

**Option #2:** UltraGard PVC Roofing Systems SR-50, 60 or 80, Plus 50 or Plus 60 or V-2/50 or V-2/60 installed in sheets 53" wide with a 5" overlap and fastened at the lap 18" o.c. using the fastener options noted above. Sheets are then heat seamed together with a minimum 1 1/2" weld area. UltraGard liquid PVC seam sealant is to be applied to all cut or non-encapsulated edges. (1:6 ft<sup>2</sup>)



**Option #3 (Grade E steel & concrete only):** UltraGard PVC Roofing Systems SR-50, 60 or 80, Plus 50 or Plus 60 or V-2/50 or V-2/60 installed in sheets 75" wide with a 5" overlap and fastened at the lap 12" o.c. using SFS Extral Load Fastener HD and Extra Load Plate or UltraGard High Load Fastener and High Load Plates. Sheets are then heat seamed together with a minimum 2" weld area. UltraGard liquid PVC seam sealant is to be applied to all cut or non-encapsulated edges. (1:5.83 ft<sup>2</sup>)

***Cementitious Wood Fiber & Gypsum Decking:***

UltraGard PVC Roofing Systems SR-50, 60 or 80, Plus 50 or Plus 60 or V-2/50 or V-2/60 installed in sheets 53" wide with a 5" overlap and fastened at the lap 6" o.c. using Rawlite fasteners and Rawlite Lap Plates JM NTB with 2" head or NTB Magnum with 2 in Head fasteners. Sheets are then heat seamed together with a minimum 1½" weld area. UltraGard liquid PVC seam sealant is to be applied to all cut or non-encapsulated edges. (1:2 ft<sup>2</sup>).

Maximum Design  
Pressure:

-45 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, Thermoplastic, Mechanically Fastened PVC  
**Deck Type 7:** Recover, Non-Insulated  
**Deck Description:** wood/steel/concrete/lightweight concrete/cementitious wood fiber/gypsum  
**System Type E:** Membrane attached to deck.

**All General and System Limitations apply.**

**Barrier** Approved slip sheet (non-"Plus" membranes only).

**Membrane**

**Wood, Steel & Concrete Decking:**

**Option #1:** UltraGard PVC Roofing Systems SR-50, 60 or 80, Plus 50 or Plus 60 or V-2/50 or V-2/60 installed in sheets up to 81" wide with a 5" overlap and fastened in the lap 6" o.c. using Tru-Fast HD, AMP-A1P or Rawl fasteners with 2" Trilock or Rawl 2" Membrane Plates, UltraFast #14, Dekfast #14, Dekfast #15 Heavy or TPR fasteners with Dekfast DK Barbed Plates, HD Insul-Fixx or TPR fasteners with ES lap plates, or Isofast IF2 or TPR fasteners with IFC/IW-82x40 Domed Convex Plates. Sheets are then heat seamed together with a minimum 1½" weld area. UltraGard liquid PVC seam sealant is to be applied to all cut or non-encapsulated edges. (1:3.166 ft<sup>2</sup>)

**Option #2:** UltraGard PVC Roofing Systems SR-50, 60 or 80, Plus 50 or Plus 60 or V-2/50 or V-2/60 installed in sheets 53" wide with a 5" overlap and fastened at the lap 18" o.c. using the fastener options noted above. Sheets are then heat seamed together with a minimum 1½" weld area. UltraGard liquid PVC seam sealant is to be applied to all cut or non-encapsulated edges. (1:6 ft<sup>2</sup>)

**Option #3 (Grade E steel & concrete only):** UltraGard PVC Roofing Systems SR-50, 60 or 80, Plus 50 or Plus 60 or V-2/50 or V-2/60 installed in sheets 75" wide with a 5" overlap and fastened at the lap 12" o.c. using SFS Extral Load Fastener HD and Extra Load Plate or UltraGard High Load Fastener and High Load Plates. Sheets are then heat seamed together with a minimum 2" weld area. UltraGard liquid PVC seam sealant is to be applied to all cut or non-encapsulated edges. (1:5.83 ft<sup>2</sup>)

**Lightweight Concrete Over 22 ga. steel pan:**

UltraGard PVC SR-50, SR-60, SR-80, V-2/50, V-2/60, Plus 50 or Plus 60 installed in sheets 75" wide with a 5" overlap and fastened through the lightweight concrete to the steel deck at the lap 6" o.c. using UltraGard High Load Fasteners and Plates or SFS Stadler ELF HD #15 Fasteners with SFS LR6 metal plates. Sheets are then heat seamed together with a minimum 1.5" weld area. UltraGard liquid PVC seam sealant is to be applied to all cut or non-encapsulated edges.

**Cementitious Wood Fiber & Gypsum Decking:**

UltraGard PVC Roofing Systems SR-50, 60 or 80, Plus 50 or Plus 60 or V-2/50 or V-2/60 installed in sheets 53" wide with a 5" overlap and fastened at the lap 6" o.c. using Rawlite fasteners and Rawlite Lap Plates JM NTB with 2" head or NTB Magnum with 2 in Head fasteners. Sheets are then heat seamed together with a minimum 1½" weld area. UltraGard liquid PVC seam sealant is to be applied to all cut or non-encapsulated edges. (1:2 ft<sup>2</sup>).

Maximum Design Pressure:

-60 psf (for lightweight concrete over steel panel) (See General Limitation #7.)  
-45 psf (for all other applications) (See General Limitation #9.)



NOA No.: 06-0522.13  
Expiration Date: 06/21/11  
Approval Date: 07/27/06  
Page 14 of 15

## RECOVER SYSTEM LIMITATIONS:

1. All System Limitations and General Limitations shall apply. See specific deck type Notice of Acceptance for deck type System Limitations.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.: 06-0522.13  
Expiration Date: 06/21/11  
Approval Date: 07/27/06  
Page 15 of 15