



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**SR Products
13311 Union Avenue
Cleveland, OH 44120**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: SR Products Built-up Roofing Systems Over Gypsum Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 6.

The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 06-0815.06
Expiration Date: 04/10/13
Approval Date: 04/10/08
Page 1 of 6**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: BUR
Deck Type: Poured Gypsum
Maximum Design Pressure -67.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
S.R. Superior Ply	3' x 110'	TAS 110	Roofing sheet comprised of fiberglass mat and modified bitumen compound.
S.R. Superior Ply Ultra	3' x 75'	TAS 110	Roofing sheet comprised of glass fiber, strand and non-woven polyester mat coated with oxidized asphalt surfaced with fine sand.
Superior Flex Moisture Guard Plus	5 Gallon Pails	ASTM D4586	A Fiberglass reinforced polymer-enriched waterproofing material.
Superior Flex Maxi Seal	5 Gallon Pails	ASTM D3019	A two component modified coal tar epoxy used as a protective roof coating.
Superior Flex Seal Plus	5 Gallon Pails	ASTM D3019	A thermoplastic rubber coating and mastic designed for waterproofing a variety of structural surfaces.
S.R. Insulation Adhesive	5 Gallon Pails	Proprietary	A two-component modified coal tar epoxy designed for adhering a wide range of approved insulation materials to standard roof deck assemblies.

APPROVED INSULATIONS:

Table 2

Product Name	Product Description	Manufacturer (With Current NOA)
AC Foam II & III	Polyisocyanurate foam insulation	Atlas Roofing Corporation
H-Shield	Polyisocyanurate foam insulation	Hunter Panels, LLC

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	N/A	N/A	N/A	N/A



NOA No.: 06-0815.06
 Expiration Date: 04/10/13
 Approval Date: 04/10/08
 Page 2 of 6

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
IRT-ARCON, Inc.	IRT06064	TAS 114 "J"	5/18/06
	IRT07016	TAS 114 "J"	5/18/06
FM Approvals	3028326	4470	10/26/07
Underwriters Laboratories, Inc	R19353	Fire Classification	10/01/07
	R13477	Fire Classification	09/17/07
	R22025	Fire Classification	01/24/06
Momentum Technologies, Inc	EX30F6A	Physical Properties	10/17/06
	EX19H5A	Physical Properties	10/17/06
	EX29F6A	Physical Properties	10/17/06
	TX08L6A	TAS 117(B) & TAS 110	12/13/06
	TX08L6A	TAS 117(B) & TAS 110	01/05/07
	TX07E7A	ASTM D4586	06/21/07
	EX20C7A	ASTM D903	06/29/07
	TX07E7B	ASTM D3019	06/21/07
	TX07E7C	ASTM D3019	06/21/07



APPROVED ASSEMBLIES

Deck Type 6I: Poured Gypsum, Insulated

Deck Description: Poured gypsum

System Type A: Anchor sheet fully adhered to the gypsum deck then adhere insulation and membranes to the anchor sheet.

All General and System Limitations apply.

Anchor Sheet Install S.R. Superior Ply Ultra fully adhered to the gypsum deck using S.R. Superior Flex Maxi Seal applied at 2-2½ gallons/ 100 ft² to the gypsum deck.

One or more layers of any of the following insulations.

Base Layer Insulation	Insulation Fasteners (Table 3)	Fastener Density/ft²
AC Foam II		
Minimum 2" thick	N/A	N/A

Note: Insulation shall be partially adhered to the anchor sheet. Apply beads of S.R. Insulation Adhesive, 1" wide, spaced 6" to the anchor sheet. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation panels listed are minimum sizes and dimensions.

Ply Sheet: Install 3 full plies of S.R. Superior Ply Ultra adhered with S.R. Superior Flex Maxi Seal applied at 2-2½ gallons/ 100 ft² to the anchor sheet.

Cap Sheet: N/A

Surfacing: N/A

Maximum Design Pressure: -45 psf (See General Limitation #9)



Deck Type 6: Poured Gypsum, Non-Insulated

Deck Description: Poured gypsum

System Type F: Anchor sheet fully adhered to gypsum deck.

All General and System Limitations apply.

Anchor Sheet Install S.R. Superior Ply Ultra fully adhered to the gypsum deck using S.R. Superior Flex Maxi Seal applied at 2-2½ gallons/ 100 ft² to the deck.

Ply Sheet: Install 2 full plies of S.R. Superior Ply Ultra adhered with S.R. Superior Flex Maxi Seal applied at 2-2½ gallons/ 100 ft² to the anchor sheet.

Cap Sheet: N/A

Surfacing: N/A

Maximum Design Pressure: -67.5 psf (See General Limitation #9)



GYPSUM DECK SYSTEM LIMITATIONS:

1. For gypsum deck application where the specific deck construction is not referenced, the deck shall be bulb tees perpendicular to purlins and spaced at 24in on center to support form boards. Place reinforcing mesh with 16 Ga wire at tight angles to sub purlins with 6in laps at ends (no laps at sides). Then pour gypsum concrete.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 06-0815.06
Expiration Date: 04/10/13
Approval Date: 04/10/08
Page 6 of 6