



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Versico, Inc.
1555 Ritner Highway
Carlisle, PA 17013**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Versico VersiFlex Single Ply PVC Roof Systems over Poured Gypsum Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This new NOA consists of pages 1 through 6.

The submitted documentation was reviewed by Alex Tigera.



**NOA No: 06-1005.01
Expiration Date: 08/17/11
Approval Date: 03/08/07
Page 1 of 6**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply
Material: PVC
Deck Type: Poured Gypsum
Maximum Design Pressure -135 psf
Fire Classification: See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product Name</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
VersiFlex	various	TAS131	Reinforced white or colored TPO membrane.
Fast 100 Adhesive	various	TAS 110	Spray Polyurethane Adhesive
Fast 100-P Adhesive	various	TAS 110	Spray Polyurethane Adhesive
Fast 102 Adhesive	various	TAS 110	Spray Polyurethane Adhesive
OlyBond 500 BA	various	TAS 110	Spray Polyurethane Adhesive
VersiFlex Bonding Adhesive	various	TAS 110	Solvent-based bonding adhesive.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
Hy Therm, Pyrox, White Line	Isocyanurate Insulation	Apache Products Co.
ACFoam I, ACFoam II	Isocyanurate Insulation	Atlas Roofing Corp.
ACFoam Composite	Isocyanurate Insulation with perlite facer	Atlas Roofing Corp.
Polyisocyanurate MP, MP-H, MP-N, MP-W	Polyisocyanurate roof insulation.	Versico, Inc.
Versico Recovery Board	High Density Wood Fiberboard.	Versico, Inc.
Foamular 150, 250, 400, 404, 600	Extruded Polystyrene insulation	Owens Corning
Foamular Durapink-FA Insulation	Extruded Polystyrene for white or black adhered system.	Owens Corning
Foamular Durapink Insulation	Extruded Polystyrene for white or black mechanically fastened roof systems.	Owens Corning
Foamular ½" Board	Extruded Polystyrene recovery board.	Owens Corning
Styrofoam	Extruded polystyrene insulation	Dow
DensDeck, DensDeck Prime	Silicon treated gypsum	G-P Products



NOA No: 06-1005.01
Expiration Date: 08/17/11
Approval Date: 03/08/07
Page 2 of 6

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
Ultra/M-II II Iso/glas	Polyisocyanurate foam insulation	Homasote Co.
ENRGY 2, ENERGY PSI-25	Isocyanurate Insulation	Johns Manville
Fesco Foam	Isocyanurate Insulation with perlite facer	Johns Manville
Wood Fiberboard	Regular wood fiber insulation	Generic
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic
Perlite Insulation Board	Perlite Insulation	Generic
Type X Gypsum	Gypsum Wallboard	Generic
XPS	Extruded polystyrene	Generic
Structodeck	High Density Wood Fiber insulation board.	Masonite
Fiber Base	Asphalt coated wood fiber insulation	Temple Inland Forest Products Corp.

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	VersicoNTB	Insulation fastener for cementitious and gypsum decks	Various	Versico, Inc.
2.	VersicoNTB Plate	Metal plates used for membrane securement with Versico NTB fasteners.	3" diameter	Versico, Inc.
3.	Versico Locking Seam Plates	Metal plates with plastic inserts used for membrane securement with fasteners.	2" diameter	Versico, Inc.
4.	Versico Polymer Seam Plates	Plastic plates used for membrane securement with fasteners.	2" diameter	Versico, Inc.
5.	Lite-Deck Fasteners	Insulation fastener for cementitious and gypsum decks	Various	Olympic Mfg. Group
6.	NTB Magnum	Insulation fastener for cementitious and gypsum decks	Various	Olympic Mfg. Group



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
7.	GTL Fastener	Insulation fastener for cementitious and gypsum decks with a 3" round head plate.	Various	Olympic Mfg. Group
8.	Strap Toggle	Insulation fastener for steel, wood and gypsum decks.	Various	Olympic Mfg. Group
9.	Iron-Lok Toggle	Insulation fastener for steel, wood and gypsum decks.	Various	Olympic Mfg. Group
10.	Lite-Deck Plate	3" round Galvalume AZ55 stress plate	3" round	Olympic Mfg. Group
11.	NTB Plate	3" round Galvalume AZ55 stress plate	3" round	Olympic Mfg. Group
12.	NTB Metal Barbed Stress Plate	2" round Galvalume AZ55 stress plate	2" round	Olympic Mfg. Group
13.	NTB Plastic Plate	Plastic plates for NTB 2" head fasteners.	3" round	Olympic Mfg. Group
14.	Olympic Standard	3" round Galvalume AZ55 stress plate	3" round	Olympic Mfg. Group
15.	Olympic G-2	3.5" round Galvalume AZ55 stress plate	3.5" round	Olympic Mfg. Group
16.	Olympic	Plastic plates for fasteners.	3" round	Olympic Mfg. Group
17.	Powerlite	Insulation fastener for cementitious and gypsum decks	Various	Powers Fasteners Inc.
18.	Powerlite	3" round Galvalume AZ55 stress plate	3" round	Powers Fasteners Inc.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Factory Mutual Research Corp.	3021764	4470	01/11/06
	3009502	4470	12/21/00
	3014692	4470	08/05/03



APPROVED ASSEMBLIES

- Membrane Type:** Single Ply, Thermoplastic, PVC
- Deck Type 6I:** Poured Gypsum, Insulated
- Deck Description:** Poured Gypsum Concrete
- System Type A:** One or more layers of insulation adhered with OlyBond 500 BA or Fast Adhesive; membrane fully adhered.

All General and System Limitations apply.

Note: All insulation shall be adhered with OlyBond 500 BA at a rate of 1 gallon/sq or Fast 100, Fast 100LV with full coverage application.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Polyisocyanurate MP-W Minimum 1.5" thick	N/A	N/A
Polyisocyanurate MP, MP-H, MP-N Minimum 1.4" thick	N/A	N/A
Versico Recovery Board Minimum 1/2" thick	N/A	N/A

Barrier: None.

Membrane: VersiFlex, 50, 60 or 80 mil membrane fully adhered to the insulation using VersiFlex Bonding Adhesive applied to the substrate at a rate of 1 gal/60 ft.²

Maximum Design Pressure:

- 112.5 psf (for Polyisocyanurate Insulation) with OlyBond 500 BA
(See General Limitation #9)
- 135 psf (for Wood Fiber Insulation) with OlyBond 500 BA
(See General Limitation #9)
- 45 psf (for Polyisocyanurate Insulation) with Fast Adhesive
(See General Limitation #9)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No: 06-1005.01
Expiration Date: 08/17/11
Approval Date: 03/08/07
Page 6 of 6