



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Intertape Polymer Corp.
50 Abbey Ave
Truro, Nova Scotia, CANADA
B2N6W4**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Nova Seal Premium Roofing Underlayment

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 06-0913.03 and consists of pages 1 through 3.
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 07-0307.08
Expiration Date: 02/01/12
Approval Date: 08/16/07
Page 1 of 3**

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: Polypropylene

SCOPE:

This acceptance is for **Nova Seal Premium Roofing Underlayment** as manufactured by Intertape Polymer Corporation, as described in this Notice of Acceptance, for use with approved prepared roof assemblies where TAS 104 or ASTM D 226 Type I or II underlayment is specified. (See Limitations Below.)

PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Nova Seal Premium Roofing Underlayment	Width = 36", 38", up to 144" Length = min. 25'	ASTM D 226 Type I & ASTM D 226 Type II & TAS 104	A hybrid underlayment composed of a woven-polypropylene core, coated on both sides with a polymer coating.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Intertek ETL SEMKO	3092073COQ-002	TAS-104	08/16/06

LIMITATIONS:

1. Fire classification is not part of this acceptance.
2. Nova Seal Premium Roofing Underlayment can be used in any prepared roof assemblies where an ASTM D 226 Type I & II is required.
3. This acceptance is for prepared roofing applications. Minimum deck requirements and underlayment requirements shall be in compliance with applicable building code.
4. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.
5. Nova Seal Premium Roofing Underlayment shall not be left exposed as a temporary roof for longer than 30 days of application. Intertape Polymer Corp., reserves the right to revise or alter product exposure times; not to exceed the preceding maximum time limitations.



NOA No.: 07-0307.08
Expiration Date: 02/01/12
Approval Date: 08/16/07
Page 2 of 3

INSTALLATION:

1. Nova Seal Premium Roofing Underlayment and its components shall be installed in strict compliance with applicable Building Code.
2. Nova Seal Premium Roofing Underlayment shall be installed with a minimum 4-inch head lap in a shingle layer fashion and a 6" end lap where required. Fastener spacing shall be a maximum of 4" o.c. on the head and end laps and 12" o.c. vertically and horizontally in the field of the membrane.
3. Nova Seal Premium Roofing Underlayment is a component used in roof assemblies. Roof assemblies are approved under specific assembly Notice of Acceptance.
4. Nova Seal Premium Roofing Underlayment may be used with Asphaltic shingles, Wood shakes and shingles, Non-structural metal roofing, and quarry slate.
5. For fire classifications of specific roof assemblies using Nova Seal Premium Roofing Underlayment refer to a current Approved Roofing Materials Directory for fire ratings of this product

LABELING:

All packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and the following statement: "Miami-Dade County Product Control Approved".

BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any documents required by the Building Official or applicable building code in order to properly evaluate the installation of these materials.

END OF THIS ACCEPTANCE



NOA No.: 07-0307.08
Expiration Date: 02/01/12
Approval Date: 08/16/07
Page 3 of 3