



BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

www.maimidade.gov/buildingcode

NOTICE OF ACCEPTANCE (NOA)

Construction Glass Industries Corporation
10100 N.W. 25th Street
Miami, FL 33172

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Aluminum Tube Mullion – L.M.I.

APPROVAL DOCUMENT: Drawing No. **M95-13A**, titled "Mullion Elevations and Details", sheets 1 through 3 of 5, dated 11/25/1995 with revision C dated 04/28/2007, prepared by Al-Farooq Corporation, dated 05/16/2007, signed and sealed by Humayoun Farooq, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official. This NOA **revises and renews** NOA # **02-0123.06** and consists of this page 1 and evidence page E-1, as well as approval document mentioned above.

The submitted documentation was reviewed by **Jaime D. Gascon, P.E.**



J. Gascon
5/24/07

NOA No. 07-0312.02
Expiration Date: March 28, 2008
Approval Date: June 14, 2007
Page 1

Construction Glass Industries Corporation

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Manufacturer's die drawings and sections.
2. Drawing No. **M95-13A**, titled "Mullion Elevations and Details", sheets 1 through 3 of 5, dated 11/25/1995 with revision C dated 04/28/2007, prepared by Al-Farooq Corporation, dated 05/16/2007, signed and sealed by Humayoun Farooq, P.E.

B. TESTS

1. Test reports on 1) Uniform Static Air Pressure Test, Loading per FBC PA-202-94 along with marked-up drawings and installation diagram of an aluminum fixed window, prepared by Hurricane Engineering & Testing Inc. Test Report No. **HETI-96-525**, dated February 12, 1996, signed and sealed by Hector M. Medina, P.E.
(Submitted under NOA#02-123.06)
2. Test reports on 1) Large Missile Impact Test, Loading per PA 201-94 along with marked-up drawings and installation diagram of an aluminum fixed window, prepared by Hurricane Test Laboratory, Inc. Test Report No. **HTL-0080-0303-96**, dated 03/06/96, signed and sealed by Timothy S. Marshall, P.E.
(Submitted under NOA#02-123.06)

C. CALCULATIONS

1. Anchor verification calculations and structural analysis, prepared by Al-Farooq Corporation, dated 1/17/02, signed and sealed by Humayoun Farooq, P.E.

D. QUALITY ASSURANCE

1. Miami Dade Building Code Compliance Office (BCCO).

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS


1. Statement letter of conformance, dated May 14, 2007, signed and sealed by Humayoun Farooq, P.E.
2. Statement letter from manufacturer stating that the product has not changed and requesting a One-Year Renewal to allow the time to perform a verification test, dated May 8, 2007, signed by Jorge Santaella.
3. Letter from laboratory confirming manufacturer has contracted and scheduled verification tests, issued by Hurricane Test Laboratory, dated March 06, 2007, signed by Monica Reum.

G. OTHER



1. None


Jaime D. Gascon, P.E.

Chief, Product Control Division
NOA No. 07-0312.02
Expiration Date: March 28, 2008
Approval Date: June 14, 2007




CLIP ANGLE
6063-T5



MULLION CLIP (ALT. TO CLIP ANGLE)

CGI-383
6063-T6



**MULLIONS CONTAINING TYPICAL GLAZING PRODUCTS
HORIZONTAL OR VERTICAL**

SEE WINDOW OR DOOR APPROVAL FOR FASTENERS SIZES AND SPACING

ALL MULLIONS 6063-T6 MIN.

**RECTANGULAR ALUMINUM TUBE MULLIONS
USING MULLION PROPERTIES ONLY**

NOTES:

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE 2004 EDITION INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).

ALL GLAZING PRODUCTS USED WITH THESE MULLIONS MUST MEET THE APPLICABLE BUILDING CODE REQUIREMENTS I.E: WIND LOAD, WATER INFILTRATION, FORCED ENTRY RESISTANCE, SAFEGUARDS ETC.

WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.

ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS, EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL COVERING (STUCCO, TILE ETC.).

ANCHORING CONDITIONS OTHER THAN THOSE SHOWN IN THESE DETAILS ARE NOT PART OF THIS APPROVAL.

A LOAD DURATION INCREASE IN ALLOWABLE STRESS IS USED IN DESIGN OF ANCHORS INTO WOOD ONLY.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF 2004 FLORIDA BLDG. CODE SECTION 2003.8.4.

INSTRUCTIONS:

USE CHARTS AND GRAPHS AS FOLLOWS.


- STEP 1** DETERMINE DESIGN LOAD REQUIRED PER ASCE 7 FOR PARTICULAR OPENING.
- STEP 2** USE DADE COUNTY APPROVED GLAZING PRODUCTS MEETING ABOVE LOAD REQUIREMENTS.
- STEP 3** USE CONNECTION TO MULLION AS PER PRODUCT APPROVAL.
- STEP 4** USING GRAPHS ON SHEET 2 SELECT MULLION SIZE WITH DESIGN RATING MORE THAN DESIGN LOAD SPECIFIED IN STEP 1 ABOVE.
- STEP 5** USING ANCHOR TYPES ON SHEETS 4 & 5, AND ANCHOR GRAPHS ON SHEET 3, SELECT ANCHOR TYPE WITH DESIGN RATING MORE THAN THE DESIGN LOADS SPECIFIED IN STEP 1 ABOVE.

MULLION SYSTEM IS RATED FOR LARGE MISSILE IMPACT, AND CAN BE USED WITH ALL MIAMI-DADE COUNTY APPROVED IMPACT AND NON-IMPACT RESISTANT PRODUCTS.

Engr: DR. HUMAYOUN FAROOQ
STRUCTURES
FLA. PE # 16557
C.A.N. 3538

[Signature]
MAY 16 2007

PRODUCT REVISED
as complying with the Florida Building Code
Acceptance No 07-0312.02
Expiration Date 03/28/2008
By *[Signature]*
Miami-Dade Product Control Division



AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
MULLION M95-13A-NEW








MULLION ELEVATIONS AND DETAILS

CGI WINDOWS & DOORS.
10100 NW 25 STREET
MIAMI, FL. 33172
TEL. (305) 593-6590 FAX. (305) 593-6592

no	date	by	description
A	01.24.96	T.H.	ANCHOR/GRAPHS REVISED
B	01.16.02	T.H.	ANCHORS TYPE A & B REV.
C	04.28.07		REV. PER BCCO COMMENTS

date: 11-25-95
scale: 1/2" = 1"
dr. by: HAMID
chk. by:

drawing no.
M95-13A
sheet 1 of 5



TYPICAL MULLION ARRANGEMENTS

$$\text{WIDTH (W)} = \frac{W1 + W2}{2}$$

NOTE:
MULLIONS RATED IN THESE CHARTS MAY BE ORIENTED
VERTICALLY OR HORIZONTALLY.
(INTERPOLATION BETWEEN WIDTHS ALLOWED)

Engr. DR. HUMAYOUN FAROOQ
STRUCTURES
FLA. PE # 16557
C.A.N. 3538

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 07-0312.02
Expiration Date 03/28/2008

By *[Signature]*
Miami Dade Product Control
Division

MULLIONS

MAY 16 2007

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
MULLION M95-13A-NEW

MULLION ELEVATIONS AND DETAILS

CGI WINDOWS & DOORS.

10100 NW 25 STREET
MIAMI, FL. 33172

TEL. (305) 593-6590 FAX. (305) 593-6592

revisions:
no date by description

date: 11-25-95

scale: 1/2" = 1"






dr. by: HAMID

chk. by:

drawing no.

M95-13A

sheet 2 of 5



TYPICAL MULLION ARRANGEMENTS

$$\text{WIDTH (W)} = \frac{W1 + W2}{2}$$

NOTE:

ANY ANCHOR CONDITION SHOWN HEREIN MAY COVER LOCATIONS AT HEAD, SILL OR JAMB ENDS.

FOR ANCHORS DESCRIPTION SEE SHEETS 4 & 5.
(INTERPOLATION BETWEEN WIDTHS OR SPANS ALLOWED)

Engr. DR. HUMAYOUN FAROOQ
STRUCTURES
FLA. PE # 16557
C.A.N. 3538

[Signature]
MAY 16 2007

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 07-0312-02
Expiration Date 03/28/2008
By *[Signature]*
Miami Dade Product Control
Division

ANCHORS

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
MULLION\M95-13A-NEW

MULLION ELEVATIONS AND DETAILS

CGI WINDOWS & DOORS.

10100 NW 25 STREET
MIAMI, FL. 33172

TEL. (305) 593-6590 FAX. (305) 593-6592




revisions:	no	date	description

date: 11-25-95
scale: 1/2" = 1"
dr. by: HAMID
chk. by:



drawing no.
M95-13A

sheet 3 of 5

ANCHORS TYPE 'A'



ANCHORS TYPE 'B'





TAPCONS

INTO 2BY WOOD BUCKS OR WOOD STRUCTURES
1-3/8" MIN. PENETRATION INTO WOOD
THRU 1BY BUCKS INTO CONC. OR MASONRY
1-1/4" MIN. EMBED INTO CONC. OR MASONRY

ANCHOR EDGE DISTANCES:

INTO CONCRETE AND MASONRY = 2" MIN.
INTO WOOD STRUCTURE = 1" MIN.
INTO METAL STRUCTURE = 5/8" MIN.

ANCHORS TYPE 'C'



WOOD BUCKS NOT BY C.G.I.
MUST SUSTAIN LOADS IMPOSED.

Engr. DR. HUMAYOUN FAROOQ
STRUCTURES
FLA. PE # 16557
C.A.N. 3538

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 07-0312.02
Expiration Date 03/29/2008

By *[Signature]*
Miami Dade Product Control
Division
MAY 16 2007




af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
12335 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
MULLION M95-13A-NEW

MULLION ELEVATIONS AND DETAILS
CGI WINDOWS & DOORS.
10100 NW 25 STREET
MIAMI, FL. 33172
TEL. (305) 593-6590 FAX. (305) 593-6592

revisions:	no.	date	description

date: 11-25-95
scale: 1/2" = 1"
dr. by: HAMID
chk. by:
drawing no.
M95-13A
sheet 4 of 5

ANCHORS TYPE 'D'



Engr. DR. HUMAYOON FAROOQ
STRUCTURES
FLA. PE # 16557
C.A.N. 3538

MAY 16 2007

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 07-0312-02
Expiration Date 03/28/2008

By *[Signature]*
Miami Dade Product Control
Division

revisions:

no	date	by	description

date: 11-25-95
scale: 1/2" = 1"
dr. by: HAMID
chk. by:

drawing no.
M95-13A
sheet 5 of 5

MULLION ELEVATIONS AND DETAILS

CGI WINDOWS & DOORS.
10100 NW 25 STREET
MIAMI, FL. 33172
TEL. (305) 593-6590 FAX. (305) 593-6592

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
12365 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978

afc
MULLION M95-13A-NEW