



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Versico, Inc.
1555 Ritner Highway
Carlisle, PA 17013**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Versico VersiWeld Single Ply TPO Roof Systems over Lightweight Concrete Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This revises NOA #06-0406.14 and consists of pages 1 through 9.
The submitted documentation was reviewed by Alex Tigera.



**NOA No: 07-0314.08
Expiration Date: 09/04/08
Approval Date: 11/15/07
Page 1 of 9**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply
Material: TPO
Deck Type: Lightweight Concrete Decks
Maximum Design Pressure -495 psf
Fire Classification: See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product Name</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
VersiWeld VersiFleece	various	TAS 131	Reinforced white or colored TPO membrane with fleece backing.
VersiFleece AC TPO 120 mil	Various	TAS 131	Reinforced white or colored TPO membrane with fleece backing.
VersiFleece AC TPO 135 mil	Various	TAS 131	Reinforced white or colored TPO membrane with fleece backing.
VersiWeld, VersiWeld Plus	various	TAS 131	Reinforced white or colored TPO membrane.
VersiWeld EF/ES	various	TAS 131	Reinforced white or colored FR TPO membrane.
CCW 702 Primer	various	TAS 110	Solvent-Based Primer
CCW 702LT Primer	various	TAS 110	Low-Temperature Solvent-Based Primer
CCW 714 Primer	various	TAS 110	Water-Based Primer
CCW 725 Vapor Barrier	various	TAS 110	40 mil Vapor Barrier
Fast 100 Adhesive	various	TAS 110	Spray Polyurethane Adhesive
Fast 100-P Adhesive	various	TAS 110	Spray Polyurethane Adhesive
Fast 102 Adhesive	various	TAS 110	Spray Polyurethane Adhesive
Versico One Step	Various	TAS 110	Polyurethane Adhesive
Versico Olybond 500 BA	Various	TAS 110	Polyurethane Adhesive
Versico Versigrip	Various	TAS 110	Polyurethane Adhesive
Carlisle Foamular Durapink Insulation	various	TAS 110	Extruded Polystyrene for white or black mechanically fastened roof systems.
VersiWeld Bonding Adhesive	various	TAS 110	Solvent-based bonding adhesive.
Aqua Base 120 Bonding Adhesive	Various	TAS 110	Water-based bonding adhesive
CP-5067 Applied Adhesive	Various	TAS 110	Asphalt-modified Polyether adhesive



NOA No: 07-0314.08
 Expiration Date: 09/04/08
 Approval Date: 11/15/07
 Page 2 of 9

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
N/A	N/A	N/A

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	N/A	N/A	N/A	N/A

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Architectural Testing Inc. Factory Mutual Research Corp.	ATI-37490.01 3022174	Membrane Brittleness Testing Wind Uplift and Fire Classification	7/7/00 09/25/06
Factory Mutual Research Corp.	3Z9A1.AM	Wind Uplift and Fire Classification	10/15/97
Factory Mutual Research Corp.	1B7A5.AM	Wind Uplift and Fire Classification	02/23/98
Factory Mutual Research Corp.	Approval Guide Excerpt	Wind Uplift and Fire Classifications Listings	5/00
Factory Mutual Research Corp.	3011220	Class 4470	08/16/01
Factory Mutual Research Corp.	3012879	Class 4470	04/04/03
Celotex Corporation Testing Services	520257	Membrane Physical Property Testing	4/19/00
SGS U.S. Testing Company Inc.	131248-R2	Membrane Ozone Resistance Testing	1/6/00



APPROVED ASSEMBLIES

- Membrane Type:** Single Ply, Thermoplastic, TPO, Reinforced and FleeceBacked
- Deck Type 4:** Lightweight Concrete, Non-insulated, over Steel Deck
- Deck Description:** Cellular or Aggregate Lightweight Concrete
- System Type F(1):** Membrane fully adhered to primed lightweight insulating concrete deck.

All General and System Limitations apply.

Vapor Retarder: None

Barrier: None.

Membrane: VersiWeld or VersiWeld EF/ES, 45 or 60 mil membrane or VersiWeld Plus, 72 or 80 membrane fully adhered to the lightweight deck using VersiWeld Bonding Adhesive applied at a rate of 1 gal/60 ft² or Aqua Base 120 Bonding Adhesive applied to the substrate at a rate of 1 gal/60 ft².

Or

VersiWeld VersiFleece 100 or 115 mil membrane fully adhered to the lightweight deck using FAST Adhesive applied at a rate of 1 gal/sq. or Aqua Base 120 Bonding Adhesive applied to the substrate at a rate of 1 gal/120 ft².

Maximum Design
Pressure:

-45 psf. (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBacked
Deck Type 4: Lightweight Concrete, Non-insulated, over Steel Deck
Deck Description: Celcore Cellular Lightweight Concrete over 18-22 ga Steel Deck
System Type F(2): Membrane fully adhered to primed lightweight insulating concrete deck.

All General and System Limitations apply.

Deck: Minimum 22 ga. steel deck secured to supports space at maximum 4 ft o.c. with ITW Buildex Traxx/5 spaced at 6" o.c.

Vapor Retarder: None

Membrane: VersiWeld or VersiWeld EF/ES, 45 or 60 mil membrane or VersiWeld Plus, 72 or 80 membrane fully adhered to the lightweight deck using VersiWeld Bonding Adhesive applied at a rate of 1 gal/60 ft² or Aqua Base 120 Bonding Adhesive applied to the substrate at a rate of 1 gal/60 ft².
Or
VersiWeld VersiFleece 100 or 115 mil membrane fully adhered to the lightweight deck using FAST Adhesive applied at a rate of 1 gal/sq. or Aqua Base 120 Bonding Adhesive applied to the substrate at a rate of 1 gal/120 ft².

Maximum Design Pressure: -90 psf. (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBacked
Deck Type 4: Celcore Lightweight Insulating Concrete, over Structural Concrete Deck
Deck Description: Celcore Lightweight Insulating Concrete
System Type F(3): Membrane fully adhered to primed lightweight insulating concrete deck.

All General and System Limitations apply.

Vapor Retarder: None

Membrane: VersiWeld or VersiWeld EF/ES 45 or 60mil or VersiWeld Plus 72 to 80 mil membrane fully adhered to the lightweight deck using VersiWeld Bonding adhesive or Aqua Base 120 Bonding Adhesive applied to the substrate at a rate of 1gal./60ft².
Or
VersiWeld VersiFleece 100 or 115 mil membrane fully adhered to the lightweight deck using FAST adhesive applied at a rate of 1 gal./sq or Aqua Base 120 Bonding Adhesive applied to the substrate at a rate of 1gal./120ft²
Or
VersiFleece AC TPO 120 mil or VersiFleece AC TPO 135 mil membrane fully adhered to the lightweight deck using CP-5067 applied to the substrate at a rate of 1gal./67ft²

Maximum Design
Pressure:

-205 psf. with VersiWeld VersiFleece & FAST Adhesive
-90 psf using VersiWeld VersiFleece & Aqua Base 120 Bonding Adhesive
-67.5 psf using VersiWeld & Aqua Base 120 Bonding Adhesive
-90 psf using VersiWeld & VersiWeld Bonding Adhesive
-127.5 psf using VersiFleece AC TPO 120 mil or VersiFleece AC TPO 135 mil with CP-5067
(See General Limitation #9 for all options)



Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBacked
Deck Type 4: Elastizell Range II Lightweight Insulating Concrete, over Structural Concrete Deck
Deck Description: Elastizell Range II Lightweight Insulating Concrete
System Type F-4: Membrane fully adhered to primed lightweight insulating concrete deck.

All General and System Limitations apply.

Vapor Retarder: None

Membrane: VersiWeld or VersiWeld EF/ES 45 or 60mil or VersiWeld Plus 72 to 80 mil membrane fully adhered to the lightweight deck using VersiWeld Bonding adhesive or Aqua Base 120 Bonding Adhesive applied to the substrate at a rate of 1gal./60ft².
Or
VersiWeld VersiFleece 100 or 115 mil membrane fully adhered to the lightweight deck using FAST adhesive applied at a rate of 1 gal./sq or Aqua Base 120 Bonding Adhesive applied to the substrate at a rate of 1gal./120ft²

Maximum Design Pressure:

-205 psf. with VersiWeld VersiFleece & FAST Adhesive
-307.5 psf using VersiWeld VersiFleece & Aqua Base 120 Bonding Adhesive
-67.5 psf using VersiWeld & Aqua Base 120 Bonding Adhesive
-495 psf using VersiWeld & VersiWeld Bonding Adhesive
(See General Limitation #9 for all options)



LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 137, calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For Systems where specific lightweight insulating concrete is referenced consult current lightweight insulating concrete NOA for specific deck construction and limitations. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No: 07-0314.08
Expiration Date: 09/04/08
Approval Date: 11/15/07
Page 9 of 9