



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

---

**Gaco Western LLC  
P.O. Box 646  
Waukesha, WI 53187**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: A3100R Acrylic Top Coat**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 07-0403.03  
Expiration Date: 05/31/12  
Approval Date: 05/31/07  
Page 1 of 3**

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Coatings  
**Material:** Acrylic

### SCOPE:

This approves "A3100R Acrylic Top Coat" as a roof maintenance coating manufactured by Gaco Western LLC, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricanes Zone.

### EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies	GW-002-02-201	ASTM D 6083 Fed Spec TT-C-555B	01/09/07
Underwriters Laboratories	File R5663 Project 07NK02171	UL 790	03/13/07

### PHYSICAL PROPERTIES OF COMPONENTS

Trade names: **A3100R Acrylic Top Coat**

Thickness: For application over spray polyurethane foam system apply a base coat at a minimum rate of 1.13 gal/100 ft<sup>2</sup>, an intermediate coat at a minimum rate of 1.13 gal/100 ft<sup>2</sup>, and a top coat at a minimum rate of 1.13 gal/100 ft<sup>2</sup>.  
For application of a recover coating over an existing acrylic roof apply a base coat at a minimum rate of 1 gal/100 ft<sup>2</sup>, and a top coat at a minimum rate of 1 gal/100 ft<sup>2</sup>.

Specifications: ASTM D 6083

Description: An acrylic white elastomeric quick set coating membrane applied to; spray polyurethane foam roof systems and a recover of any existing acrylic roof.

Container Size: 5, 55 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with specific Roof Assembly, Product Control Notice of Acceptance.



NOA No.: 07-0403.03  
Expiration Date: 05/31/12  
Approval Date: 05/31/07  
Page 2 of 3

## **LIMITATIONS:**

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. A3100R Acrylic Top Coat shall not be applied in inclement weather conditions.
3. A3100R Acrylic Top Coat shall not be applied over asphaltic shingles, metal shingles, fiber-cement shingles, quarry slate, cement or clay roofing tile, or wood shingles or shakes.
4. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance. For applications over existing single ply, smooth or granulated BUR systems. Refer applicable building code for requirements
5. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.
6. All approved products listed herein shall be labeled in compliance with TAS 121.
7. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
8. A3100R Acrylic Top Coat shall only be applied by a factory trained and certified applicators.
9. A3100R Acrylic Top Coat shall be applied in accordance with manufacturer's published application instructions.

**END OF THIS ACCEPTANCE**

