MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908
www.miamidade.gov/buildingcode

BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

NOTICE OF ACCEPTANCE (NOA)

Canplas Industries, LTD.
500 Veterans Drive
Barrie, Ontario L4M 4V3 Canada

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Duraflo Vent Plastic "Dow PP C719-35RNHP"

MISSILE IMPACT RATING: None

LIMITATIONS: This is a component approval and does not include evaluation of structural performance of this component. Systems incorporating this component shall be tested as a system for compliance with applicable systems testing to design pressures according to Chapter 16 of the Florida Building Code and Supplements.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page 1 and evidence pages E-1.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**

PRODUCT CONTROL ACCEPTED

Canplas Industries LTD

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

None.

B. TESTS

Test Report CANP-006-02-01, prepared by PRI Construction Materials Technologies, dated 03/20/07, signed and sealed by Duc T. Nguyen, P.E. and Test Report ETC-06-718-18119.0, prepared by ETC Laboratories, dated 09/11/06, signed and sealed by Joseph L. Doldan, P.E:

Test:	Description:	Properties:
ASTM G 155	Accelerated Weathering	4500 hr Xenon-Arc Exposure
ASTM D 638	Tensile Strength Difference	4.6 %< 10%
ASTM D 2843	Smoke Density Rating	16.2%< 75%
ASTM D 1929	Self-Ignition Temperature	750°F>650°F
ASTM D 635	Rate of Burning	1.62in/min<2.25in/min (C-2)

C. CALCULATIONS

None

D. QUALITY ASSURANCE

Miami Dade Building Code Compliance Office (BCCO).

E. MATERIAL CERTIFICATIONS

None.

F. STATEMENTS

None.

Carlos M. Utrera, P.E.
Product Control Examiner
NOA No 07-0425.10
Expiration Date: July 12, 2012
Approval Date: July 12, 2007