MIAMI-DADE

BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

RGM Products, A GAF-Elk Subsidiary
3441 S. Willow Ave.
Fresno, CA 93725

SCOPE:
This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCCO reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: RGM-Elk Modified Bitumen Roof Systems over Wood Decks

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 4.
The submitted documentation was reviewed by Jorge L. Acebo.

PRODUCT CONTROL ACCEPTED

ROOFING ASSEMBLY NOTICE OF ACCEPTANCE

Category:	Roofing
Sub-Category:	Modified Bitumen
Material:	SBS
Deck Type:	Wood
Maximum Design Pressure	**-45 psf**

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

Table 1

Product	Dimensions	Test Specification	Product Description
TG-2 (Plylock Nailable Base)	39.37" x 65.8'	ASTM D4601	A fiberglass reinforced, SBS modified bitumen, nailable base sheet.
RoofGard SA Cap P (FR) (Plylock SA Cap P FR)	39.37" x 34'	ASTM D6164	A polyester/fiberglass reinforced fire resistant cap membrane with a self-adhered bottom surface and a mineral granule top surface.

EVIDENCE SUBMITTED

Test Agency	Test Identifier	Description	Date
Trinity | ERD	R3360.02.07-3	TAS 114-J FM 4470	02/28/2007
Trinity | ERD	R3360.02.07-2	Physical Properties Testing of Elk Base Sheets and Ply Sheets	02/28/2007
Trinity | ERD	R3360.02.07-1	Physical Properties Testing of Elk RoofGard SA Cap P FR	02/28/2007
Trinity | ERD	R3360.05.07	TAS 114-G & I	05/09/2007

APPROVED ASSEMBLIES:

Membrane Type:	Modified Bitumen
Deck Type 1:	Wood, Non-Insulated
Deck Description:	19/32" or greater plywood or wood plank fastened with 8d common nails spaced 24" o.c.
System Type E:	Base sheet mechanically fastened.
Base Sheet:	RGM-Elk TG-2, Plylock Nailable Base or RoofGard Base G
Fastening:	Attached with 12 ga. Annular ring-shank nails with 3/8-in. diameter heads through 1-5/8-in. diameter tin-caps spaced 8-in o.c. in the 3-in. lap and 8-in o.c. in three equally spaced and staggered rows.
Ply Sheet:	ShieldGard MP, Plylock SA Base/Ply G or RoofGard SA Base/Ply G fully adhered to base sheet.
Cap Sheet:	RoofGard SA Cap P FR, Plylock SA Cap P FR, RoofGard SA Cap P or Plylock SA Cap P fully adhered to ply sheet.
Maximum Design Pressure:	-45psf (see general limitation #7.)

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

END OF THIS ACCEPTANCE