



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Johns Manville Corporation
717 17th Street
Denver, CO 80202**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: JM TPO Single Ply Roof Systems over Cementitious Wood Fiber Deck

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 06-0522.05 and consists of pages 1 through 7.
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 07-0517.05
Expiration Date: 07/05/12
Approval Date: 07/12/07
Page 1 of 7**

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Single Ply
Material:	TPO
Deck Type:	Cementitious Wood Fiber
Maximum Design Pressure	-45 psf
Fire Classification:	See General Limitation #1

TABLE 1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product Name</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
JM TPO	48", 75", 96", 120" or 148" wide x 100' long x 45 or 60 mils thick	TAS 131	Polyester reinforced Thermoplastic Olefin single ply membrane.
ENRGY 3	Various	TAS 110	Polyisocyanurate insulation
E'NRG'Y 3 Plus	Various	TAS 110	Isocyanurate insulation with wood fiberboard facer
Invinsa Roof Board	Various	TAS 110	High density polyisocyanurate board

TABLE 2

APPROVED INSULATIONS:

<u>Product</u>	<u>Product Description</u>	<u>Manufacturer</u> (With current NOA)
AC Foam II	Isocyanurate insulation	Atlas Roofing Corp.
AC Foam Composite	Isocyanurate insulation with perlite facer	Atlas roofing Corp.
Multi-Max FA	Isocyanurate insulation	R-Max, Inc.
Thermarroof Composite	Isocyanurate insulation with perlite facer	R-Max, Inc.
High Density Fiberboard	Wood fiberboard insulation	The Celotex Corp.
Dens-Deck	Silicon treated gypsum	G-P Gypsum

TABLE 3

APPROVED FASTENERS:

<u>Product</u>	<u>Product Description</u>	<u>Manufacturer</u> (With current NOA)
1. Construction Fasteners	Insulation and membrane fasteners	Construction Fasteners
2. Buildex Fasteners	Insulation and membrane fasteners	ITW Buildex Corp.
3. Olympic Fasteners	Insulation and membrane fasteners	Olympic Manufacturing
4. Tru-Fast Fasteners	Insulation and membrane fasteners	Tru-Fast Corporation
5. GenFlex Fasteners	Insulation and membrane fasteners	Gen-Flex Corporation



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>	
Factory Mutual Research	3009797	FM 4470	02/04/02	
	3007119	FM 4470	01/02/02	
	3005794	FM 4470	12/13/01	
	3002357	FM 4470	05/16/00	
	3005415	FM 4470	02/08/00	
	3002775	FM 4470	09/16/99	
	3000919	FM 4470	04/07/99	
	3003690	FM 4470	03/29/99	
	3B9A2.AM	FM 4470	01/25/99	
	4B1A9.AM	FM 4470	09/09/98	
	1D9A7.AM	FM 4470	07/31/98	
	1D9A0.AM	FM 4470	07/30/98	
	1D0A3.AM	FM 4470	09/24/97	
	1B0A9.AM	FM 4470	05/09/97	
	3012149	FM 4470	08/28/02	
	3015927	FM 4470	01/26/04	
	3019052	FM 4470	01/28/05	
	3023988	FM 4470	09/29/05	
	3025484	FM 4470	05/31/06	
	3026594	FM 4470	06/01/06	
	3025659	FM 4470	06/02/06	
	Exterior Research & Design, LLC.	8054.02.02-1	Physical Properties TAS 131	02/22/02
		EX30M3B	Physical Properties	06/17/04
	Momentum Technologies, Inc.	01NK14490	Fire Classification	06/01/01
		96NK22037	TAS 114, (UL 790)	03/10/97
		01NK25823	Wind Uplift, TAS 114, (UL 1897)	07/02/01
02NK47751		Fire Classification	10/10/03	
Underwriters Laboratories, Inc.	04NK04226	Fire Classification	11/12/04	



APPROVED ASSEMBLIES:

- Membrane Type:** Single Ply, Thermoplastic, TPO
- Deck Type 5I:** Cementitious wood fiber, Insulated
- Deck Description:** Cementitious wood fiber
- System Type A(1):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered.

All General and System Limitations apply.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Fastener Density/ft²</u>	<u>Fastener Type</u>
ACFoam II, H-Shield, ENRGY 3 Minimum 1.0" thick	N/A	N/A
DensDeck, DensDeck Prime Minimum 0.25" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Fastener Density/ft²</u>	<u>Fastener Type</u>
DensDeck, DensDeck Prime Minimum 0.25" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in full coating of OlyBond Adhesive Fastener at a rate of 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: JM TPO adhered to insulation using JM TPO Membrane Adhesive (Solvent Based) applied at 30 ft²/gal (0.7 m²/L) to both the substrate and the bottom side of the roof cover for a combined rate of 60 ft²/gal (1.5 m²/L)

Maximum Design Pressure: -45.0 psf (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, TPO
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Cementitious Wood Fiber
System Type A(2): One or more layers of insulation adhered with approved adhesive, membrane fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Fastener Density/ft²</u>	<u>Fastener Type</u>
ACFoam II, H-Shield, ENRGY 3, ISO 95+GL Minimum 1.5" thick	N/A	N/A
High Density Wood Fiberboard Minimum 0.5" thick	N/A	N/A
DensDeck, DensDeck Prime Minimum 0.25" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Fastener Density/ft²</u>	<u>Fastener Type</u>
High Density Wood Fiberboard Minimum 1.0" thick	N/A	N/A
DensDeck, DensDeck Prime Minimum 0.25" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in ¾" – 1" wide beads 12" o.c. of OlyBond 500 or Spot Shot Adhesive Fastener or JM Two Part Urethane Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: JM TPO adhered to insulation using JM TPO Membrane Adhesive (Solvent Based) applied to both the substrate and the bottom side of the roof cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design Pressure: -45.0 psf (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 5I: Cementitious Wood fiber, Insulated

Deck Description: Cementitious Wood Fiber

System Type D Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

<u>Insulation Base or Top Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
AC Foam II, ENRGY 3 (flat or tapered) Minimum: 1.3" thick	N/A	N/A
AC Foam Composite, ENRGY 3 Plus (flat or tapered), Multi-Max FA, Thermofoam Composite Minimum: 1.5" thick	N/A	N/A
High Density Fiberboard Minimum: ½" thick	N/A	N/A

Note: All insulation shall have preliminary attachment prior to installation of the roofing membrane at a minimum application of two fasteners per board for insulation boards having no dimension greater than 4ft, and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: JM TPO attached to deck as follows:

Fastening: N.T.B Magnum Fasteners with 2 in (51 mm) head spaced at max 6 in. (152 mm) o.c. within minimum 4.5 in (114 mm) wide laps, which are spaced at max 57 in. (1448 mm) o.c. and sealed with a minimum 1.5 in (38 mm) heat weld. Fasteners shall have minimum 2 in (51 mm) embedment.

Maximum Design Pressure: -45 psf (See General Limitation #7)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

END OF THIS ACCEPTANCE



NOA No.: 07-0517.05
Expiration Date: 07/05/12
Approval Date: 07/12/07
Page 7 of 7