



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

**Custom-Bilt Metals  
13940 Magnolia Avenue  
Chino, CA. 91710**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

**DESCRIPTION: Vail Metal Shingle, Vail Titan Select & Vail Majestic Copper**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This renews NOA #06-0417.13 and consists of pages 1 through 6.  
The submitted documentation was reviewed by Alex Tigera.



**NOA No.: 07-0521.05  
Expiration Date: 05/16/12  
Approval Date: 07/19/07  
Page 1 of 6**

## ROOFING SYSTEM APPROVAL

**Category:** Roofing  
**Sub-Category:** Non-Structural Metal Panel  
**Material:** Copper, Steel  
**Maximum Design Pressure:** -67.5 psf.

## TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT

| <b><u>Product</u></b> | <b><u>Dimensions</u></b>                     | <b><u>Product Description</u></b>  |
|-----------------------|--|--|
| Vail Majestic Copper  | 34" long x 12" wide                          | 16oz. Copper (with or without aged bronze finish) metal shingle.   |
| Vail Titan Select     | 34" long x 12" wide<br>Min. thickness 0.0217 | Kynar 500 coated Galvalume metal shingle available in 25 colors.   |
| Trim Pieces           | Various                                      | End wall, drip edge, valley, sidewall, rake edge, and interlocking hip and ridge trim pieces for use with the Vail Select or Riva Classic metal shingle systems. |

## EVIDENCE SUBMITTED:

| <b><u>Test Agency/Identifier</u></b> | <b><u>Name</u></b> | <b><u>Report</u></b> | <b><u>Date</u></b> |
|--------------------------------------|--------------------|----------------------|--------------------|
| Underwriters Laboratories, Inc.      | TAS 107            |                      |                    |
|                                      | TAS-125            | 05CA17407            | 11/28/05           |
|                                      | TAS-125            | 05CA17407            | 11/29/05           |
| Center for Applied Engineering       | TAS 100            |                      |                    |
| Exterior Research & Design, LLC.     | TAS 102            | #9106.08097-1        | 08/15/97           |



NOA No.: 07-0521.05  
Expiration Date: 05/16/12  
Approval Date: 07/19/07  
Page 2 of 6

**SYSTEM A-1S:** Vail Titan Select Shingle

**Deck Type:** Wood, Non-insulated

**Deck Description:** New Construction or Re-roof  
 $\frac{19}{32}$ " or greater plywood or wood plank.

**Slope Range:** 3":12" or greater

**Maximum Uplift Pressure:** The maximum allowable design pressure for the panel shall be **-58 psf (See System Limitation # 2)**

---

**Deck Attachment:** In accordance with applicable building code, but in no case shall it be less using minimum #8 x 1  $\frac{3}{4}$ " wood screws or annular ring shank nails at a spacing of 6" o.c. at supports. In re-roofing, where the deck is less than  $\frac{19}{32}$ " thick (Minimum  $\frac{15}{32}$ " ) The above attachment method must be in addition to existing attachment.

**Underlayment:** Minimum underlayment shall be an ASTM D 226 Type II installed with a minimum 4" side-lap and 6" end-laps. Underlayment shall be fastened with corrosion resistant tin-caps and 12 gauge 1- $\frac{1}{4}$ " annular ring-shank nails, spaced 6" o.c. at all laps and two staggered rows 12" o.c. in the field of the roll. Or, any approved underlayment having a current NOA.

**Fire Barrier:** Any approved fire barrier having a current NOA. Or for class A or B fire rating, install minimum  $\frac{1}{4}$ " thick Georgia Pacific "Dens Deck" (with current NOA) or minimum 4mm thick of Tritex, RockRoof (with current NOA) or  $\frac{5}{8}$ " water resistant type X gypsum sheathing with treated core and facer.

**Valleys:** Valley construction shall be in compliance with Miami-Dade County Roofing Application Standard RAS 133 and with Vail Metal Systems current published installation instructions.

**Metal Panels and Accessories:** Install Vail Select metal shingles including flashing penetrations, valleys end laps and accessories in compliance with Vail Metal Systems, LLC current, published installation instructions and in compliance with the minimum requirements detailed in Roofing Application Standard RAS 133.

Clips Shall be attached to substrate with one #10 x 1 screw of sufficient length to penetrate through the sheathing a minimum of  $\frac{3}{16}$ ".



**SYSTEM A-1C:** Vail Majestic Copper Shingle

**Deck Type:** Wood, Non-insulated

**Deck Description:** New Construction or Re-roof  
 $\frac{19}{32}$ " or greater plywood or wood plank.

**Maximum Uplift Pressure:** See Fastening Options Below

---

**Deck Attachment:** In accordance with applicable building code, but in no case shall it be less using minimum #8 x 1  $\frac{3}{4}$ " wood screws or annular ring shank nails at a spacing of 6" o.c. at supports. In re-roofing, where the deck is less than  $\frac{19}{32}$ " thick (Minimum  $\frac{15}{32}$ " ) the above attachment method must be in addition to existing attachment.

**Underlayment:** Minimum underlayment shall be an ASTM D 226 Type II installed with a minimum 4" side-lap and 6" end-laps. Underlayment shall be fastened with corrosion resistant tin-caps and 12 gauge 1- $\frac{1}{4}$ " annular ring-shank nails, spaced 6" o.c. at all laps and two staggered rows 12" o.c. in the field of the roll. Or, any approved underlayment having a current NOA.

**Fire Barrier:** Any approved fire barrier having a current NOA. Or for class A or B fire rating, install minimum  $\frac{1}{4}$ " thick Georgia Pacific "Dens Deck" (with current NOA) or minimum 4mm thick of Tritex, RockRoof (with current NOA) or  $\frac{5}{8}$ " water resistant type X gypsum sheathing with treated core and facer.

**Valleys:** Valley construction shall be in compliance with Roofing Application Standard RAS 133 and with current published installation instruction and details in Vail metal shingle systems Limited current published installation instructions.

**Metal Panels and Accessories:** Install Riva Classic copper shingles including flashing, penetrations, valleys, end laps and accessories in compliance with Vail Metal Systems current, published installation instructions and in compliance with the minimum requirements detailed in Roofing Application Standard RAS 133.

**Field Condition Fastening:** Clips shall be attached to substrate with one corrosion resistant #10 x 1 screw of sufficient length to penetrate through the sheathing a minimum of  $\frac{3}{16}$ ".

**Maximum Design Pressure:** -56 psf (See General Limitation #2)

**Perimeter and Corner Condition Fastening:** Clips shall be attached to substrate with one #10 x 1 stainless steel screw of sufficient length to penetrate through the sheathing a minimum of  $\frac{3}{16}$ ".

**Maximum Design Pressure:** -67.5 psf (See General Limitation #2)




## SYSTEM LIMITATIONS


1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. The maximum designed pressure listed herein shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).
3. All panels shall be permanently labeled with the manufacturer's name and/or logo, and the following statement: "Miami-Dade County Product Control Approved.
4. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.



## VAIL TITAN SELECT METAL SHINGLES



## VAIL MAJESTIC COPPER SHINGLES



END OF THIS ACCEPTANCE

