



MIAMI-DADE COUNTY
BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908
www.buildingcodeonline.com

NOTICE OF ACCEPTANCE (NOA)

Golden Pharos USA, Inc.
700 Atlantis Road Bldg.101
Melbourne, FL 32904

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series "F2130" Outswing Raised Wood Panel Door Slab- Component

APPROVAL DOCUMENT: Drawing titled "Project FLBMDA #95-0003" Series F2130 6-Panel Door", sheets A1 through A7 of 7, prepared by the manufacturer, dated 7/14/98 last revised on 08-13-02, bearing the Miami-Dade County Product Control Renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: None

LABELING: Each unit shall bear a permanent label, with the Golden Pharos, Kuala Lumpur, Malaysia and label by the system manufacturer as required in the system NOA and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **renews NOA # 02-0805.08** and, consists of this page 1 and evidence sheet E-1, as well as, approval document mentioned above.

The submitted documentation was reviewed by **Ishaq I. Chanda, P.E.**

10/16/07



NOA No 07-0928.06
Expiration Date: August 19, 2008
Approval Date: November 08, 2007
Page 1


Golden Pharos USA, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

- A. DRAWINGS** (Transferred from file # 02-0805.08)
1. Manufacturer's parts and sections drawings.
 2. Drawing titled "Project FLBMDA #95-0003" Series F2130 6-Panel Door", sheets A1 thru A7 of 7, prepared by the manufacturer, dated 7/14/98 last revised on 08-13-02.
- B. TESTS**
1. This approval is based on Comparative Inspection Report for model 2130, Report No. CTLA-334W, dated September 17, 1998 issued by Certified Testing Laboratories, signed and sealed by Ramesh Patel, P. E.
 2. Test report (see file # 02-0805.08)
- C. CALCULATIONS**
1. None
- D. MATERIAL CERTIFICATIONS**
1. None
- E. STATEMENTS**
1. Statement Letter dated Aug. 24, 2007, issued by Hurricane Engineering & Testing Inc, for up-coming Golden Pharos's scheduled test, signed by Dr. Syed Ali.
 2. Statement that "Product has not changed" issued by Golden Pharos, signed by Michael F. Pomroy.
- F. OTHER**
1. This NOA **renews** NOA **02-0805.08**, expired on 19, 2007.
 2. One year conditional approval subjected to verification test at Hurricane Engineering & Testing Inc.
 3. Distribution agreement between Golden Pharos (USA) and Golden Pharos Doors Sdn. Bhd., Kuala Lumpur, Malaysia.
 4. Test proposal dated 08/06/07 approved by BCCO.

Ishaq I. Chanda

Ishaq I Chanda, P.E.
Product Control Examiner
NOA No 07-0928.06
Expiration Date: August 19, 2008
Approval Date: November 08, 2007




Not to Scale
F-2130
 Six Panel
 36"x96"x1 3/4"

Wood Species

- Vertical Grain Douglas Fir (Pseudotsuga Taxfolia)
- American Red Oak (Quercus Rubis)
- Nyatoh (Sapotaceae)
- Meranti Bakau (Shorea Uliginosa)


REVISION: 3/30/99 ADDED DESIGN PRESSURE;
 REDUCED TO 8-1/2" X 11" FORMAT
 REVISION: 4/15/99 PANEL SIZE CORRECTED TO 3/4"
 REVISION: 8/13/02 ADD NOTES

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No 07-0928-06
 Expiration Date AUGUST 19, 2008
 By Ishag I. Chanda
 Miami Dade Product Control
 Division



PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No 02-0805-08
 Expiration Date AUG 19, 2007
 By Ishag I. Chanda
 Miami Dade Product Control
 Division

Section Drawings
 Not to Scale



7/16" x 2 1/4"
 Position Dowel
 (Typical)
 3/4" Thick Panel
 5/8" x 5"
 Hardwood Dowels
 (Typical)

3/8" From Bottom to Center of Lock Rail

General Notes:

1. This component is approved as equal alternate to the Series 2130 Out-swing Raised Panel Door, per NWWDAI.S. 6-91, to be used, interchangeably only, in out-swing door systems with approvals under the auspices of FLBMDA's (FBMA) system: 95-0003(b).
2. Single door units shall include all components described in the active leaf of system approval.
3. Installation of this product will require HVZ approved hurricane protection system.

Prepared: 14 July 1998

Golden Pharos USA, Inc.

700 Atlantic Road, Unit 101, Bldg. A. • Melbourne, Fla. 32904
Phone (407)676-1615 • Fax (407)676-6551

Design Pressure: +48.3psf-83.4psf

BILL OF MATERIALS

PRODUCT TYPE AND SERIES

Golden Pharos USA, Inc.

F-2130 Six Panel Exterior Door
Vertical Grain Douglas Fir
Veneer Construction

M-2130 Meranti Veneer Construction
N-2130 Nyatoh Veneer Construction
R-2130 Red Oak Veneer Construction

CONFIGURATION:

Single Slab Door

Dimensions: 1 3/4" X 96" X 96"

CORNER CONSTRUCTION:

Top Rail: 1 3/4" X 6 1/2" X 27 5/8"
Two (2) 5/8" X 5" Dowels at each end.
2 7/8" Penetration into the rail.

Cross Rail: 1 3/4" X 4 1/2" X 27 5/8"
Two (2) 5/8" X 5" Dowels at each end.
2 7/8" Penetration into the rail.

Lock Rail: 1 3/4" X 7 1/2" X 27 5/8"
Three (3) 5/8" X 5" Dowels at each end.
2 7/8" Penetration into the rail.

Bottom Rail: 1 3/4" X 9 7/16" X 27 5/8"
Four (4) 5/8" X 5" Dowels at each end.
2 7/8" Penetration into the rail.

Stiles: 1 3/4" X 4 1/2" X 96"

Mullions:
One (1) 1 3/4" X 4 1/2" X 12 3/16"
One (1) 1 3/4" X 4 1/2" X 34 5/8"
One (1) 1 3/4" X 4 1/2" X 23 1/2"

Panel: 96" Door
Two (2) 3/4" X 11 13/16" X 12"
Two (2) 3/4" X 11 13/14" X 34 7/16"
Two (2) 3/4" X 11 13/16" X 23 3/8"

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 07-0928-06
Expiration Date AUG 19, 2008
By Ishag I. Chanda
Miami Dade Product Control
Division

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 02-0805-08
Expiration Date AUG 19, 2007
By Ishag I. Chanda
Miami Dade Product Control
Division

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE September 09, 1999
BY Ishag I. Chanda
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 98-1229-02

Drawings Not to Scale

Revisions: 3/30/99: Added design pressure; Reduced to 8 1/2" x 11" format
Revisions: 4/18/99: Panel size corrected to 3/4"

Prepared: 14 July 1999

Project

FLBMDA #85-0003

F2130 6-Panel Door

(7 Pages: A1-A7)


Page No:
A2

Golden Pharos USA, Inc.
 700 Atlantic Road, Unit 101, Bldg. A • Melbourne, Fla. 32904
 Phone (407)676-1615 • Fax (407)676-8551

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 07-0928-00
 Expiration Date Aug 19, 2008
 By Ishaq I. Chanda
 Miami Dade Product Control
 Division

Design Pressure: +48.3psf-63.4psf


PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 02-0805-08
 Expiration Date Aug 19, 2007
 By Ishaq I. Chanda
 Miami Dade Product Control
 Division



**Dowel Penetration
 (Typical Detail)**

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE September 09, 1997
 BY Ishaq I. Chanda
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 98-1229-03

**Veneer Construction
 (Typical)**



Drawings Not to Scale

Revisions: 2/20/00: Added design pressure; Reduced to 8 1/2" x 11" format

Prepared: 14 July 1998.

Project:

FLBMDA #95-0003

F2130 6-Panel Door

(7 Pages: A1-A7)

Page No:

A3


Golden Pharos USA, Inc.
 700 Atlantis Road, Unit 101, Bldg. A. • Melbourne, Fla. 32904
 Phone (407)676-1815 • Fax (407)676-8551

Design Pressure: +48.3psf-63.4psf


PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 07-0928-06
 Expiration Date Aug 19, 2008
 By Ishaq I. Chanda
 Miami Dade Product Control
 Division

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 02-0805-08
 Expiration Date Aug 19, 2007
 By Ishaq I. Chanda
 Miami Dade Product Control
 Division

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE September 09 1999
 BY Ishaq I. Chanda
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 98-1229-03



Veneer Construction (Typical)



Drawings Not to Scale

Revisions: 3/30/99: Added design pressure; Reduced to 8 1/2"x11" format
 Revisions: 4/15/99: Panel size corrected to 3/4"

Prepared: 14 July 1999

Project:


FLBMDA #95-0003

F2130


6-Panel Door

(7 Pages: A1-A7)


Page No:
A4



Mullion Detail



Position Dowel
(Typical)



Grooved Hardwood Dowel
(Typical)

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 07-0928-06
 Expiration Date Aug 19, 2008
 By Ishag I. Chanda
 Miami Dade Product Control
 Division

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE September 09 1999
 BY Ishag I. Chanda
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 98-1229-03




PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 02-0805-08
 Expiration Date Aug 19, 2007
 By Ishag I. Chanda
 Miami Dade Product Control
 Division

Drawings Not to Scale

Revision: 3/20/99: Added design pressure; Reduced to 8 1/2" x 11" format
 Revision: 4/15/99: Panel size corrected to 3/4"

Prepared: 14 July 1998


Group A: 2130 Family




PRODUCT RENEWED *St. Marks Park*
 as complying with the Florida
 Building Code
 Acceptance No. 07-0928-06
 Expiration Date Aug 19, 2008
 By Ishag I. Chaudh
 Miami Dade Product Control
 Division

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 02-0805-08
 Expiration Date Aug 19, 2007
 By Ishag I. Chaudh
 Miami Dade Product Control
 Division


10 Panel
 APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE September 09 1999
 BY Ishag I. Chaudh
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 98-1229-03




10 Panel



6 Panel



6 Panel Curve Top



15 Panel

Drawings Not to Scale.

Revisions/3/9/98: Added design pressure; Reduced to 8 1/2"x11" format
 Revisions/1/8/98: Doors under 6 panels separated into a separate family

Prepared: 14 July 1998.

Project:

FLBMDA #95-0003

F2130 6-Panel Door

(7 Pages: A1-A7)






Page No:
A6

Group A: 2130 Family

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 07-0928.06
 Expiration Date April 19, 2008
 By Ishaq I. Chanda
 Miami Dade/Product Control
 Division

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 02-0805.08
 Expiration Date April 19, 2007
 By Ishaq I. Chanda
 Miami Dade Product Control
 Division

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE September 09, 1999
 BY Ishaq I. Chanda
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 98-1229.03



Drawings Not to Scale

Revision: 8/21/99: Added design pressure; Reduced to 61/2"x11" format
 Revision: 4/18/96: Doors under 8 panels separated into a separate family

Prepared: 14 July 1999

Project: