MIAMI-DADE

BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

Interwrap, Inc.
32923 Mission Way
Misssion, BC, Canada V2V-6E4

SCOPE:
This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 03-0307.02 and consists of pages 1 through 3.
The submitted documentation was reviewed by Jorge L. Acebo.

MIAMI-DADE COUNTY APPROVED

NOA No.: 07-1003.01
Expiration Date: 08/08/13
Approval Date: 04/24/08

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: Polypropylene

SCOPE:

This acceptance is for **Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment** as manufactured by Interwrap, Inc., as described in this Notice of Acceptance, for use with approved prepared roof assemblies.

PRODUCT DESCRIPTION:

Product	Dimensions	Test Specification	Product Description
Titanium-UDL™ 30	48" x 250' rolls	ASTM D226 Type I & II	Woven synthetic polymer underlayment two sided coated with UV protected and slip resistant polymer stabilized polypropylene on both sides.
Titanium-UDL™ 50	48" x 250' rolls	ASTM D226 Type I & II	Woven synthetic polymer underlayment two sided coated with UV protected and slip resistant polymer stabilized polypropylene on both sides.

EVIDENCE SUBMITTED:

Test Agency	Test Identifier	Test Name/Report	Date
Intertek Testing Services	#3031783	TAS 104	02/19/03
	3119607COQ-003B	ICC-ES AC48	02/20/08
	3124826-01	ASTM E108	02/19/08
	3124826MID-007	ASTM E108	02/25/08
	3118010COQ-003	ASTM D226	02/20/08
	3130639COQ-002A	ASTM D226	02/20/08

INSTALLATION:

1. Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment shall be installed in strict compliance with applicable Building Code.
2. Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment shall be installed with a minimum 4-inch head lap in a single layer fashion.
3. Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment shall be fastened with corrosion resistant tin-caps and 12 gauge 1 ¼" annular ring-shank nails, spaced 6" o.c. at all laps and three staggered rows fastened 12" o.c. in the field of the roll.
4. Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment may be used with Asphaltic shingles, Wood shakes and shingles, Non-structural metal roofing, and quarry slate. Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment shall not be used as roof tile underlayment.
5. For fire classification of specific roof assemblies using Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment refer to a current Approved Roofing Materials Directory for fire ratings of this product.

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.
3. Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment shall be applied to a smooth, clean and dry surface with deck free of irregularities. All nails in the deck shall be carefully checked for protruding heads. Re-fasten any loose decking panels. Sweep the deck thoroughly to remove any dust and debris prior to application.
4. Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment shall not be hot mopped, refer to manufacturer's published literature for product compatibility.
5. Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment shall not be applied over an existing roof membrane as a recover system.
6. Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment shall not be left exposed as a temporary roof for longer than 30 days of application.
7. Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment are components used in roof system assemblies. Roof system assemblies are approved under a specific Notice of Acceptance. Refer to Prepared Roofing system Product Control Notice of Acceptance for listed approval of this product with specific prepared roofing products.
8. Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment may be used with any approved roof covering Notice of Acceptance listing Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment as a component part of an assembly in the Notice of Acceptance. If Titanium-UDL™ 30 & Titanium-UDL™ 50 Synthetic Underlayment is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.

LABELING:

All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.

MIAMI-DADE COUNTY APPROVED

BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

END OF THIS ACCEPTANCE