



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Polyglass USA, Inc.
150 Lyon Drive
Fernley, NV 89408**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Polyglass Modified Bitumen Roof System Over Lightweight Concrete Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 07-0418.07 and consists of pages 1 through 14.
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 07-1030.04
Expiration Date: 07/13/13
Approval Date: 04/10/08**

ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub-Category: Modified Bitumen
Materials: SBS/APP
Deck Type: Lightweight Insulating Concrete
Maximum Design Pressure: -225 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Polyflex	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a smooth or sanded top surface.
Polyflex G	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a granule top surface.
Polyflex G FR	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a granule top surface and fire retardant chemistry.
Polybond	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a smooth or sanded top surface.
Polybond G	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a granule top surface.
Elastoflex S6	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a polyethylene or sanded top surface.
Elastoflex S6 G	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface.
Elastoflex S6 G FR	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface and fire retardant chemistry.



NOA No.: 07-1030.04
 Expiration Date: 07/13/13
 Approval Date: 04/10/08
 Page 2 of 14

Elastoshield TS4	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface.
Elastoshield TS4 FR	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface and fire retardant chemistry.
Elastoflex V	32' 10" x 3' 3-3/8"	ASTM D 6163	Torch, hot asphalt or cold adhesive applied, fiberglass reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a sanded top surface.
Elastoflex VG	32' 10" x 3' 3-3/8"	ASTM D 6163	Torch, hot asphalt or cold adhesive applied, fiberglass reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface.
Elastoflex VG FR	32' 10" x 3' 3-3/8"	ASTM D 6163	Torch, hot asphalt or cold adhesive applied, fiberglass reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface and fire retardant chemistry.
Xtraflex	32' 10" x 3' 6"	ASTM D 5147	Torch applied, polyester reinforced, TPO modified bitumen membrane with a burn off polyethylene back face and a smooth top surface.
Xtraflex G	32' 10" x 3' 6"	ASTM D 5147	Torch applied, polyester reinforced, TPO modified bitumen membrane with a burn off polyethylene back face and a granule top surface.
Xtraflex G FR	32' 10" x 3' 6"	ASTM D 5147	Torch applied, polyester reinforced, TPO modified bitumen membrane with a burn off polyethylene back face and a granule top surface and fire retardant chemistry.
Elastobase V	65' 2" x 3' 3-3/8"	ASTM D 4601	SBS modified asphalt coated fiberglass reinforced base sheet.
Elastobase P	65' 2" x 3' 3-3/8"	ASTM D 6164	SBS modified asphalt coated polyester reinforced base sheet.
Cold Process Adhesive	1, 5 or 55 gal.	ASTM D3019 Type III	A fibered cold process adhesive for use with roll or BUR roofing.
PG100 Asphalt Primer	1, 5, 55 gal. or 17 oz. spray can	ASTM D41	A penetrating solution of solvent and a blend of selected asphalts used to promote adhesion.
PG350 Mod Bit Adhesive	1, 5 or 55 gal.	ASTM D3019 Type III	A fibered rubberized adhesive designed for use with modified bitumen membranes.
PG400 Plastic Roof Cement	1, 5 gal. or tube	ASTM D4586 ASTM D3409	A thick, fibered, rubberized flashing cement for use in dry or damp conditions.
PG425 Wet/Dry Roof Cement	1, 5 gal. or tube	ASTM D4586 ASTM D3409	A thick, fibered, rubberized flashing cement for use in dry or damp conditions.
PG450 Flashing Cement	1, 5 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement.



PG500 MB Flashing Cement	1, 5 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement for use with modified bitumen membranes.
Polyplus 35 Premium Mod Bit Adhesive	1, 5 or 55 gal.	ASTM D3019 Type III	A fibered rubberized adhesive designed for use with modified bitumen membranes.
Polyplus 45 Premium Flashing Cement	1, 5 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement.
Polyplus 50 Premium MB Flashing Cement	1, 5 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement for use with modified bitumen membranes.

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
Polytherm, POLYTHERM A1	Polyisocyanurate foam insulation	Polyglass USA, Inc.
Polytherm Composite	Polyisocyanurate/perlite composite insulation.	Polyglass USA, Inc.
ACFoam II	Polyisocyanurate foam insulation	Atlas Energy Products
ACFoam III	Polyisocyanurate foam insulation	Atlas Energy Products
GAF High Density Wood Fiberboard	High Density Wood Fiberboard	GAF Materials. Corp.
High Density Wood Fiberboard	Wood fiber insulation board	Generic
Perlite Insulation	Perlite insulation board	Generic
Dens-Deck	Gypsum insulation board	Georgia-Pacific
Armor Board High Density Wood Fiberboard	Wood fiber insulation board	Honeywell Int'l. Inc.
H-Shield	Polyisocyanurate foam insulation	Hunter Panels, LLC
H-Shield CG	Polyisocyanurate/perlite composite insulation	Hunter Panels, LLC
Fesco Board	Expanded mineral fiber	Johns Manville Corp.
Structodek, Structodek FS	Wood fiber board	Masonitec
Multi-Max FA	Polyisocyanurate foam insulation	RMax, Inc.
Fiberbond	Type-x Gypsum	United States Gypsum Co.
Securock	Fiber reinforced coverboard	USG



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Dekfast Fasteners #15	Insulation fastener for wood, steel and concrete decks		SFS Intec
2.	Dekfast 2 ½" HS membrane Plate	Galvalume stress plate.	2.5" round	SFS Intec
3.	Lite Weight Concrete Fasteners	Insulation fastener for wood, steel and concrete decks.		OMG.
4.	Lite Weight Concrete Plate	Galvalume stress plate.	2.7" round	OMG.
5.	Twin Loc-Nails	Pre-assembled Galvalume Base Sheet Fastener and stress plate.	Various	ES Products, Inc.
6.	FM-260 Base Ply Fastener	Pre-assembled Galvalume Base Sheet Fastener and stress plate.	Various	ES Products, Inc.
7.	FM-245 Base Ply Fastener	Pre-assembled Galvalume Base Sheet Fastener and stress plate.	Various	ES Products, Inc.
8.	FM-90 Base Ply Fastener	Pre-assembled Galvalume Base Sheet Fastener and stress plate	Various	ES Products, Inc.
9.	Roofgrip	Insulation fastener for wood, steel, and concrete decks.	Various	OMG

APPROVED SURFACING:

TABLE 4

Number	Product Name	Product Description	Application Rate	Specification	Manufacturer
1.	PG200 Non-Fibered Roof Coating	A non fibered asphaltic coating used to add life and rejuvenate existing BUR roofing substrates.	1½-2 gal/sq	TAS 140	Polyglass USA, Inc.
2.	PG300 Fibered Roof Coating	An asphalt cutback fibered roof coating. May be applied by brush or spray equipment to rejuvenate aged BUR	1½-2 gal/sq	ASTM D4479	Polyglass USA, Inc.
3.	PG600 Non-Fibered Aluminum Roof Coating	Non-fibered aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Polyglass USA, Inc.



APPROVED SURFACING:

TABLE 4

Number	Product Name	Product Description	Application Rate	Specification	Manufacturer
4.	PG650 Fibered Aluminum Roof Coating	Fibered aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Polyglass USA, Inc.
5.	PG700 White Reflective Roof Coating	A premium white elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
6.	PG800 Non-Fibered Asphalt Emulsion Roof Coating	An asphalt base, unfibered clay emulsion	3 gal/sq in two coats	ASTM D1227	Polyglass USA, Inc.
7.	PG850 Fibered Asphalt Emulsion Roof Coating	An asphalt base, fibered clay emulsion	3 gal/sq in two coats	ASTM D1227	Polyglass USA, Inc.
8.	Polyplus 65 Premium Fibered Aluminum Roof Coating	Fibered aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Polyglass USA, Inc.
9.	Polyplus 60 Premium Non-Fibered Aluminum Roof Coating	Non-fibered aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Polyglass USA, Inc.
10.	Polybrite 70 White Elastomeric Roof Coating	A premium white elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
11.	Mule-Hide 111 Non-Fibrated Roof Coating	A non-fibrated asphaltic coating used to add life and rejuvenate existing BUR roofing substrates.	1½-2 gal/sq	TAS 140	Mule-Hide Products Co., Inc.
12.	Mule-Hide 102 Fibrated Roof Coating	An asphalt cutback fibered roof coating. May be applied by brush or spray equipment to rejuvenate aged BUR	1½-2 gal/sq	ASTM D4479	Mule-Hide Products Co., Inc.
13.	Mule-Hide 416 Standard Non-Fibrated Aluminum Roof Coating	Non-fibrated aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Mule-Hide Products Co., Inc.



APPROVED SURFACING:

TABLE 4

Number	Product Name	Product Description	Application Rate	Specification	Manufacturer
14.	Mule-Hide 406 Standard Fibrated Aluminum Roof Coating	Fibrated aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Mule-Hide Products Co., Inc.
15.	Mule-Hide 401 Premium Fibrated Aluminum Roof Coating	Fibrated aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Mule-Hide Products Co., Inc.
16.	Mule-Hide 410 Premium Non-Fibrated Aluminum Roof Coating	Non-fibrated aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Mule-Hide Products Co., Inc.
17.	Mule-Hide 311 Emulsion Non-Fibrated	An asphalt base, unfibred clay emulsion	3 gal/sq in two coats	ASTM D1227	Mule-Hide Products Co., Inc.
18.	Mule-Hide 301 Emulsion Fibrated	An asphalt base, fibred clay emulsion	3 gal/sq in two coats	ASTM D1227	Mule-Hide Products Co., Inc.
19.	Gravel	To be installed in a flood coat of approved asphalt at 60 lbs/sq	400 lbs/sq	N/A	Generic
20.	Slag	To be installed in a flood coat of approved asphalt at 60 lbs/sq	300 lbs/sq	N/A	Generic

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Name/Report</u>	<u>Report No.</u>	<u>Date</u>
Factory Mutual Research Corporation	4470	J.I. 2W7A7.AM	08.04.94
	4470	J.I. 3001334	02.15.00
	4470	J.I. 3000857	01.12.00
	4470	J.I. 3004091	01.12.00
	4470	3014692	08.05.03
	4470	3023458	07.18.06
Underwriters Laboratory	TAS 114	00NK20869	06.08.00
Trintiy ERD	TAS 114	11752.09.99-1	02.08.00
	TAS 114	11776.06.02	06.13.02
	TAS 114	11758.08.03	08.11.03
	TAS 114	020843.02.05-1	02.10.05
	TAS 114	P1739.01.07	01.23.07
	TAS 117(B)-ASTM D6862	C8500SC.11.07	11.30.07



APPROVED ASSEMBLIES:

- Deck Type 4I:** Lightweight Concrete, Insulated
- Deck Description:** Approved Cellular Lightweight Concrete
- System Type A(1):** Anchor sheet mechanically fastened; one or more layers of insulation fully adhered with approved asphalt.

All General and System limitations apply.

Anchor Sheet: One ply of GAFGLAS #75 fastened to the deck as described below:

Fastening: Attach anchor sheet using ITW Buildex Lite Weight Concrete Fasteners spaced 7" o.c. in a 4" lap and 7" o.c. in two equally spaced staggered rows in the center of the sheet.

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam II, Multi-Max FA, Polytherm A1, H-Shield, Tapered H-Shield Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Thermarook Composite, Polytherm Composite Minimum 1.5" thick	N/A	N/A
Fiberbond Minimum 5/8" thick	N/A	N/A
High Density Wood Fiberboard Minimum 1/2" thick	N/A	N/A
Fesco Board Minimum 3/4" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full moppings of approved hot asphalt within the EVT range and at a rate of 20-40 lbs. Please refer to RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate face down.

- Base Sheet:** (Optional if using 1 to 3 plies of ply sheet noted below) One ply of Elastobase, Modibase, Perma Ply No. 28 or GAFGLAS #75 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Ply Sheet:** (Optional) One ply of Elastobase, Modibase or Perma Ply 28 or one or more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** One ply of Polyflex, Polyflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.
- Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
- Maximum Design Pressure:** -45 psf; (See general limitation #7.)



Deck Type 4I: Lightweight Concrete, Insulated

Deck Description: Elastizell LWIC over structural concrete; minimum 200psi

System Type A(2): All layers of insulation adhered to LWIC. Membrane is subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
AC Foam II, H-Shield Minimum 2" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Securock Minimum 1/4" thick	N/A	N/A

Note: Apply insulation in Olybond 500 or SpotShot Adhesive in continuous 3/4" to 1" beads/ribbons spaced 12" o.c. Additional layers of insulation to be adhered with Olybond 500 or SpotShot Adhesive in continuous 3/4" to 1" beads/ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional if using ply sheet in hot asphalt) One or more plies of Elastoflex S6 or Elastoflex V adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional if using base sheet in hot asphalt) One or more plies of Elastoflex S6, Elastoflex V adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4, Elastoshield TS4 FR, Elastoflex VG or Elastoflex VG FR hot asphalt applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -225.0 psf (See General Limitation #9)



Deck Type 4I: Lightweight Concrete, Insulated
Deck Description: Elastizell LWIC over structural concrete; minimum 200psi
System Type A(3): All layers of insulation adhered to LWIC. Membrane is subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
AC Foam II, H-Shield Minimum 2" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Securock Minimum ¼" thick	N/A	N/A

Note: Apply insulation in Olybond 500 or SpotShot Adhesive in continuous ¾" to 1" beads/ribbons spaced 12" o.c. Additional layers of insulation to be adhered with Olybond 500 or SpotShot Adhesive in continuous ¾" to 1" beads/ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One or more plies of Polyflex, Polybond torch applied.
Membrane: One ply of Polyflex G, Polyflex G FR, Polybond G torch applied.
Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
Maximum Design Pressure: -225.0 psf (See General Limitation #9)



Deck Type 4: Lightweight Concrete, Non-insulated
Deck Description: Approved Cellular Lightweight Concrete
System Type E(1): Base sheet mechanically fastened.

All General and System limitations apply.

Base Sheet: One ply of GAFGLAS #75 fastened to the deck as described below:
Fastening: Attach base sheet using OMG Lite Weight Concrete Fasteners spaced 7" o.c. in a 4" lap and 7" o.c. in two equally spaced staggered rows in the center of the sheet.
Ply Sheet: (Optional) One ply of Elastobase, Modibase or Perma Ply 28 or one to more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs.
Membrane: One ply of Polyflex, Polyflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt.
Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
Maximum Design Pressure: -45 psf; (See general limitation #7.)

Deck Type 4: Lightweight Concrete, Non-insulated
Deck Description: Celcore MF Lightweight Concrete; 300psi compressive strength.
System Type E(2): Base sheet mechanically fastened.

All General and System limitations apply.

Base Sheet: Elastobase P fastened as outlined below:
Fastening: FM-260 fasteners at 10" o.c. in 4" lap and 10" o.c. in three equally spaced center rows.
Ply Sheet: (Optional) One ply of Elastobase, Modibase or Perma Ply 28 or one to more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs.
Membrane: One ply of Polyflex, Polyflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.
Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
Maximum Design Pressure: -90 psf; (See general limitation #7.)



Deck Type 4: Lightweight Concrete, Non-insulated
Deck Description: Celcore MF Lightweight Concrete; 300psi compressive strength.
System Type E(3): Base sheet mechanically fastened.

All General and System limitations apply.

Base Sheet: Elastobase V or Elastobase P fastened as outlined below:
Fastening: FM-90 fasteners at 8" o.c. in 4" lap and 8" o.c. in three equally spaced center rows.
Ply Sheet: One ply of Elastobase, Modibase or Perma Ply 28 or one to more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs.
Membrane: One ply of Polyflex, Polyflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.
Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
Maximum Design Pressure: -60 psf; (See general limitation #7.)

Deck Type 4: Lightweight Concrete, Non-insulated
Deck Description: Approved Cellular or Aggregate Lightweight Concrete
System Type E(4): Membrane mechanically fastened.

All General and System limitations apply.

Base Sheet: none.
Ply Sheet: none.
Membrane: One ply of Xtraflex G or Xtraflex G FR mechanically fastened with Dekfast #15 Heavy Fasteners and Dekfast 2.5 in. Seam Plates installed through the lightweight concrete to the underlying steel or structural concrete deck spaced 12" o.c. in the 6 inch wide heat welded side lap.
Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
Maximum Design Pressure: -60 psf; (See General Limitation #7.)



Deck Type 4: Lightweight Concrete, Non-insulated

Deck Description: Elastizell with Zell-Crete fibers; 350-400 psi Compressive strength. Supplemental attachment with Roofgrip #21 screws and 3" Flat Bottom Plates at 1 per 8ft².

System Type E(5): Base sheet mechanically fastened.

All General and System limitations apply.

Base Sheet: Elastobase V or Elastobase P fastened as outlined below:

Fastening: Twin-Loc nails at 6" o.c. in 4" lap and 6" o.c. in three equally spaced center rows.

Ply Sheet: One ply of Elastobase, Modibase or Perma Ply 28 or one to more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs.

Membrane: One ply of Polyflex, Polyflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -60 psf; (See general limitation #7.)



LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.
Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

END OF THIS ACCEPTANCE



NOA No.: 07-1030.04
Expiration Date: 07/13/13
Approval Date: 04/10/08
Page 14 of 14