



BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908

**NOTICE OF ACCEPTANCE (NOA)**

**Polyglass USA, Inc.**  
150 Lyon Drive  
Fernley, NV 89408

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Polyglass Modified Bitumen Roof System Over Wood Decks**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 06-0410.06 and consists of pages 1 through 25.  
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 07-1030.05  
Expiration Date: 09/13/11  
Approval Date: 04/10/08  
Page 1 of 25

## ROOFING ASSEMBLY APPROVAL

Category: Roofing  
Sub-Category: Modified Bitumen  
Materials: SBS/APP  
Deck Type: Wood  
Maximum Design Pressure: -112.5 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Polyflex	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a smooth or sanded top surface.
Polyflex G	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a granule top surface.
Polyflex G FR	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a granule top surface and fire retardant chemistry.
Polybond	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a smooth or sanded top surface.
Polybond G	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a granule top surface.
Elastoflex S6	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a polyethylene or sanded top surface.
Elastoflex S6 G	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface.
Elastoflex S6 G FR	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface and fire retardant chemistry.



NOA No.: 07-1030.05  
 Expiration Date: 09/13/11  
 Approval Date: 04/10/08  
 Page 2 of 25

Elastoshield TS4	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface.
Elastoshield TS4 FR	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface and fire retardant chemistry.
Elastoflex V	32' 10" x 3' 3-3/8"	ASTM D 6163	Torch, hot asphalt or cold adhesive applied, fiberglass reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a sanded top surface.
Elastoflex VG	32' 10" x 3' 3-3/8"	ASTM D 6163	Torch, hot asphalt or cold adhesive applied, fiberglass reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface.
Elastoflex VG FR	32' 10" x 3' 3-3/8"	ASTM D 6163	Torch, hot asphalt or cold adhesive applied, fiberglass reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface and fire retardant chemistry.
Xtraflex	32' 10" x 3' 6"	ASTM D 5147	Torch applied, polyester reinforced, TPO modified bitumen membrane with a burn off polyethylene back face and a smooth top surface.
Xtraflex G	32' 10" x 3' 6"	ASTM D 5147	Torch applied, polyester reinforced, TPO modified bitumen membrane with a burn off polyethylene back face and a granule top surface.
Xtraflex G FR	32' 10" x 3' 6"	ASTM D 5147	Torch applied, polyester reinforced, TPO modified bitumen membrane with a burn off polyethylene back face and a granule top surface and fire retardant chemistry.
Elastobase V	65' 2" x 3' 3-3/8"	ASTM D 4601	SBS modified asphalt coated fiberglass reinforced base sheet.
Elastobase P	65' 2" x 3' 3-3/8"	ASTM D 6164	SBS modified asphalt coated polyester reinforced base sheet.
Cold Process Adhesive	1, 5 or 55 gal.	ASTM D3019 Type III	A fibered cold process adhesive for use with roll or BUR roofing.
PG100 Asphalt Primer	1, 5, 55 gal. or 17 oz. spray can	ASTM D41	A penetrating solution of solvent and a blend of selected asphalts used to promote adhesion.
PG350 Mod Bit Adhesive	1, 5 or 55 gal.	ASTM D3019 Type III	A fibered rubberized adhesive designed for use with modified bitumen membranes.
PG400 Plastic Roof Cement	1, 5 gal. or tube	ASTM D4586 ASTM D3409	A thick, fibered, rubberized flashing cement for use in dry or damp conditions.
PG425 Wet/Dry Roof Cement	1, 5 gal. or tube	ASTM D4586 ASTM D3409	A thick, fibered, rubberized flashing cement for use in dry or damp conditions.
PG450 Flashing Cement	1, 5 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement.



PG500 MB Flashing Cement	1, 5 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement for use with modified bitumen membranes.
Polyplus 35 Premium Mod Bit Adhesive	1, 5 or 55 gal.	ASTM D3019 Type III	A fibered rubberized adhesive designed for use with modified bitumen membranes.
Polyplus 45 Premium Flashing Cement	1, 5 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement.
Polyplus 50 Premium MB Flashing Cement	1, 5 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement for use with modified bitumen membranes.

**APPROVED INSULATIONS:**

**TABLE 2**

<b>Product Name</b>	<b>Product Description</b>	<b>Manufacturer (With Current NOA)</b>
Polytherm A1	Polyisocyanurate foam insulation	Polyglass USA, Inc.
Polytherm Composite	Polyisocyanurate/perlite composite insulation.	Polyglass USA, Inc.
ACFoam II	Polyisocyanurate foam Insulation	Atlas Energy Products
ACFoam III	Polyisocyanurate foam Insulation	Atlas Energy Products
High Density Wood Fiberboard	Wood fiber insulation board	Generic
Perlite Insulation	Perlite insulation board	Generic
Type X Gypsum	Fire resistant rated gypsum.	Generic
Dens Deck or Dens Deck Prime	Water resistant gypsum board	G-P Gypsum Corp.
ENRGY-3	Polyisocyanurate foam insulation	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
Multi-Max	Polyisocyanurate roof insulation	RMax, Inc.
Multi-Max FA	Polyisocyanurate roof insulation	RMax, Inc.
Hunter H-Shield	Polyisocyanurate foam Insulation	Hunter
Securock	Fiber reinforced Coverboard	USG Corp.



**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	Dekfast Fasteners #12, #14 & #15	Insulation fastener for wood, steel and concrete decks		SFS Intec
2.	Dekfast Hex Plate	Galvalume hex stress plate.	2 7/8" x 3 1/4"	SFS Intec
3.	Dekfast Lock Plate #12 & #14	Polypropylene locking plate.	3" x 3 1/4"	SFS Intec
4.	Roofgrip	Insulation and membrane fastener	Various	OMG
5.	Metal Plate	Galvalume AZ50 stress plate	3" square	OMG
6.	Plastic Plate	Polyethylene stress plate	3.2" round	OMG
7.	Insul-Fixx HD Fastener	Insulation fastener for steel and wood decks	Various	SFS Intec
8.	Insul-Fixx S	Galvalume AZ55 stress plate	3" round	SFS Intec
9.	Insul-Fixx P	Polyethylene stress plate	3" round	SFS Intec
10.	Tru-Fast HD	Insulation fastener for steel and wood decks		The Tru-Fast Corp.
11.	Tru-Fast Plates	Galvalume AZ55 steel plate	3" round	The Tru-Fast Corp.
12.	Tru-Fast Plates	Polyethylene plastic plate	3" round	The Tru-Fast Corp.

**APPROVED SURFACING:**

**TABLE 4**

<b>Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Application Rate</b>	<b>Specification</b>	<b>Manufacturer</b>
1.	PG200 Non-Fibered Roof Coating	A non fibered asphaltic coating used to add life and rejuvenate existing BUR roofing substrates.	1½-2 gal/sq	TAS 140	Polyglass USA, Inc.
2.	PG300 Fibered Roof Coating	An asphalt cutback fibered roof coating. May be applied by brush or spray equipment to rejuvenate aged BUR	1½-2 gal/sq	ASTM D4479	Polyglass USA, Inc.
3.	PG600 Non-Fibered Aluminum Roof Coating	Non-fibered aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Polyglass USA, Inc.
4.	PG650 Fibered Aluminum Roof Coating	Fibered aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Polyglass USA, Inc.



**APPROVED SURFACING:**

**TABLE 4**

<b>Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Application Rate</b>	<b>Specification</b>	<b>Manufacturer</b>
5.	PG700 White Reflective Roof Coating	A premium white elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
6.	PG800 Non-Fibered Asphalt Emulsion Roof Coating	An asphalt base, unfibered clay emulsion	3 gal/sq in two coats	ASTM D1227	Polyglass USA, Inc.
7.	PG850 Fibered Asphalt Emulsion Roof Coating	An asphalt base, fibered clay emulsion	3 gal/sq in two coats	ASTM D1227	Polyglass USA, Inc.
8.	Polyplus 65 Premium Fibered Aluminum Roof Coating	Fibered aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Polyglass USA, Inc.
9.	Polyplus 60 Premium Non-Fibered Aluminum Roof Coating	Non-fibered aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Polyglass USA, Inc.
10.	Polybrite 70 White Elastomeric Roof Coating	A premium white elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
11.	Mule-Hide 111 Non-Fibrated Roof Coating	A non-fibrated asphaltic coating used to add life and rejuvenate existing BUR roofing substrates.	1½-2 gal/sq	TAS 140	Mule-Hide Products Co., Inc.
12.	Mule-Hide 102 Fibrated Roof Coating	An asphalt cutback fibered roof coating. May be applied by brush or spray equipment to rejuvenate aged BUR	1½-2 gal/sq	ASTM D4479	Mule-Hide Products Co., Inc.
13.	Mule-Hide 416 Standard Non-Fibrated Aluminum Roof Coating	Non-fibrated aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Mule-Hide Products Co., Inc.
14.	Mule-Hide 406 Standard Fibrated Aluminum Roof Coating	Fibrated aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Mule-Hide Products Co., Inc.



**APPROVED SURFACING:**

**TABLE 4**

<b>Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Application Rate</b>	<b>Specification</b>	<b>Manufacturer</b>
15.	Mule-Hide 401 Premium Fibrated Aluminum Roof Coating	Fibrated aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Mule-Hide Products Co., Inc.
16.	Mule-Hide 410 Premium Non-Fibrated Aluminum Roof Coating	Non-fibrated aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Mule-Hide Products Co., Inc.
17.	Mule-Hide 311 Emulsion Non-Fibrated	An asphalt base, unfibred clay emulsion	3 gal/sq in two coats	ASTM D1227	Mule-Hide Products Co., Inc.
18.	Mule-Hide 301 Emulsion Fibrated	An asphalt base, fibred clay emulsion	3 gal/sq in two coats	ASTM D1227	Mule-Hide Products Co., Inc.
19.	Gravel	To be installed in a flood coat of approved asphalt at 60 lbs/sq	400 lbs/sq	N/A	Generic
20.	Slag	To be installed in a flood coat of approved asphalt at 60 lbs/sq	300 lbs/sq	N/A	Generic

**EVIDENCE SUBMITTED:**

<b><u>Test Agency/Identifier</u></b>	<b><u>Name</u></b>	<b><u>Report</u></b>	<b><u>Date</u></b>
Factory Mutual Research Corp.	J.I. 3001334	FMRC 4470	02.15.00
	J.I. 3000857		01.12.00
	J.I. 3004091		01.12.00
Exterior Research & Design, LLC	#11757.12.00-1		12.07.00
	#11757.04.01-1		04.25.01
	#11751.05.03		05.30.03
	#11758.08.03		08.11.03
Underwriters Laboratories, Inc. Trinity   ERD	00NK20869	UL 790	06.08.00
	#P1738.02.07	TAS 114	02.05.07
	C8500SC.11.07	TAS 117(B)	11.30.07



**APPROVED ASSEMBLIES**

**Deck Type 1I:** Wood, Insulated

**Deck Description:** 1 9/32" or greater plywood or wood plank, fastened with 8d common nails at 4" o.c. or #8 screws at 6" o.c.

**System Type A(1):** All insulation layers are adhered to a mechanically attached anchor sheet. Membrane is subsequently adhered to insulation.

**All General and System limitations apply.**

One or more layers of the following:

**Anchor Sheet:** One ply of Elastobase Poly/Sand, Sand/Sand fastened to the deck as described below:

**Fastening:** Attach base sheet using Buildex Roofgrip Fasteners and Flat Bottom Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved Polyisocyanurate Minimum 1" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Dens Deck, Dens Deck Prime, Securock Minimum 1/4" thick</b>	N/A	N/A
<b>Fesco Board Minimum 3/4" thick</b>	N/A	N/A
<b>High Density Wood Fiber Minimum 1/2" thick</b>	N/A	N/A

**Note:** All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

**Ply Sheet:** (Optional) One ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V, Elastoflex V 2.5, Polybond or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

**Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -60 psf; (See general limitation #7.)



**Deck Type 1I:** Wood, Insulated

**Deck Description:** <sup>19</sup>/<sub>32</sub>" or greater plywood or wood plank, fastened with 8d common nails at 4" o.c. or #8 screws at 6" o.c.

**System Type A(2):** All insulation layers are adhered to a mechanically attached anchor sheet. Membrane is subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of the following:

**Anchor Sheet:** One ply of CertainTeed Glasbase, Polyglass Base, Firestone MB Base, JM Perma-Ply #28, Tamko Glass Base or GAFGLAS #75 fastened to the deck as described below:

**Fastening:** Attach base sheet using 11 ga. annular ring shank and 1-5/8" diameter tin caps spaced 8" o.c. in a 4" lap and 8" o.c. in three equally spaced staggered rows in the center of the sheet.

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved Polyisocyanurate Minimum 1" thick</b>	N/A	N/A

**Note:** All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Fesco Board Minimum 3/4" thick</b>	N/A	N/A
<b>High Density Wood Fiber Minimum 1/2" thick</b>	N/A	N/A
<b>Dens Deck, Dens Deck Prime, Securock Minimum 1/4" thick</b>	N/A	N/A

**Note:** Apply top layer of insulation in a full mopping of any approved mopping asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.



Ply Sheet: (Optional) One ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V, Elastoflex V 2.5 or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -60 psf; (See general limitation #7.)



- Deck Type 1I:** Wood, Insulated
- Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank.
- System Type A(3):** All insulation layers are adhered to a mechanically attached anchor sheet. Membrane is subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of the following:

**Anchor Sheet:** One ply of CertainTeed Glasbase, Polyglass Base, Elastobase, Firestone MB Base, JM Perma-Ply #28, Tamko Glass Base or GAFGLAS #75 fastened to the deck as described below:

**Fastening #1:** Attach base sheet using 11 ga. annular ring shank and 1-5/8" diameter tin caps spaced 8" o.c. in a 4" lap and 8" o.c. in three equally spaced staggered rows in the center of the sheet.

**Fastening #2:** Attach base sheet using Buildex Roofgrip Fasteners and Flat Bottom Plates, Dekfast #14 with Hex Plates or Tru-Fast HD with MP-3 Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved Polyisocyanurate Minimum 1" thick</b>	N/A	N/A

**Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Fesco Board Minimum 3/4" thick</b>	N/A	N/A
<b>High Density Wood Fiber Minimum 1/2" thick</b>	N/A	N/A
<b>Dens Deck, Dens Deck Prime, Securock Minimum 1/4" thick</b>	N/A	N/A

**Note: Apply top layer of insulation in a full mopping of any approved mopping asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.**



Ply Sheet: (Optional) One ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V, Elastoflex V 2.5 or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -52.5 psf; (See general limitation #7.)



**Deck Type 1I:** Wood, Insulated

**Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank.

**System Type A(4):** All insulation layers are adhered to a mechanically attached anchor sheet. Membrane is subsequently adhered to insulation.

**All General and System Limitations apply.**

**Anchor Sheet:** One ply of Elastobase V or Elastobase P fastened as below:

**Fastening:** 12 ga. annular ring shank nails and 1-5/8" tin-caps attached 6" o.c. in 4" lap and 6" o.c. in four equally spaced staggered center rows.

One or more layers of the following:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam II, ACFoam III, H-Shield, H-Shield CG, Multi-Max FA3, or ENRGY-3 Minimum 1" thick</b>	N/A	N/A

**Insulation:** Adhered with WeatherTite One-Step Foamable Adhesive, Olybond 500, Insta-Stick or TITASET applied in continuous rows 12" o.c.

**Ply Sheet:** (Optional) One ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V, Elastoflex V 2.5 or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

**Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -60 psf; (See general limitation #7.)



- Deck Type II:** Wood, Insulated
- Deck Description:** <sup>19</sup>/<sub>32</sub>" or greater plywood or wood plank, fastened with 8d common nails at 4" o.c. or #8 screws at 6" o.c.
- System Type B(1):** Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

**All General and System Limitations apply.**

One or more layers of the following:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ENRGY-3, H-Shield or Polytherm Minimum 1.5" thick</b>	<b>1 or 10</b>	<b>1:1.33 ft<sup>2</sup></b>

**Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Fesco Board Minimum 3/4" thick</b>	<b>N/A</b>	<b>N/A</b>
<b>High Density Wood Fiber Minimum 1/2" thick</b>	<b>N/A</b>	<b>N/A</b>

**Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.**

- Base Sheet:** (Optional if using ply sheet in hot asphalt) One or more plies of Elastobase, Modibase, Perma Ply No. 28 or GAFGLAS #75 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Ply Sheet:** (Optional if using base sheet in hot asphalt) One or more plies of Polybond, Polyflex or Xtraflex torch applied or one ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V or Elastoflex V 2.5 or one to more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied
- Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
- Maximum Design Pressure:** -60 psf; (See general limitation #7.)



**Deck Type II:** Wood, Insulated

**Deck Description:** <sup>19</sup>/<sub>32</sub>" or greater plywood or wood plank.

**System Type B(2):** Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

**All General and System Limitations apply.**

One or more layers of the following:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ENRGY-3, H-Shield or Polytherm Minimum 1.5" thick</b>	<b>1 or 10</b>	<b>1:1.33 ft<sup>2</sup></b>

**Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Fesco Board Minimum 3/4" thick</b>	<b>N/A</b>	<b>N/A</b>
<b>High Density Wood Fiber Minimum 1/2" thick</b>	<b>N/A</b>	<b>N/A</b>

**Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.**

**Base Sheet:** (Optional if using ply sheet in hot asphalt) One or more plies of Elastobase, Modibase, Perma Ply No. 28 or GAFGLAS #75 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:** (Optional if using base sheet in hot asphalt) One or more plies of Polybond, Polyflex or Xtraflex torch applied or one ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V or Elastoflex V 2.5 or one to more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

**Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -52.5 psf; (See general limitation #7.)



**Deck Type II:** Wood, Insulated  
**Deck Description:** <sup>19</sup>/<sub>32</sub>" or greater plywood or wood plank, fastened with wood screws at 6" o.c.  
**System Type C(1):** All layers of insulation are mechanically attached to roof deck. Membrane is subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of the following:

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved Polyisocyanurate Minimum 1.5" thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>High Density Wood Fiber Minimum ½" thick</b>	1	1:1.33 ft <sup>2</sup>
<b>Dens Deck, Dens Deck Prime, Securock Minimum ¼" thick</b>	1	1:1.33 ft <sup>2</sup>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** (Optional if using ply sheet in hot asphalt) One or more plies of Elastobase, Modibase, Perma Ply No. 28 or GAFGLAS #75 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:** (Optional if using base sheet in hot asphalt) One or more plies of Polybond, Polyflex or Xtraflex torch applied or one ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V or Elastoflex V 2.5 or one to more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied

**Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -82.5 psf; (See General limitation #7.)



**Deck Type II:** Wood, Insulated  
**Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank, fastened with 8d common nails at 4" o.c.  
**System Type C(2):** All layers of insulation are mechanically attached to roof deck. Membrane is subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of the following:

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved Polyisocyanurate Minimum 1.5" thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>High Density Wood Fiber Minimum 1/2" thick</b>	1	1:1.33 ft <sup>2</sup>
<b>Dens Deck, Dens Deck Prime, Securock Minimum 1/4" thick</b>	1	1:1.33 ft <sup>2</sup>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** (Optional if using ply sheet in hot asphalt) One or more plies of Elastobase, Modibase, Perma Ply No. 28 or GAFGLAS #75 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:** (Optional if using base sheet in hot asphalt) One ply of Polybond, Polyflex or Xtraflex torch applied or one ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V or Elastoflex V 2.5 or one to more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

**Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -67.5 psf; (See General limitation #7.)



**Deck Type II:** Wood, Insulated  
**Deck Description:** <sup>19</sup>/<sub>32</sub>" or greater plywood or wood plank.  
**System Type C(3):** All layers of insulation are mechanically attached to roof deck. Membrane is subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of the following:

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
Any approved Polyisocyanurate Minimum 1.5" thick	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
High Density Wood Fiber Minimum 1/2" thick	1	1:1.33 ft <sup>2</sup>
Dens Deck, Dens Deck Prime, Securock Minimum 1/4" thick	1	1:1.33 ft <sup>2</sup>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** (Optional if using ply sheet in hot asphalt) One or more plies of Elastobase, Modibase, Perma Ply No. 28 or GAFGLAS #75 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:** (Optional if using base sheet in hot asphalt) One or more plies of Polybond, Polyflex or Xtraflex torch applied or one ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V or Elastoflex V 2.5 or one to more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

**Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -52.5 psf; (See General limitation #7.)



**Deck Type 1I:** Wood, Insulated

**Deck Description:** <sup>19</sup>/<sub>32</sub>" or greater plywood or wood plank, fastened with 8d common nails at 4" o.c. or #8 screws at 6" o.c.

**System Type D(1):** All layers of insulation and base sheet mechanically fastened.

**All General and System Limitations apply.**

One or more layers of the following:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved Polyisocyanurate Minimum 1" thick</b>	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Fesco Board Minimum 3/4" thick</b>	N/A	N/A
<b>High Density Wood Fiber Minimum 1/2" thick</b>	N/A	N/A
<b>Dens Deck, Dens Deck Prime, Securock Minimum 1/4" thick</b>	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** One or more plies of Elastobase V or Elastobase P fastened to the deck as described below:

**Fastening:** Attach base sheet using Buildex Roofgrip Fasteners and Flat Bottom Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.

**Ply Sheet:** (Optional) One or more plies of Polyflex, Polybond, or Xtraflex torch applied or one ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V, or Elastoflex V 2.5 or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq..

**Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

**Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -60 psf; (See General limitation #7.)



**Deck Type 1I:** Wood, Insulated

**Deck Description:**  $1\frac{9}{32}$ " or greater plywood or wood plank.

**System Type D(2):** All layers of insulation and base sheet mechanically fastened.

**All General and System Limitations apply.**

One or more layers of the following:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved Polyisocyanurate Minimum 1" thick</b>	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Fesco Board Minimum <math>\frac{3}{4}</math>" thick</b>	N/A	N/A
<b>High Density Wood Fiber Minimum <math>\frac{1}{2}</math>" thick</b>	N/A	N/A
<b>Dens Deck, Dens Deck Prime, Securock Minimum <math>\frac{1}{4}</math>" thick</b>	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** One or more plies of CertainTeed Glasbase, Polyglass Base, Elastobase, Firestone MB Base, JM Perma-Ply #28, Tamko Glass Base or GAFGLAS #75 fastened to the deck as described below:

**Fastening** Attach base sheet using Buildex Roofgrip Fasteners and Flat Bottom Plates, Dekfast #14 with Hex Plates or Tru-Fast HD with MP-3 Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.

**Ply Sheet:** (Optional) One or more plies of Polyflex, Polybond, or Xtraflex torch applied or one ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V, or Elastoflex V 2.5 or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

**Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -52.5 psf; (See General limitation #7.)



**Deck Type 1:** Wood, Non-Insulated

**Deck Description:** <sup>19</sup>/<sub>32</sub>" or greater plywood or wood plank, fastened with 8d common nails at 4" o.c or #8 wood screws at 6" o.c.

**System Type E(1):** Base sheet is mechanically attached to roof deck.

**All General and System Limitations apply.**

**Base Sheet:** One ply of Elastobase Poly/Sand, Sand/Sand fastened to the deck as described below:

**Fastening:** Attach base sheet using Buildex Roofgrip Fasteners and Flat Bottom Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.

**Ply Sheet:** (Optional) One or more plies of Polyflex, Polybond or Xtraflex torch applied or one ply of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V, or Elastoflex V 2.5 or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

**Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -60 psf; (See General limitation #7.)



**Deck Type 1:** Wood, Non-Insulated

**Deck Description:** <sup>119</sup>/<sub>32</sub>" or greater plywood or wood plank, fastened with 8d common nails at 4" o.c or #8 wood screws at 6" o.c.

**System Type E(2):** Base sheet is mechanically attached to roof deck.

**All General and System Limitations apply.**

**Base Sheet:** One ply of CertainTeed Glasbase, Polyglass Base, Elastobase, Firestone MB Base, JM Perma-Ply #28, Tamko Glass Base or GAFGLAS #75 fastened to the deck as described below:

**Fastening:** Attach base sheet using 11 ga. annular ring shank and 1-5/8" diameter tin caps spaced 8" o.c. in a 4" lap and 8" o.c. in three equally spaced staggered rows in the center of the sheet.

**Ply Sheet:** (Optional) One or more plies of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V, Elastoflex V 2.5 or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

**Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -60 psf; (See General limitation #7.)



- Deck Type 1:** Wood, Non-Insulated
- Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank.
- System Type E(3):** Base sheet is mechanically attached to roof deck.

**All General and System Limitations apply.**

- Base Sheet:** One ply of CertainTeed Glasbase, Polyglass Base, Elastobase, Firestone MB Base, JM Perma-Ply #28, Tamko Glass Base or GAFGLAS #75 fastened to the deck as described below:
- Fastening #1:** Attach base sheet using 11 ga. annular ring shank and 1-5/8" diameter tin caps spaced 8" o.c. in a 4" lap and 8" o.c. in three equally spaced staggered rows in the center of the sheet.
- Fastening #2:** Attach base sheet using Buildex Roofgrip Fasteners and Flat Bottom Plates, Dekfast #14 with Hex Plates or Tru-Fast HD with MP-3 Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.
- Ply Sheet:** (Optional) One or more plies of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V, Elastoflex V 2.5 or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.
- Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
- Maximum Design Pressure:** -52.5 psf; (See General limitation #7.)



**Deck Type 1:** Wood, Non-Insulated

**Deck Description:** 1<sup>9</sup>/<sub>32</sub>" or greater plywood or wood plank.

**System Type E(4):** Base sheet is mechanically attached to roof deck.

**All General and System Limitations apply.**

**Base Sheet:** One ply of Elastobase V or Elastobase P fastened to the deck as described below:

**Fastening:** 12 ga. Annular ring shanked nails and 1-5/8" tin-caps 6" o.c. in 4" lap and 6" o.c. in four equally spaced staggered rows. Tin-caps are primed with D41 primer.

**Ply Sheet:** (Optional) One or more plies of Elastobase, Modibase, Perma Ply No. 28, Elastoflex S6, Elastoflex V, Elastoflex V 2.5 or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** One ply of Polyflex, Polflex G, Polyflex G FR, Polybond, Polybond G, Xtraflex, Xtraflex G or Xtraflex G FR torch applied or one ply of Elastoflex S6, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS4 or Elastoshield TS4 FR torch or hot asphalt applied.

**Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -112.5 psf; (See General limitation #7.)



## WOOD DECK SYSTEM LIMITATIONS:

1. A slip sheet is required with Ply 4 and Ply 6 when used as a mechanically fastened base or anchor sheet.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant (**When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.**)
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). (**When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.**)

**END OF THIS ACCEPTANCE**

