



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Soprema, Inc.
310 Quadral Drive
Wadsworth, OH 44281**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCCO reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Soprema Modified Bitumen Roofing Systems Over Wood Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 06-0111.01 and consists of pages 1 through 39.
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 07-1217.08
Expiration Date: 03/01/11
Approval Date: 05/08/08
Page 1 of 39**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Modified Bitumen
Material: SBS
Deck Type: Wood
Maximum Design Pressure -60 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE I

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Sopra-G	39" x 108' (3.5 sq.)	ASTM D 4601	Fiberglass reinforced oxidized asphalt base sheet for bonding or mechanically attaching to substrate.
Modified Sopra-G	39" x 108' (3.5 sq.)	ASTM D 4601	Fiberglass reinforced modified asphalt base sheet for bonding or mechanically attaching to substrate.
Sopraglass M	39" x 66' (2 sq.)	ASTM D 5147	Fiberglass reinforced modified bitumen base sheet. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopraglass M GR	39" x 33' (1 sq.)	ASTM D5147	Fiberglass reinforced modified bitumen base sheet with a mineral granular top surface. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopra ESHAvent	39" x 49' (1.5 sq.)	ASTM D 1970	Fiberglass reinforced modified bitumen membrane with self-adhering round areas on back side and a sanded top side.
Sopraglass 40	39" x 82' (2.5 sq)	ASTM D 4601 Type I	Fiberglass reinforced oxidized asphalt base sheet for bonding, mechanically attaching or ribbon stripping to substrate.
Sopraglass 100	39" x 66' (2 sq.)	ASTM D 4601	Fiberglass reinforced oxidized asphalt base sheet for bonding or mechanically attaching to substrate.
Soprabase	39" x 99' (3 sq.)	ASTM D 6164	Oxidized asphalt, polyester reinforced base sheets. Primarily used as a mechanically attached anchor sheet. Applied in hot asphalt, cold adhesive or ribbon stripped.
Sopra IV or VI	36" x 180' (5 sq.)	ASTM D 2178 Type IV or VI	Type IV or VI, fiberglass reinforced, smooth surfaced plysheet. Sopra IV or VI are used in multi-ply systems and complies with ASTM and UL Standards. Applied in hot asphalt or cold adhesive.
Colvent TG	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass reinforced, modified bitumen membrane with 1" wide factory applied heat weldable strips on back side.



NOA No.: 07-1217.08
 Expiration Date: 03/01/11
 Approval Date: 05/08/08
 Page 2 of 39

Colvent SA	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass reinforced, modified bitumen membrane with 1" wide factory applied self-adhering strips on back side
Colvent 180 TG	39" x 33' (1 sq.)	ASTM D 6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied heat weld strips on back side.
Colvent 180 SA	39" x 33' (1 sq.)	ASTM D6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied self-adhering strips on back side
Colvent 180 TG GR	39" x 33' (1 sq.)	ASTM D 6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied heat weld strips on back side, and a mineral granular top surface.
Colvent 180 SA GR	39" x 33' (1 sq.)	ASTM D6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied self-adhering strips on back side and a mineral granular top surface.
Elastophene Sanded, Elastophene FR	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane sanded on both sides, used as a base and top ply. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene Sanded 3.0	39" x 33' (1sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane sanded on both sides, used as a base and top ply. Applied in hot asphalt, cold adhesive or ribbon stripped.
Elastophene HD	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane sanded on both sides, used as a base and top ply. Applied in hot asphalt, cold adhesive or ribbon stripped.
Elastophene HS FR	39" x 66' (2 sq.)	ASTM D 6162	Woven fiberglass/polyester composite reinforced modified bitumen membrane with fire retardants and sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene Sanded FR	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants and sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene HR	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass scrim reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene HR FR	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass scrim reinforced modified bitumen membrane with fire retardants and sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene HP	39" x 66' (2 sq.)	ASTM D 5147	Fiberglass/non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.



Elastophene PS, Elastophene PS 3.0	39" x 49' (1.5 sq.)	ASTM D 6163	Glass reinforced modified bitumen membrane with a plastic burn-off film for heat weld bonding to the top side. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene SP 2.2mm	39" x 49' (1.5 sq.)	ASTM D 6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied b heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene SP 3.0mm	39" x 49' (1 sq.)	ASTM D 6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied b heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene Flam	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane covered on both sides with a plastic burn-off film. Applied by heat welding.
Elastophene Flam 2.2	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane covered on both sides with a plastic burn-off film. Applied by heat welding.
Elastophene Flam HS FR	39" x 33' (1 sq.)	ASTM D6162	Woven fiberglass/polyester composite reinforced modified bitumen membrane with fire retardants and plastic burn-off film on both sides. Applied by heat welding.
Elastophene Flam HP	39" x 66' (2 sq.)	ASTM D 5147	Fiberglass/non-woven polyester reinforced modified bitumen membrane with plastic burn-off film on both sides. Applied by heat welding.
Elastophene 180 Sanded	39" x 49' (1.5 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene 180 PS	39" x 49' (1.5 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and a plastic burn-off film on the top, used as a base sheet. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene FR GR or FR+ GR, Elastophene LS FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene HR FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass scrim reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.



Elastophene HS FR GR	39" x 33' (1 sq.)	ASTM D 6162	Woven fiberglass/polyester composite reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene HP FR GR	39" x 33' (1 sq.)	ASTM D 5147	Fiberglass/non-woven polyester reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene Flam GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam FR GR or FR+ GR, Elastophene Flam LS FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam HR FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass scrim reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene Flam HS FR GR	39" x 33' (1 sq.)	ASTM D 6162	Woven fiberglass composite reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene Flam HP FR GR	39" x 33' (1 sq.)	ASTM D 5147	Fiberglass/non-woven polyester reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180, 250 or 350	39" x 33' (1 sq.) 39" x 26' (¾ sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides, used as a base/ply/cap. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopralene 180 SP 3.5 mm	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Soprafix [S], [H], [F] and [X]	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.



Soprafix	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with a 4-inch or 5-inch wide side lap with a plastic burn-off film on the bottom and sanded on the top. Applied by mechanical attachment. Lap heat welded or sealed with an approved cold adhesive.
Soprafix-e	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with a 5-inch wide side lap with a self-adhering compound and release film and sanded on the bottom and top surfaces. Applied by mechanical attachment. Lap self-adhered or sealed with approved cold adhesive.
Soprafix (X)	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with plastic burn-off film or sanded on the top and bottom surfaces and a 6-inch wide side lap. Applied by heat welding.
Sopralene Flam 180, 250 or 350	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced SBS modified bitumen membrane, both sides covered with a plastic burn-off film, used as a base/ply. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180, 250 or 350 GR or FR GR	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180, 250 or 350 GR	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180, 250 or 350 FR GR or FR+ GR	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 2.7 mm	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralast	various	ASTM D 6298	Fiberglass reinforced modified bitumen sheeting faced with aluminum, copper or stainless steel foil. Applied by heat welding of ribbon stripping (after removal of plastic burn-off film).
Soprarstar Flam	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced SBS modified bitumen membrane with a plastic burn-off film on the bottom side and a reflective white top surface. Applied by heat welding.



Soprastar Stick	39" x 33' (1 sq)	ASTM D6163	Fiberglass reinforced SBS modified bitumen membrane with a release film covered self-adhering bottom side and a reflective white top surface.
UNILAY	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants and surfaced with mineral granules. Applied by mechanical attachment, heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Stick	39" x 33' (1 sq.)	ASTM D 6164	Self adhered, polyester reinforced membrane with a release film on the bottom and a sanded top.
Sopralene Flam Stick	39" x 33' (1 sq.)	ASTM D 6164	Self adhered, polyester reinforced membrane with a release film on the bottom and a plastic burn-off film on the top.
EPS Flam Stick	39" x 33' (1 sq.)	ASTM D 6163	Self adhered, film surfaced, glass mat/glass grid reinforced membrane with a release film on the bottom and a plastic burn-off film on the top.
Colphene 1500	39" x 33' (1 sq.) 39" x 132' (4 sq.) 39" x 66' (2.1 sq.)	ASTM D 1970	Self adhered, non-reinforced membranes used as a vapor retarder.
Colphene FR GR, Colphene GR	39" x 33' (1 sq.)	ASTM D 6163	Self adhered, granule surfaced, fiberglass reinforced membranes.
Colphene HR FR GR	39" x 33' (1 sq.)	ASTM D 6163	Self adhered, granule surfaced, fiberglass scrim reinforced membranes.
Lastobond S	39" x 49' (1.5 sq.)	ASTM D 1970	Self-adhered underlayment membrane.
Lastobond Shield	various	ASTM D 1970	Self-adhering underlayment membrane.
Lastobond Shield HT	various	ASTM D 1970	Self-adhering underlayment membrane.
Lastobond Shield- R	various	ASTM D 1970	Self-adhering underlayment membrane.
Lastobond Shield- HT RW	various	ASTM D 1970	Self-adhering underlayment membrane.
Sopratape 606	5" wide		Bituminous tape for sealing of side and head laps.
Sopramastic 200	17 oz. pouch or 10.4 oz cartridge		Caulking compound.
Elastocol 400, 500 and 600c	various	ASTM D 41	Asphalt primers.
Sopracolle "E"	keg		Cold-applied adhesive used to bond membrane to prepared substrates or to other membranes.
ALSAN Flashing™	1.25 gallon pail or 3.75 gallon pail		One part polyurethane/bitumen resin, moisture cure compound.
ALSAN Polyfleece	4", 8" or 39" wide by 50' long		Non-woven polyester reinforcement used in the ALSAN Flashing system.
SBS Mastic	10.4 oz tube		Plasticized rubber/bitumen mastic compound.
SBS Elastic Cement	5 gallon pail		Elastomeric bitumen based mastic compound.



Soprawalk	39" x 26' (3/4 sq)		Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and mineral granules on the top. Applied by hot asphalt, cold adhesive or ribbon stripping.
High Velocity® Insulation Adhesive II (HVIA-II)	3 gal pail	Proprietary	One part elastomeric urethane foam adhesive.
High Velocity® Insulation Adhesive III (HVIA-III)	4 dual cartridges per carton	Proprietary	Two part elastomeric urethane foam adhesive.
FM Adhesive	5 gallon pail, 55 gallon drum or 350 gallon tote	Proprietary	Plastomeric bitumen based cold adhesive.
FM Adhesive Trowel Grade	5 gallon pail	Proprietary	Plastomeric bitumen based cold adhesive.
FM Adhesive (VOC)	5 gallon pail, 55 gallon drum or 350 gallon tote	Proprietary	Elastomeric bitumen based cold adhesive.
FM Adhesive (VOC) Trowel Grade	5 gallon pail	Proprietary	Elastomeric bitumen based cold adhesive.
High Velocity® Membrane Adhesive (HVMA)	5 gallon pail or 55 gallon drum	Proprietary	Polyurethane bitumen adhesive.
Sopraboard	various		Mineral fortified asphaltic cored coverboard between two layers of asphalt saturated fiberglass mat.
Granules	5 gallon pail or Supersac		Semi-ceramic coated colored granules.



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
Apache Pyrox, Apache White Line, Apache Pyrox PSI-25, Apache White Line PSI-25	Polyisocyanurate foam insulation	Apache Products Company
Apache Millox, Apache Millox-P	Composite polyisocyanurate insulation	Apache Products Company
ACFoam II, ACFoam III	Polyisocyanurate foam insulation	Atlas Energy Products
ACFoam Composite	Composite polyisocyanurate insulation	Atlas Energy Products
FlintBoard ISO, FlintBoard ISO Cold	Polyisocyanurate foam insulation	CertainTeed Corp.
FlintBoard ISO Plus	Composite polyisocyanurate insulation	CertainTeed Corp.
Hytherm AP	Polyisocyanurate foam insulation	Dow
Hytherm Composite	Composite polyisocyanurate insulation	Dow
ISO 95+, ISO 95+ (25psi)	Polyisocyanurate foam insulation	Firestone
ISO 95+ Composite	Composite polyisocyanurate insulation	Firestone
EnergyGuard ISO, EnergyGuard Ultra	Polyisocyanurate foam insulation	GAF
EnergyGuard Composite	Composite polyisocyanurate insulation	GAF
Extruded or Expanded Polystyrene	Polystyrene Insulation	generic
Gypsum	Gypsum board	generic
High Density Wood Fiberboard	Wood fiber insulation board	generic
Perlite Insulation	Perlite insulation board	generic
DensDeck, DensDeck Prime, DensDeck Fireguard, DensDeck Prime Fireguard, DensDeck DuraGuard	Water resistant gypsum board	G-P Gypsum Corp.
H-Shield	Polyisocyanurate foam insulation	Hunter Panels, Inc.
H-Shield CG	Polyisocyanurate foam insulation	Hunter Panels, Inc.
H-Shield-P, H-Shield-WF	Composite Insulation board	Hunter Panels, Inc.
ENRGY-2	Polyisocyanurate foam insulation	Johns Manville
ENRGY-2 Plus, Composite, Fesco Foam	Composite Insulation board	Johns Manville
ENRGY-3	Polyisocyanurate foam insulation	Johns Manville
ENRGY-3 Plus	Composite Insulation board	Johns Manville
Multi-Max FA	Polyisocyanurate foam insulation	RMax
Thermarroof Composite	Composite Insulation board	RMax
UltraMax	Polyisocyanurate foam insulation	RMax
Multi-Max FA-3	Polyisocyanurate foam insulation	RMax
Thermarroof Composite-3	Composite insulation board	RMax
SECUROCK®	Gypsum board	US Gypsum



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Tri-Fix Fastening System	Fastening system for base sheet attachment to lightweight concrete, gypsum or cementitious wood fiber decks.	3" diameter plate with various length fasteners	Soprema, Inc.
2.	#12, #14 & #15 Soprema Fasteners	Fasteners for membrane or insulation attachment to wood, steel or concrete decks.		Soprema, Inc.
3.	Soprafix [X]-EL #15	Fasteners for membrane attachment to steel or concrete decks.		Soprema, Inc.
4.	Soprafix Plates	AZ-55 Galvalume steel plate for use with the Soprafix system.	2" diameter	Soprema, Inc.
5.	Soprema Plates	Metal or plastic stress plates for use with Soprema Fasteners.	3" diameter	Soprema, Inc.
6.	Sopradisc	Galvanized metal bearing plate used for side lap attachment of Soprafix system.	2" diameter	Soprema, Inc.
7.	Soprema Isofast IF/IFT	AZ-50 Galvalume steel plate for use with the Soprafast System.	2¾" diameter	Soprema, Inc.
8.	Soprafix/Soprafast	Stress plates for membrane securement.	3" diameter	Soprema, Inc.
9.	UNILAY Plate	Stress plates for Unilay membrane securement.	2-3/8" diameter	Soprema, Inc.
10.	#12, #14 & #15 Dekfast Fasteners	Insulation fastener		SFS Intec
11.	Omega Fastener	Stainless steel insulation fastener		SFS Intec
12.	Dekfast Hex Plate	Galvalume AZ50 steel plate	2 7/8" x 3 1/4"	SFS Intec
13.	Dekfast Lock Plate	Polypropylene locking plate.	3" x 3 1/4"	SFS Intec
14.	Twin Loc-Nails	Base ply fastening systems for lightweight concrete, gypsum or cementitious wood fiber decks		ES Products, Inc.
15.	FM-30, FM-45, FM-60, FM-90 Fasteners	Base ply fastening systems for lightweight concrete decks		ES Products, Inc.
16.	OMG AccuTrac Plate	Galvalume square stress plate	3" square	OMG, Inc.
17.	OMG 3" Standard Steel Plate	Galvalume stress plate.	3" round 3" square	OMG, Inc.
18.	Olympic CR Base Ply Fasteners	Base ply fastening assembly		OMG, Inc.



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
19.	NTB Magnum	Glass reinforced Nylon insulation fastener for gypsum & CWF decks with barbs.		OMG, Inc.
20.	NTB Plate	Galvalume stress plate	3" round	OMG, Inc.
21.	Lite-Deck	Insulation fastener for CWF and Gypsum decks.		OMG, Inc.
22.	Lite-Deck Plate	Galvalume stress plate	3" round	OMG, Inc.
23.	Olympic Fastener #12, #14 & #15	Insulation fastener.		OMG, Inc.
24.	Olympic CD-10	Insulation fastener.		OMG, Inc.
25.	Olympic Fluted Nail	Insulation fastener.		OMG, Inc.
26.	Olympic Standard	Galvalume AZ50 steel plate	3" round	OMG, Inc.
27.	Olympic Plastic	Polypropylene stress plate	3.25" round	OMG, Inc.
28.	Powerlite	Insulation fastener.		Powers Fasteners, Inc.
29.	Powerlite	Galvalume stress plate.	3" round	Powers Fasteners, Inc.
30.	Base-Lok Fasteners	Base sheet fastener for lightweight concrete, cwf and gypsum decks	1.75" long with 3" dia. head	Simplex Nails
31.	Turbo Tube-Lok Fasteners	Base sheet fastener for lightweight concrete, cwf and gypsum decks	1.75" long with 2" dia. head	Simplex Nails
32.	SFS Base-Lok Fasteners	Base sheet fastener for lightweight concrete, cwf and gypsum decks	1.75" long with 3" dia. head	SFS Intec, Inc.
33.	Insul-Fixx Fastener	Insulation fastener for wood, steel and concrete.		SFS Intec, Inc.
34.	Isofast Fasteners	Insulation fastener for wood, steel and concrete.		SFS Intec, Inc.
35.	Extra Load Fasteners #15	Fasteners for membrane attachment to steel or concrete decks.		SFS Intec, Inc.
36.	Insul-Fixx S Plate	Galvalume AZ50 steel plate	3" round	SFS Intec, Inc.
37.	Insul-Fixx P Plate	Polyethylene stress plate	3" round	SFS Intec, Inc.
38.	Isofast Plate	Square or oblong galvalume steel plates for use with Isofast fasteners		SFS Intec, Inc.



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
39.	ES-I Fastening Systems	Insulation fastening assembly with plate.	3" round	SFS Intec, Inc.
40.	#12, #14 & #15 Dekfast Fastener	Insulation fastener		SFS Intec
41.	Omega Fastener	Stainless steel insulation fastener		SFS Intec
42.	Dekfast Hex Plate	Galvalume AZ50 steel plate	2 7/8" x 3 1/4"	SFS Intec
43.	DekFlat Lock Plate	Polypropylene locking plate.	3" x 3 1/4"	SFS Intec
44.	Tru-Fast TL Fastener	Insulation fastener for lightweight concrete, CWF and gypsum decks		The Tru-Fast Corp.
45.	Tru-Fast Fastener	Insulation fastener for wood, steel and concrete.		The Tru-Fast Corp.
46.	Tru-Fast HD or EHD	Insulation fastener for wood, steel and concrete.		The Tru-Fast Corp.
47.	Tru-Fast MP-3	Galvalume AZ50 steel plate	3" round	The Tru-Fast Corp.
48.	Tru-Fast Metal	Galvalume AZ55 steel plate	3" round	The Tru-Fast Corp.
49.	Tru-Fast Plastic	Polypropylene plate	3" round	The Tru-Fast Corp.
50.	ES Products Batten Bar-TL	Batten bar		ES Products, Inc.
51.	OMG #12	Insulation fastener		OMG, Inc.
52.	OMG Polymer Batten Strip	Modified polymer batten bar		OMG, Inc.
53.	OMG MAXLoad	Insulation fastener		OMG, Inc.
54.	Olympic Heavy Duty	Insulation fastener		OMG, Inc.
55.	Olympic ASAP 3P	Pre-assembled insulation fastener and plastic plate	3" round	OMG, Inc.
56.	Olympic ASAP 3S	Pre-assembled insulation fastener and steel plate	3" round	OMG, Inc.
57.	Isofast IF2	Insulation fastener		SFS Intec
58.	Isofast IF/IG	Galvalume AZ50 steel plate	82 x 40 mm	SFS Intec
59.	Isofast IFC/IW	Galvalume AZ50 steel plate	70 x70 mm	SFS Intec
60.	#15 Dekfast HS	Insulation fastener		SFS Intec
61.	Galvalume Steel 3" Round Insulation Plate	Galvalume AZ50 steel plate	3" round	SFS Intec
62.	K-Fast Fastener	Insulation Fastener		SFS Intec



NOA No.: 07-1217.08
 Expiration Date: 03/01/11
 Approval Date: 05/08/08
 Page 12 of 39

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
63.	Dekfast Steel Batten Bar	Galvalume AZ50 steel		SFS Intec
64.	Dekfast Coiled Batten Strip	Batten bar		SFS Intec
65.	Soprafix #14 PAS-2" SB Stress Plate	Pre-assembled plate and fastener	2" diameter	Soprema, Inc.
66.	Soprema 3" Insulation Plate	Stress plate	3" diameter	Soprema, Inc.
67.	Soprafix 2" – SB Stress Plate	Stress plate	2" diameter	Soprema, Inc.
68.	Soprafix 2-3/8" – SB Stress Plate	Stress plate	2-3/8" diameter	Soprema, Inc.
69.	Soprafix (X) 2-3/4" Stress Plate	Stress plate	2-3/4" diameter	Soprema, Inc.
70.	Soprafix MBB-R	Metal Batten Bar		Soprema, Inc.
71.	Soprema #12, #14, #15 Fastener	Insulation and membrane fasteners		Soprema, Inc.
72.	Soprema PAS #12-3" Insulation Plate	Pre-assembled plate and fastener	3" diameter	Soprema, Inc.
73.	Soprafix #21-K Fastener	Insulation and membrane fastener		Soprema, Inc.
74.	Tru-Fast DP	Insulation fastener for wood, steel and concrete		The Tru-Fast Corp.
75.	Tru-Fast SHD	Insulation fastener for wood, steel and concrete		The Tru-Fast Corp.
76.	Tru-Fast MPH-3	Galvalume AZ50 steel plate	3" round	The Tru-Fast Corp.
77.	Tru-Fast MP-2000			The Tru-Fast Corp.
78.	Tru-Fast MPB-2000			The Tru-Fast Corp.
79.	Tru-Fast MPB-2400			The Tru-Fast Corp.
80.	Tru-Fast BB-18 Batten Bar	Galvalume AZ55 steel batten bar		The Tru-Fast Corp.
81.	Tru-Fast BB-18-R Batten Bar	Galvalume AZ55 steel batten bar with recessed holes		The Tru-Fast Corp.
82.	Tru-Fast Twin-Loc Batten Bar	Batten bar		The Tru-Fast Corp.



APPROVED SURFACING/COATING OPTIONS:

TABLE 4

System Number	Manufacturer	Application
1.	Generic	Gravel applied at 400 lbs/sq., adhered with flood coat of asphalt at 60 lbs/sq.
2.	Generic	Slag applied at 300 lbs/sq., adhered with flood coat of asphalt at 60 lbs/sq.
3.	Soprema	Gravel applied at 400 lbs/sq., adhered with FM Adhesive or FM Adhesive (VOC) at 4 gal/sq.
4.	Karnak Corporation	Karnak #97 Fibrated Aluminum Roof Coating applied at an application rate of 1.5 gal/sq.
5.	Soprema	Cural Aluminizer applied at an application rate of 2 gal/sq.
6.	Thermo Manufacturing Systems, LLC	Super Prep Roof Coating applied in two coats at an application rate of 1.5 gal/sq/coat.
7.	United Coatings Manufacturing Company	Roof Mate Coating, applied in one base coat at a rate of 1.5 gal/sq, and one finish coat at a rate of 1.5 gal/sq.
8.	Insulating Coatings Corporation	Astec 2000 Finish Coat applied in two base coats at a rate of 0.75 gal/sq/coat and two finish coats at a rate of 0.75 gal/sq/coat.
9.	Henry Company	HE280DC White Elastomeric Roof Coating applied in two coats at an application rate of 1 gal/sq/coat.
10.	National Coating	Acryshield® A500 applied in two coats at an application rate of 1 gal/sq/coat.

EVIDENCE SUBMITTED:

Test Agency/Identifier	Name	Report	Date	
Dynatech Engineering Corp.	10.94.27	Wind Uplift	10.27.94	
	2491-04.95	Wind Uplift	01.04.95	
Exterior Research & Design, LLC.	2003.02.97-1	Wind Uplift	02.15.97	
	2003-2.04.97-1	Wind Uplift	04.15.97	
	2002.07.97-1	Wind Uplift	08.15.97	
	2738-10.00-1	Wind Uplift	10/20/2000	
	2757.02.05	Physical Properties	02/03/05	
	2778.07.05	Wind Uplift	07/15/05	
	2779.11.05-R1	Wind Uplift	04.18.07	
	S6740.11.07	Physical Properties	11.02.07	
	Factory Mutual Research Corporation	J.I. 1Z3A6.AM	Wind Uplift Classification	04.27.95
		J.I. 1W8A1.AM	Wind Uplift Classification	07.15.93
J.I. 2D0A0.AM		Wind Uplift Classification	08.15.97	
3014614		FM 4470	02.27.06	
3025860		FM 4470	04.17.06	
3026028		FM 4470	05.25.06	
3023749		FM 4470	09.28.06	
3029098		FM 4470	10.25.07	
IRT of S. Florida ITS / Warnock Hersey	990028	Wind Uplift	9/30/99	
		ASTM D 5147 Physical	05.27.93	



NOA No.: 07-1217.08
 Expiration Date: 03/01/11
 Approval Date: 05/08/08
 Page 14 of 39

APPROVED ASSEMBLIES:

- Deck Type II:** Wood, Insulated
- Deck Description:** 1 9/32" or greater plywood or wood plank
- System Type A(1):** Anchor sheet mechanically fastened; all layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of the following:

<u>Insulation Base Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
AC Foam II, AC Foam III, H-Shield (flat or tapered) Minimum 1.5" thick	N/A	N/A
E'NRG'Y-2, ENRGY3 (flat or tapered) Minimum 1.4" thick	N/A	N/A
<u>Insulation Base or Top Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
Toprox Minimum 1.0" thick	N/A	N/A
<u>Insulation Top Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
BP High Strength, FM-90 Traffic Top/High Density, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek Minimum 0.5" thick	N/A	N/A
Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board Minimum 0.75" thick	N/A	N/A
DensDeck Minimum 0.25" thick	N/A	N/A
Fireguard, type X gypsum Minimum 0.25" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Anchor Sheet: One ply of Sopra-G, Modified Sopra-G, Sopraglass 100, GAFGLAS #75, Celotex Vaporbar, or Johns Manville GlasBase fastened to the deck as described. Attach anchor sheet using approved roofing nails and tin caps spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.



Base Sheet: (Optional) One or two plies of Sopra-G, Modified Sopra-G, Sopraglass 100, Sopra-IV, Elastobase, GAFGLAS #75, Celotex Vaporbar, Johns Manville GlasBase, or Johns Manville GlasPly IV adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded.

Or

One ply of Elastophene Sanded, Elastophene 180 Sanded, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 PS*, Sopralene (180, 250 or 350) PS*, or Sopralene (180, 250 or 350) Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced anchor or base membrane.

*Requires heat welded cap membrane.

Membrane: Elastophene SP, Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Soprastar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, or Sopralast 50 TV Alu, heat welded.

Or

Elastophene Sanded*, Elastophene 180 Sanded*, Sopralene (180, 250, 350) Sanded*, Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced ply membrane

*Requires approved Surfacing.

Surfacing: Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Deck TypeII: Wood, Insulated
Deck Description: 19/32" or greater plywood or wood plank
System Type A(2): Anchor sheet mechanically fastened, all layers of insulation adhered with approved asphalt or adhesive.

All General and System Limitations apply.

Vapor Retarder: One layer Elastophene HP, Soprabase, Elastophene 180 Sanded, Sopralene 180 Sanded, Sopralene 180 Sanded 2.2 mm, Sopralene 180 Sanded 3.5mm, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5mm, Sopralene 250 SP, Sopralene 350 Sanded or Sopralene 350 SP, mechanically attached with FBC HVHZ nails and tin-caps spaced 6" o.c. in a 4" wide side lab and 6" o.c. in three evenly spaced rows in the field of the sheet.

One or more layers of the following.

Base Insulation (Optional)

Layer:

Min 1.5" thick AC Foam II, AC Foam III, ENRGY 3, Multi-Max FA, Multi-Max FA-3 or H-Shield, adhered to the vapor barrier in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft², or in Soprema High Velocity® Insulation Adhesive II (HVIA-II) or High Velocity® Insulation Adhesive III (HVIA-III) in ¾" wide ribbons, Insta-Stik adhesive in 1" wide ribbons, TITASET or FasTac in 3" wide ribbons, spaced 6" o.c. (Adhesive is applied atop fastener rows)

Top Insulation

Layer:

Min. ¼" thick DensDeck or SECUROCK® or min. 1/8" Sopraboard, adhered to the vapor barrier or base insulation layer in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft², or in Soprema High Velocity® Insulation Adhesive II (HVIA-II) or High Velocity® Insulation Adhesive III (HVIA-III) in ¾" wide ribbons, Insta-Stik adhesive in 1" wide ribbons, TITASET or FasTac in 3" wide ribbons, spaced 6" o.c. (Adhesive is applied atop fastener rows)

Note: Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as a final membrane substrate.

Primer:

Elastocol 400, 500, Elastocol 600c or AquaTac at a rate of 1 gal/sq, for use of Colvent SA or Colvent 180 SA.

(Optional) Elastocol 500, Elastocol 600c or AquaTac at a rate of 1 gal/sq for Colvent TG or Colvent 180 TG application.

Base Sheet:

One layer Colvent SA or Colvent 180 SA self-adhered.
Or
One layer Colvent TG or Colvent 180 TG, heat welded.

Ply Sheet:

(Optional)

One or more layers of Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.

Or

Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS*, adhered in hot asphalt at 25 lbs/sq. to sand surfaced base membrane.

*Requires heat welded cap membrane.

Membrane:

Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Sopralene 180 SP 3.5mm*, Soprafix*, Soprastar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

One layer of Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR UW GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR, adhered in hot asphalt at 25 lbs/sq. to sand surfaced base or ply membrane.

*Requires approved Surfacing.

Surfacing:

Surfacing is Optional on granular surfaced field cap membranes.

Surfacing is Required for smooth or sanded surfaced field cap membranes.

Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications

Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

Maximum Design Pressure:

-60 psf (See General Limitation #7.)



NOA No.: 07-1217.08
Expiration Date: 03/01/11
Approval Date: 05/08/08
Page 18 of 39

Deck TypeII: Wood, Insulated
Deck Description: 19/32" or greater plywood or wood plank
System Type A(3): Anchor sheet mechanically fastened, all layers of insulation adhered with approved asphalt or adhesive.

All General and System Limitations apply.

Vapor Retarder: One layer Elastophene HP, Soprabase, Elastophene 180 Sanded, Sopralene 180 Sanded, Sopralene 180 Sanded 2.2 mm, Sopralene 180 Sanded 3.5mm, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5mm, Sopralene 250 SP, Sopralene 350 Sanded or Sopralene 350 SP, mechanically attached with FBC HVHZ nails and tin-caps spaced 6" o.c. in a 4" wide side lab and 6" o.c. in three evenly spaced rows in the field of the sheet.

One or more layers of the following.

Base Insulation Layer: (Optional)

Min 1.5" thick ACFoam II, ACFoam III, ENRGY 3, Multi-Max FA, Multi-Max FA-3 or H-Shield, adhered to the vapor barrier in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft², or in Soprema High Velocity® Insulation Adhesive II (HVIA-II) or High Velocity® Insulation Adhesive III (HVIA-III) in ¾" wide ribbons, Insta-Stik adhesive in 1" wide ribbons, TITSESET or FasTac in 3" wide ribbons, spaced 6" o.c. (Adhesive is applied atop fastener rows)

Top Insulation Layer:

Min. ¼" thick Dens Deck or Securock or min. 1/8" Sopraboard, adhered to the vapor barrier or base insulation layer in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft², or in Soprema High Velocity® Insulation Adhesive II (HVIA-II) or High Velocity® Insulation Adhesive III (HVIA-III) in ¾" wide ribbons, Insta-Stik adhesive in 1" wide ribbons, TITSESET or FasTac in 3" wide ribbons, spaced 6" o.c. (Adhesive is applied atop fastener rows)

Note: Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as a final membrane substrate.

Primer: Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any insulation, base or ply sheet prior to application of next layer.
(Optional) Elastocol 400, 500, Elastocol 600c or AquaTac at a rate of 1 gal/sq for Colvent TG or Colvent 180 TG.



Base Sheet:

One layer of Sopralene Flam Stick*, EPS Flam Stick*, Sopralene Stick, Colvent SA or Colvent 180 SA, self-adhered.

Or

One layer of Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, Colvent TG or Colvent 180 TG, heat welded.

Or

One layer of Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm, Sopralene 350 Sanded, Sopralene 350 PS*, adhered in hot asphalt at 25 lbs/sq, FM Adhesive or FM Adhesive (VOC).

*Requires heat welded ply or cap membrane.

Ply Sheet:

(Optional)

One or more layers of Sopralene Flam Stick*, EPS Flam Stick*, Sopralene Stick, self-adhered to sand surfaced base membrane.

Or

Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.

Or

Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS*, adhered in hot asphalt at 25 lbs/sq, FM Adhesive or FM Adhesive (VOC) to sand surface base membrane.

*Requires heat welded cap membrane.



Membrane:

One layer of Colphene HR FR GR, Colphene FR GR, Colphene GR, Sopralene Stick*, or Colphene SA GR, self-adhered to sand surfaced base or ply membrane.

Or

Soprarstar Stick, self-adhered to Elastocol 600c primed sand surfaced base or ply membrane

Or

Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Soprarstar Flam, Sopralene 180 SP 3.5mm*, Soprafix*, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

One layer of Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR UW GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR, adhered in hot asphalt at 25 lbs/sq, FM Adhesive or FM Adhesive (VOC) to sand surfaced base or ply membrane.

*Requires approved Surfacing.

Surfacing:

Surfacing is Optional on granular surfaced field cap membranes.

Surfacing is Required for smooth or sanded surfaced field cap membranes.

Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications

Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

Maximum Design Pressure:

-60 psf (See General Limitation #7.)



Deck Type 1I: Wood, Insulated
Deck Description: 1 9/32" or greater plywood or wood plank
System Type B(1): Base layer of insulation mechanically attached, optional top layer adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of the following:

<u>Insulation Base Layer</u>	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener Density/ft²</u>
AC Foam II, AC Foam III, H-Shield (flat or tapered) Minimum 1.5" thick	2, 10, 11, 23, 33, 34, 39, 40, 41, 45	1:2 ft ²
Minimum 2.0" thick	2, 10, 11, 23, 33, 34, 39, 40, 41, 45	1:4 ft ²
E'NRG'Y-2, ENRGY3, PSI-25 (flat or tapered) Minimum 1.4" thick	2, 10, 11, 23, 33, 34, 39, 40, 41, 45	1:2.67 ft ²
Minimum 2.0" thick	2, 10, 11, 23, 33, 34, 39, 40, 41, 45	1:4 ft ²
AC Foam Composite, E'NRG'Y-2 Composite, E'NRG'Y-2 Plus, ENRGY3 Plus (flat or tapered) Minimum 1.5" thick	2, 10, 11, 23, 33, 34, 39, 40, 41, 45	1:4 ft ²
Toprox Minimum 1.0" thick	2, 23	1:2.4 ft ²
DensDeck Minimum 0.25" thick	2, 10, 23, 33, 40	1:4 ft ²
Fireguard Minimum 5/8" thick	2, 10, 23, 33, 40	1:4 ft ²
Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board Minimum 0.75" thick	10, 11, 40, 41	1:2 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density. See Roofing Application Standard RAS 117 for fastening details.

<u>Insulation Middle Layer</u>	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener Density/ft²</u>
(Optional) EPS Board - For use between Dens Deck or Fireguard base layer and Approved wood fiber top layer only. Minimum 1.0" thick	N/A	N/A



Insulation Top Layer

Insulation Fasteners
(Table 3)

Fastener
Density/ft²

BP High Strength, FM-90 Traffic Top/High Density, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek
Minimum 0.5" thick

N/A

N/A

Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board
Minimum 0.75" thick

N/A

N/A

DensDeck
Minimum 0.25" thick

N/A

N/A

Fireguard, Type X gypsum
Minimum 5/8" thick

N/A

N/A

Toprox
Minimum 1.0" thick

N/A

N/A

Note: Apply optional top layer of insulation shall be adhered with approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side face down.

Base Sheet: (Optional) One or two plies of Sopra-G, Modified Sopra-G, Sopraglass 100, Sopra-IV, Elastobase, GAFGLAS #75, Celotex Vaporbar, Johns Manville GlasBase, or Johns Manville GlasPly IV adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq..

Ply Sheet: One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded
Or
One ply of Elastophene Sanded, Elastophene 180 Sanded, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 PS*, Sopralene (180, 250 or 350) PS*, or Sopralene (180, 250 or 350) Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base membrane.
*Requires heat welded cap membrane.

Membrane: Elastophene SP*, Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, SopraStar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, or Sopralast 50 TV Alu, heat welded
Or
Elastophene Sanded*, Elastophene 180 Sanded*, Sopralene (180, 250, 350) Sanded*, Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base or ply membrane.
*Requires approved Surfacing.

Surfacing: Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Deck Type 1I: Wood, Insulated
Deck Description: 1 9/32" or greater plywood or wood plank
System Type C(1): All layers of insulation simultaneously attached.

All General and System Limitations apply.

One or more layers of the following:

<u>Insulation Base Layer</u>	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener Density/ft²</u>
AC Foam II, AC Foam III, E'NRG'Y-2, ENRGY3, PSI-25, H-Shield (flat or tapered) Minimum 1.0" thick	N/A	N/A
DensDeck Minimum 0.25" thick	N/A	N/A
Fireguard, Type X gypsum Minimum 5/8" thick	N/A	N/A
Toprox Minimum 1.0" thick	N/A	N/A

Note: All layers of insulation shall be simultaneously fastened; see layer below for fasteners and density.

<u>Insulation Top Layer</u>	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener Density/ft²</u>
AC Foam II, AC Foam III, H-Shield (flat or tapered) Minimum 1.5" thick	2, 10, 11, 23, 33, 34, 39, 40, 41, 45	1:2 ft ²
Minimum 2.0" thick	2, 10, 11, 23, 33, 34, 39, 40, 41, 45	1:4 ft ²
E'NRG'Y-2, ENRGY3, PSI-25 (flat or tapered) Minimum 1.4" thick	2, 10, 11, 23, 33, 34, 39, 40, 41, 45	1:2.67 ft ²
Minimum 2.0" thick	2, 10, 11, 23, 33, 34, 39, 40, 41, 45	1:4 ft ²
AC Foam Composite, E'NRG'Y-2 Composite, E'NRG'Y-2 Plus, ENRGY3 Plus (flat or tapered) Minimum 1.5" thick	2, 10, 11, 23, 33, 34, 39, 40, 41, 45	1:4 ft ²
Toprox Minimum 1.0" thick	2, 23	1:2.4 ft ²
Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board Minimum 0.75" thick	2, 10, 11, 33, 34, 39, 40, 41, 45	1:2 ft ²
Esgard, High Density Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard Minimum 1.0" thick	2, 10, 11, 33, 34, 39, 40, 41, 45	1:4 ft ²
DensDeck Minimum 0.25" thick	2, 10, 11, 23, 40, 41	1:4 ft ²
Fireguard, type X gypsum Minimum 5/8" thick	2, 10, 11, 23, 40, 41	1:4 ft ²



Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners shall be increased maintaining the same fastener density. (See Roofing Application Standard RAS 117 for fastening details.)

Base Sheet: (Optional) One or two plies of Sopra-G, Modified Sopra-G, Sopraglass 100, Sopra-IV, Elastobase, GAFGLAS #75, Celotex Vaporbar, Johns Manville GlasBase, or Johns Manville GlasPly IV adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq..

Ply Sheet: One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded

Or

One ply of Elastophene Sanded, Elastophene 180 Sanded, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 PS*, Sopralene (180, 250 or 350) PS*, or Sopralene (180, 250 or 350) Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base membrane.

*Requires heat welded cap membrane.

Membrane: Elastophene SP*, Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, SopraStar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, or Sopralast 50 TV Alu torch applied

Or

Elastophene Sanded*, Elastophene 180 Sanded*, Sopralene (180, 250, 350) Sanded*, Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced ply membrane.

*Requires approved Surfacing.

Surfacing: Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



NOA No.: 07-1217.08
Expiration Date: 03/01/11
Approval Date: 05/08/08
Page 25 of 39

Deck Type II: Wood, Insulated
Deck Description: 19/32" or greater plywood or wood plank
System Type C(2): All layers of insulation simultaneously attached.

All General and System Limitations apply.

One or more layers of the following.

<u>Insulation Base Layer</u>	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener</u> <u>Density/ft²</u>
(Optional) Any approved ASTM C1289, Type II, Class 1 or 2, polyisocyanurate insulation (flat or tapered) Minimum 1.0" thick	N/A	N/A
(Optional) Any approved ASTM C578, minimum 1.25 pcf EPS Minimum 1.0" thick	N/A	N/A

Note: All layers of insulation shall be simultaneously fastened; see layer below for fasteners and density.

<u>Insulation Top Layer</u>	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener</u> <u>Density/ft²</u>
DensDeck, Securock Minimum 0.25" thick	2, 10, 23, 40, 46 (minimum #14)	1:1.6 ft ²
Sopraboard Minimum 1/8" thick	2, 10, 23, 40, 46 (minimum #14)	1:1.6 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners shall be increased maintaining the same fastener density. (See Roofing Application Standard RAS 117 for fastening details.)

Primer: (Optional) Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any insulation, base or ply sheet prior to application of next layer.

Base Sheet: One layer Colvent SA or Colvent 180 SA, self adhered.
Or
One layer Colvent TG or Colvent 180 TG, heat welded.

Ply Sheet: (Optional)

One or more layers of Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.

Or

Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS*, adhered in hot asphalt at 25 lbs/sq. to sand surfaced base membrane.

*Requires heat welded cap membrane.



Membrane:

Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Soprastar Flam, Sopralene 180 SP 3.5mm*, Soprafix*, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

One layer of Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR UW GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR, adhered in hot asphalt at 25 lbs/sq. to sand surfaced base or ply membrane.

*Requires approved Surfacing.

Surfacing:

Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

Maximum Design Pressure:

-52.5 psf (See General Limitation #7.)



Deck Type 1I: Wood, Insulated
Deck Description: 19/32" or greater plywood or wood plank
System Type C(3): All layers of insulation simultaneously attached.

All General and System Limitations apply.

One or more layers of the following.

<u>Insulation Base Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
(Optional) Any approved ASTM C1289, Type II, Class 1 or 2, polyisocyanurate insulation (flat or tapered) Minimum 1.0" thick	N/A	N/A
(Optional) Any approved ASTM C578, minimum 1.25 pcf EPS Minimum 1.0" thick	N/A	N/A

Note: All layers of insulation shall be simultaneously fastened; see layer below for fasteners and density.

<u>Insulation Top Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
DensDeck, Securock Minimum 0.25" thick	2, 10, 23, 40, 46 (minimum #14)	1:1.6 ft ²
Sopraboard Minimum 1/8" thick	2, 10, 23, 40, 46 (minimum #14)	1:1.6 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners shall be increased maintaining the same fastener density. (See Roofing Application Standard RAS 117 for fastening details.)

Primer: (Optional) Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any insulation, base or ply sheet prior to application of next layer.

Base Sheet: One layer of Sopralene Flam Stick*, EPS Flam Stick*, Sopralene Stick, Colvent SA or Colvent 180 SA, self-adhered.

Or

One layer of Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, Colvent TG or Colvent 180 TG, heat welded.

Or

One layer of Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm, Sopralene 350 Sanded, Sopralene 350 PS*, adhered in hot asphalt at 25 lbs/sq, FM Adhesive or FM Adhesive (VOC).

*Requires heat welded ply or cap membrane.



Ply Sheet:

(Optional)

One or more layers of Sopralene Flam Stick*, EPS Flam Stick*, Sopralene Stick, self-adhered to sand surfaced base membrane.

Or

Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.

Or

Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS*, adhered in hot asphalt at 25 lbs/sq, FM Adhesive or FM Adhesive (VOC) to sand surfaced base membrane.

Membrane:

One layer of Colphene HR FR GR, Colphene FR GR, Colphene GR, Sopralene Stick, or Colphene SA GR, self-adhered to sand surfaced base or ply membrane.

Or

Soprastar Stick, self-adhered to Elastocol 600c primed sand surfaced base or ply membrane

Or

Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Soprastar Flam, Sopralene 180 SP 3.5mm*, Soprafix*, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

One layer of Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR UW GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR, adhered in hot asphalt at 25 lbs/sq, FM Adhesive or FM Adhesive (VOC) to sand surfaced base or ply membrane.

*Requires approved Surfacing.

Surfacing:

Surfacing is Optional on granular surfaced field cap membranes.

Surfacing is Required for smooth or sanded surfaced field cap membranes.

Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications

Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

Maximum Design Pressure:

-52.5 psf (See General Limitation #7.)



Deck Type II: Wood, Insulated
Deck Description: 19/32" or greater plywood or wood plank
System Type D(1): All layers of insulation and base sheet simultaneously attached.

All General and System Limitations apply.

One or more layers of the following:

<u>Insulation Base Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
AC Foam II, AC Foam III, H-Shield (flat or tapered) Minimum 1.5" thick	N/A	N/A
E'NRG'Y-2, ENRGY3 (flat or tapered) Minimum 1.4" thick	N/A	N/A
<u>Insulation Base or Top Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
Toprox Minimum 1.0" thick	N/A	N/A
<u>Insulation Top Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
(Optional) BP High Strength, FM-90 Traffic Top/High Density, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek Minimum 0.5" thick	N/A	N/A
(Optional) Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board Minimum 0.75" thick	N/A	N/A
(Optional) DensDeck, Securock Minimum 0.25" thick	N/A	N/A
(Optional) Sopraboard Minimum 1/8" thick	N/A	N/A
(Optional) Fireguard, Type X gypsum Minimum 5/8" thick	N/A	N/A

Note: Top insulation layer shall have preliminary attachment at a density of two Approved insulation fasteners per board for insulation boards having any one dimension no greater than 4 ft. and a minimum of four Approved insulation fasteners per board for insulation boards having any one dimension greater than 4 ft. Composite insulation panels shall be placed with the polyisocyanurate side down.

Base Sheet: One ply of Sopra-G, Modified Sopra-G, Sopraglass 100, GAFGLAS #75, Celotex Vaporbar, or Johns Manville GlasBase fastened to the deck as described. Attach base sheet using CF #14 Dekfast with Hex Plates or SFS Insulfixx S or HD Insulfixx S spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.



Ply Sheet: (Optional) One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded
Or
One ply of Elastophene Sanded, Elastophene 180 Sanded, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 PS*, Sopralene (180, 250 or 350) PS*, or Sopralene (180, 250 or 350) Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base membrane.

Membrane: *Requires heat welded cap membrane.
Elastophene SP*, Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Soprastar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, or Sopralast 50 TV Alu, heat welded

Or
Elastophene Sanded*, Elastophene 180 Sanded*, Sopralene (180, 250, 350) Sanded*, Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base or ply membrane.

*Requires approved Surfacing.

Surfacing: Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure: -45 psf (See General Limitation #9.)



- Deck Type 1I:** Wood, Insulated
- Deck Description:** 1⁹/₃₂" or greater plywood or wood plank
- System Type D(2):** All layers of insulation and base sheet simultaneously attached.

All General and System Limitations apply.

One or more layers of the following:

<u>Insulation Base Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
AC Foam II, AC Foam III, E'NRG'Y-2, ENRGY3, H-Shield (flat or tapered) Minimum 1.4" thick	N/A	N/A
Toprox Minimum 2.0" thick	N/A	N/A
<u>Insulation Top Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
(Optional) BP High Strength, FM-90 Traffic Top/High Density, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek Minimum 0.5" thick	N/A	N/A
(Optional) Celotherm, ConPerl, GAFTEMP Permalite, Fesco Board Minimum 0.75" thick	N/A	N/A
(Optional) DensDeck, Securock Minimum 0.25" thick	N/A	N/A
(Optional) Sopraboard Minimum 1/8" thick	N/A	N/A
(Optional) Fireguard, Type X gypsum Minimum 5/8" thick	N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density. Composite insulation panels shall be placed with the polyisocyanurate side down.

- Base Sheet:** One ply of Soprafix, Soprafix-T or Sopralene Flam 180*, Sopralene Flam 250* fastened to the deck as described below:
*Requires heat welded ply or cap membrane.
- Fastening #1:** Attach base sheet using Insulfixx or Soprema fasteners with Soprafix 2" Round Barbed Plates spaced 18" o.c. in a 4" wide heat welded or bituminous taped seam.
- Fastening #2:** Attach base sheet using Insulfixx or Isofast fasteners and Insulfixx or Isofast plates spaced 24" o.c. in the center of the sheet. Laps are heat fused. Fastener rows are stripped in with a 7" wide section of torch applied base sheet membrane.



Ply Sheet: (Optional) One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded

*Requires heat welded cap membrane.

Membrane: Elastophene SP*, Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, SopraStar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, or Sopralast 50 TV Alu, heat welded.

Or

Colphene FR GR, Colphene GR, Colphene HR FR GR, Colphene HR GR or SopraStar Stick, self adhered to sand surfaced base or ply membrane

*Requires approved Surfacing.

Surfacing: Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



- Deck Type 1I:** Wood, Insulated
- Deck Description:** Min. 19/32" plywood or wood plank
- System Type D(3):** All layers of insulation and base sheet simultaneously attached.
- Deck:** Decking is attached to spans spaced maximum 24" o.c. with #10 wood screws spaced maximum 6" o.c.

All General and System Limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Any approved polyisocyanurate (flat or tapered) Minimum 1" thick	N/A	N/A
Any approved 1.25 pcf polystyrene Minimum 1" thick	N/A	N/A
Rockwool Minimum 1" thick	N/A	N/A
High density wood fiberboard Minimum 0.5" thick	N/A	N/A
Perlite Minimum 0.75" thick	N/A	N/A
DensDeck, DensDeck Prime, Securock Minimum 0.5" thick	N/A	N/A
Sopraboard Minimum 1/8" thick	N/A	N/A

Note: Insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Primer: Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer

Base Sheet: One ply of Soprafix, Soprafix (X)*, Soprafix-e, fastened to the deck as described below:

*Requires heat welded ply or cap membrane.

Fastening: Attach base sheet using Soprafix Polymer Batten Strip (PBB), Metal Batten Strip (MBB or MBB-R) with Soprema #15-EL fasteners spaced 6" o.c. in the minimum 5" wide lap.

Ply Sheet: (Optional)

Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.

*Requires heat welded cap membrane.



Membrane: SopraStar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, heat welded.

Or

SopraStar Stick, self-adhered to Elastocol 600c primed sand surfaced base or ply membrane

Surfacing: Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

Maximum Design Pressure: -52.5 psf (with SopraStar Flam or SopraStar Stick as cap membrane)
(See General Limitation #7)
-90.0 psf (with all other cap membranes) (See General Limitation #7)



Deck Type 1: Wood, Non-insulated
Deck Description: 19/32" or greater plywood or wood plank decks
System Type E(1): Base sheet mechanically fastened.

All General and System Limitations apply.

Barrier: (Optional) Roctex Rocroof, loose laid
Base Sheet: One or two plies of Sopra-G, Modified Sopra-G, Sopraglass 100, GAFGLAS #75, Celotex Vaporbar, or Johns Manville GlasBase fastened to the deck using approved roofing nails and tin caps spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

Ply Sheet: One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded
Or
One ply of Elastophene Sanded, Elastophene 180 Sanded, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 PS*, Sopralene (180, 250 or 350) PS*, or Sopralene (180, 250 or 350) Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base membrane.

*Requires heat welded cap membrane.

Membrane: Elastophene SP*, Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, SopraStar Flam Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, or Sopralast 50 TV Alu, heat welded
Or
Elastophene Sanded*, Elastophene 180 Sanded*, Sopralene (180, 250, 350) Sanded*, Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base or ply membrane.

*Requires approved Surfacing.

Surfacing: Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Deck Type 1: Wood, Non-insulated
Deck Description: 19/32" or greater plywood or wood plank decks
System Type E(2): Base sheet mechanically fastened.

All General and System Limitations apply.

Barrier: (Optional) Rocutex Rocroof, loose laid
Base Sheet: One ply of Soprafix, Soprafix-T or Sopralene Flam 180* or Sopralene Flam 250* fastened to the deck as described below:

*Requires heat welded ply or cap membrane.

Fastening #1: Attach base sheet using Insulfixx or Soprema fasteners with Soprafix 2" Round Barbed Plates spaced 18" o.c. in a 4" wide heat welded or bituminous taped seam.

Fastening #2: Attach base sheet using Insulfixx or Isofast fasteners and Insulfixx or Isofast plates spaced 24" o.c. in the center of the sheet. Laps are heat fused. Fastener rows are stripped in with a 7" wide section of torch applied base sheet membrane.

Ply Sheet: (Optional) One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded

*Requires heat welded cap membrane.

Membrane: Elastophene SP*, Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, SopraStar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, or Sopralast 50 TV Alu, heat welded

Or

Colphene FR GR, Colphene GR, Colphene HR FR GR or SopraStar Stick self adhered to sand surfaced base or ply membrane.

Surfacing: Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Deck Type 1I: Wood, Insulated
Deck Description: Min. 19/32" plywood or wood plank
System Type E(3): Base sheet mechanically fastened.
Deck: Decking is attached to spans spaced maximum 24" o.c. with #10 wood screws spaced maximum 6" o.c.

All General and System Limitations apply.

Primer: Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer

Base Sheet: One ply of Soprafix, Soprafix (X)*, Soprafix-e, fastened to the deck as described below:

*Requires heat welded ply or cap membrane.

Fastening #1: Attach base sheet using Soprafix Polymer Batten Strip (PBB), Metal Batten Strip (MBB or MBB-R) with Soprema #15-EL fasteners spaced 6" o.c. in the minimum 5" wide lap.

Ply Sheet: (Optional)

Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.

*Requires heat welded cap membrane.

Membrane: Soprastar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, heat welded.

Or

Soprastar Stick, self-adhered to Elastocol 600c primed sand surfaced base or ply membrane

Surfacing: Surfacing is Optional on granular surfaced field cap membranes.

Surfacing is Required for smooth or sanded surfaced field cap membranes.

Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications

Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

Maximum Design Pressure: -52.5 psf (with Soprastar Flam or Soprastar Stick as cap membrane)
(See General Limitation #7)

-90.0 psf (with all other cap membranes) (See General Limitation #7)



WOOD DECK SYSTEM LIMITATIONS:

1. A slip sheet is required with Ply 4 and Ply 6 when used as a mechanically fastened base or anchor sheet.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
- 10 All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 07-1217.08
Expiration Date: 03/01/11
Approval Date: 05/08/08
Page 39 of 39