



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Soprema, Inc.
310 Quadral Drive
Wadsworth, OH 44281**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCCO reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Soprema Modified Bitumen Roofing Systems Over Lightweight Insulating Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 07-0416.04 and consists of pages 1 through 44.
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 07-1217.10
Expiration Date: 02/22/11
Approval Date: 04/24/08
Page 1 of 44**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Modified Bitumen
Material: SBS
Deck Type: Lightweight Insulating Concrete
Maximum Design Pressure -262.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:
TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Sopra-G	39" x 108' (3.5 sq.)	ASTM D 4601	Fiberglass reinforced oxidized asphalt base sheet for bonding or mechanically attaching to substrate.
Modified Sopra-G	39" x 108' (3.5 sq.)	ASTM D 4601	Fiberglass reinforced modified asphalt base sheet for bonding or mechanically attaching to substrate.
Sopraglass M	39" x 66' (2 sq.)	ASTM D 5147	Fiberglass reinforced modified bitumen base sheet. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopraglass M GR	39" x 33' (1 sq.)	ASTM D5147	Fiberglass reinforced modified bitumen base sheet with a mineral granular top surface. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopra ESHAvent	39" x 49' (1.5 sq.)	ASTM D 1970	Fiberglass reinforced modified bitumen membrane with self-adhering round areas on back side and a sanded top side.
Sopraglass 40	39" x 82' (2.5 sq.)	ASTM D 4601 Type I	Fiberglass reinforced oxidized asphalt base sheet for bonding, mechanically attaching or ribbon stripping to substrate.
Sopraglass 100	39" x 66' (2 sq.)	ASTM D 4601	Fiberglass reinforced oxidized asphalt base sheet for bonding or mechanically attaching to substrate.
Soprabase	39" x 99' (3 sq.)	ASTM D 6164	Oxidized asphalt, polyester reinforced base sheets. Primarily used as a mechanically attached anchor sheet. Applied in hot asphalt, cold adhesive or ribbon stripped.
Sopra IV or VI	36" x 180' (5 sq.)	ASTM D 2178 Type IV or VI	Type IV or VI, fiberglass reinforced, smooth surfaced ply sheet. Sopra IV or VI are used in multi-ply systems and complies with ASTM and UL Standards. Applied in hot asphalt or cold adhesive.
Colvent TG	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass reinforced, modified bitumen membrane with 1" wide factory applied heat weldable strips on back side.



NOA No.: 07-1217.10
 Expiration Date: 02/22/11
 Approval Date: 04/24/08
 Page 2 of 44

Colvent SA	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass reinforced, modified bitumen membrane with 1" wide factory applied self-adhering strips on back side
Colvent 180 TG	39" x 33' (1 sq.)	ASTM D 6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied heat weld strips on back side.
Colvent 180 SA	39" x 43' (1 sq.)	ASTM D6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied self-adhering strips on back side
Colvent 180 TG GR	39" x 33' (1 sq.)	ASTM D 6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied heat weld strips on back side, and a mineral granular top surface.
Colvent 180 SA GR	39" x 33' (1 sq.)	ASTM D6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied self-adhering strips on back side and a mineral granular top surface.
Elastophene Sanded	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane sanded on both sides, used as a base and top ply. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene Sanded 3.0	39" x 33' (1sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane sanded on both sides, used as a base and top ply. Applied in hot asphalt, cold adhesive or ribbon stripped.
Elastophene HD	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane sanded on both sides, used as a base and top ply. Applied in hot asphalt, cold adhesive or ribbon stripped.
Elastophene HS FR	39" x 66' (2 sq.)	ASTM D 6162	Woven fiberglass/polyester composite reinforced modified bitumen membrane with fire retardants and sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene Sanded FR	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants and sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene HR	39" x 49' (1.5 sq.)	ASTM D 5147	Fiberglass scrim reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene HR FR	39" x 49' (1.5 sq.)	ASTM D 5147	Fiberglass scrim reinforced modified bitumen membrane with fire retardants and sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene HP	39" x 66' (2 sq.)	ASTM D 5147	Fiberglass/non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.



Elastophene PS, Elastophene PS 3.0	39" x 49' (1.5 sq.)	ASTM D 6163	Glass reinforced modified bitumen membrane with a plastic burn-off film for heat weld bonding to the top side. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene SP 2.2mm	39" x 49' (1.5 sq.)	ASTM D 6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied b heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene SP 3.0mm	39" x 49' (1 sq.)	ASTM D 6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied b heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene Flam	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane covered on both sides with a plastic burn-off film. Applied by heat welding.
Elastophene Flam 2.2	39" x 49' (1.5 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane covered on both sides with a plastic burn-off film. Applied by heat welding.
Elastophene Flam HS FR	39" x 33' (1 sq.)	ASTM D6162	Woven fiberglass/polyester composite reinforced modified bitumen membrane with fire retardants and plastic burn-off film on both sides. Applied by heat welding.
Elastophene Flam HP	39" x 66' (2 sq.)	ASTM D 5147	Fiberglass/non-woven polyester reinforced modified bitumen membrane with plastic burn-off film on both sides. Applied by heat welding.
Elastophene 180 Sanded	39" x 49' (1.5 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene 180 PS	39" x 49' (1.5 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and a plastic burn-off film on the top, used as a base sheet. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene GR, Elastophene LS FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene FR GR or FR+ GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.



Elastophene HR FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass scrim reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene HS FR GR	39" x 33' (1 sq.)	ASTM D 6162	Woven fiberglass/polyester composite reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene HP FR GR	39" x 33' (1 sq.)	ASTM D 5147	Fiberglass/non-woven polyester reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene Flam GR, Elastophene Flam LS FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam FR GR or FR+ GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam HR FR GR	39" x 33' (1 sq.)	ASTM D 6163	Fiberglass scrim reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene Flam HS FR GR	39" x 33' (1 sq.)	ASTM D 6162	Woven fiberglass composite reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene Flam HP FR GR	39" x 33' (1 sq.)	ASTM D 5147	Fiberglass/non-woven polyester reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180, 250 or 350	39" x 33' (1 sq.) 39" x 26' (¾ sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides, used as a base/ply/cap. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopralene 180 SP 3.5 mm	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).



Soprafix [S], [H], [F] and [X]	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
Soprafix	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with a 4-inch or 5-inch wide side lap with a plastic burn-off film on the bottom and sanded on the top. Applied by mechanical attachment. Lap heat welded or sealed with an approved cold adhesive.
Soprafix-e	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with a 5-inch wide side lap with a self-adhering compound and release film and sanded on the bottom and top surfaces. Applied by mechanical attachment. Lap self-adhered or sealed with approved cold adhesive.
Soprafix (X)	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with plastic burn-off film or sanded on the top and bottom surfaces and a 6-inch wide side lap. Applied by heat welding.
Sopralene Flam 180, 250 or 350	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced SBS modified bitumen membrane, both sides covered with a plastic burn-off film, used as a base/ply. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180, 250 or 350 GR or FR GR	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180, 250 or 350 GR	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180, 250 or 350 FR GR or FR+ GR	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 2.7 mm	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).



Sopralast	various	ASTM D 6298	Fiberglass reinforced modified bitumen sheeting faced with aluminum, copper or stainless steel foil. Applied by heat welding of ribbon stripping (after removal of plastic burn-off film).
Soprastar Flam	39" x 33' (1 sq)	ASTM D6163	Fiberglass reinforced SBS modified bitumen membrane with a plastic burn-off film on the bottom side and a reflective white top surface. Applied by heat welding.
Soprastar Stick	39" x 33' (1 sq)	ASTM D6163	Fiberglass reinforced SBS modified bitumen membrane with a release film covered self-adhering bottom side and a reflective white top surface.
UNILAY	39" x 33' (1 sq.)	ASTM D 6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants and surfaced with mineral granules. Applied by mechanical attachment, heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Stick	39" x 33' (1 sq.)	ASTM D 6164	Self adhered, polyester reinforced membrane with a release film on the bottom and a sanded top.
Sopralene Flam Stick	39" x 33' (1 sq.)	ASTM D 6164	Self adhered, polyester reinforced membrane with a release film on the bottom and a plastic burn-off film on the top.
EPS Flam Stick	39" x 33' (1 sq.)	ASTM D 6163	Self adhered, film surfaced, glass mat/glass grid reinforced membrane with a release film on the bottom and a plastic burn-off film on the top.
Colphene 1500	39" x 33' (1 sq.) 39" x 132' (4 sq.) 39" x 66' (2.1 sq.)	ASTM D 1970	Self adhered, non-reinforced membranes used as a vapor retarder.
Colphene FR GR, Colphene GR	39" x 33' (1 sq.)	ASTM D 6163	Self adhered, granule surfaced, fiberglass reinforced membranes.
Colphene HR FR GR	39" x 33' (1 sq.)	ASTM D 6163	Self adhered, granule surfaced, fiberglass scrim reinforced membranes.
Lastobond S	39" x 49' (11.5 sq.)	ASTM D 1970	Self-adhered underlayment membrane.
Lastobond Shield	various	ASTM D 1970	Self-adhering underlayment membrane.
Lastobond Shield HT	various	ASTM D 1970	Self-adhering underlayment membrane.
Lastobond Shield-R	various	ASTM D 1970	Self-adhering underlayment membrane.
Lastobond Shield-HT RW	various	ASTM D 1970	Self-adhering underlayment membrane.
Sopratape 606	5" wide		Bituminous tape for sealing of side and head laps.
Sopramastic 200	17 oz. pouch or 10.4 oz cartridge		Caulking compound.
Elastocol 400, 500 and 600c	various	ASTM D 41	Asphalt primers.



Sopracolle "E"	keg		Cold-applied adhesive used to bond membrane to prepared substrates or to other membranes. One part polyurethane/bitumen resin, moisture cure compound.
ALSAN Flashing™	1.25 gallon pail or 3.75 gallon pail		
ALSAN Polyfleece	4", 8" or 39" wide by 50' long		Non-woven polyester reinforcement used in the ALSAN Flashing system.
SBS Mastic	10.4 oz tube		Plasticized rubber/bitumen mastic compound.
SBS Elastic Cement	5 gallon pail		Elastomeric bitumen based mastic compound.
Soprawalk	39" x 26' (3/4 sq)		Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and mineral granules on the top. Applied by hot asphalt, cold adhesive or ribbon stripping.
High Velocity® Insulation Adhesive II (HVIA-II)	3 gal pail	Proprietary	One part elastomeric urethane foam adhesive.
High Velocity® Insulation Adhesive III (HVIA-III)	4 dual cartridges per carton	Proprietary	Two part elastomeric urethane foam adhesive.
FM Adhesive	5 gallon pail, 55 gallon drum or 350 gallon tote	Proprietary	Plastomeric bitumen based cold adhesive.
FM Adhesive Trowel Grade	5 gallon pail	Proprietary	Plastomeric bitumen based cold adhesive.
FM Adhesive (VOC)	5 gallon pail, 55 gallon drum or 350 gallon tote	Proprietary	Elastomeric bitumen based cold adhesive.
FM Adhesive (VOC) Trowel Grade	5 gallon pail	Proprietary	Elastomeric bitumen based cold adhesive.
High Velocity® Membrane Adhesive (HVMA)	5 gallon pail or 55 gallon drum	Proprietary	Polyurethane bitumen adhesive.
Sopraboard	various		Mineral fortified Asphaltic cored coverboard between two layers of asphalt saturated fiberglass mat.
Granules	5 gallon pail or Supersac		Semi-ceramic coated colored granules.



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
Apache Pyrox, Apache White Line, Apache Pyrox PSI-25, Apache White Line PSI-25	Polyisocyanurate foam insulation	Apache Products Company
Apache Millox, Apache Millox-P ACFoam II, ACFoam III	Composite polyisocyanurate insulation Polyisocyanurate foam insulation	Apache Products Company Atlas Energy Products
ACFoam Composite	Composite polyisocyanurate insulation board	Atlas Energy Products
FlintBoard ISO, FlintBoard ISO Cold FlintBoard ISO Plus	Polyisocyanurate foam insulation Composite polyisocyanurate insulation board	CertainTeed Corp. CertainTeed Corp.
Hytherm AP	Polyisocyanurate foam insulation	Dow
Hytherm Composite	Composite polyisocyanurate insulation	Dow
ISO 95+, ISO 95+ (25psi)	Polyisocyanurate foam insulation	Firestone
ISO 95+ Composite	Composite polyisocyanurate insulation board	Firestone
EnergyGuard ISO, EnergyGuard Ultra	Polyisocyanurate foam insulation	GAF
EnergyGuard Composite	Composite polyisocyanurate insulation board	GAF
Extruded or Expanded Polystyrene Gypsum	Polystyrene Insulation Gypsum board	generic generic
High Density Wood Fiberboard	Wood fiber insulation board	generic
Perlite Insulation	Perlite insulation board	generic
DensDeck, DensDeck Prime, DensDeck Fireguard, DensDeck Prime Fireguard, DensDeck DuraGuard	Water resistant gypsum board	G-P Gypsum Corp.
H-Shield	Polyisocyanurate foam insulation	Hunter Panels, Inc.
H-Shield CG	Polyisocyanurate foam insulation	Hunter Panels, Inc.
H-Shield-P, H-Shield-WF	Composite Insulation board	Hunter Panels, Inc.
ENRGY-2	Polyisocyanurate foam insulation	Johns Manville
ENRGY-2 Plus, Composite, Fesco Foam	Composite Insulation board	Johns Manville
ENRGY-3	Polyisocyanurate foam insulation	Johns Manville
ENRGY-3 Plus	Composite Insulation board	Johns Manville
Multi-Max FA	Polyisocyanurate foam insulation	RMax
Thermarroof Composite	Composite Insulation board	RMax
UltraMax	Polyisocyanurate foam insulation	RMax
Multi-Max FA-3	Polyisocyanurate foam insulation	RMax
Thermarroof Composite-3	Composite insulation board	RMax
Securock	Gypsum board	US Gypsum



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Tri-Fix Fastening System	Fastening system for base sheet attachment to lightweight concrete, gypsum or cementitious wood fiber decks.	3" diameter plate with various length fasteners	Soprema, Inc.
2.	#12, #14 & #15 Soprema Fasteners	Fasteners for membrane or insulation attachment to wood, steel or concrete decks.		Soprema, Inc.
3.	Soprafix [X]-EL #15	Fasteners for membrane attachment to steel or concrete decks.		Soprema, Inc.
4.	Soprafix Plates	AZ-55 Galvalume steel plate for use with the Soprafix system.	2" diameter	Soprema, Inc.
5.	Soprema Plates	Metal or plastic stress plates for use with Soprema Fasteners.	3" diameter	Soprema, Inc.
6.	Sopradisc	Galvanized metal bearing plate used for side lap attachment of Soprafix system.	2" diameter	Soprema, Inc.
7.	Soprema Isofast IF/IFT	AZ-50 Galvalume steel plate for use with the Soprafast System.	2¾" diameter	Soprema, Inc.
8.	Soprafix/Soprafast	Stress plates for membrane securement.	3" diameter	Soprema, Inc.
9.	UNILAY Plate	Stress plates for Unilay membrane securement.	2-3/8" diameter	Soprema, Inc.
10.	#12, #14 & #15 Dekfast Fastener	Insulation fastener		SFS Intec
11.	Omega Fastener	Stainless steel insulation fastener		SFS Intec
12.	Dekfast Hex Plate	Galvalume AZ50 steel plate	2 7/8" x 3 1/4"	SFS Intec
13.	Dekfast Lock Plate	Polypropylene locking plate.	3" x 3 1/4"	SFS Intec
14.	Twin Loc-Nails	Base ply fastening systems for lightweight concrete, gypsum or cementitious wood fiber decks		ES Products, Inc.
15.	FM-30, FM-45, FM-60, FM-90 Fasteners	Base ply fastening systems for lightweight concrete decks		ES Products, Inc.
16.	#12, #14 & #15 OMG Fasteners	Insulation fastener for wood, steel and concrete.		OMG, Inc.
17.	#12 OMG Fastener	Insulation fastener for wood, steel and concrete.		OMG, Inc.
18.	OMG AccuTrac Plate	Galvalume square stress plate	3" square	OMG, Inc



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
19.	OMG 3" Standard Steel Plate	Galvalume stress plate.	3" round 3" square	OMG, Inc.
20.	Olympic CR Base Ply Fasteners	Base ply fastening assembly		OMG, Inc.
21.	NTB Magnum	Glass reinforced Nylon insulation fastener for gypsum & CWF decks with barbs.		OMG, Inc.
22.	NTB Plate	Galvalume stress plate	3" round	OMG, Inc.
23.	Lite-Deck	Insulation fastener for CWF and Gypsum decks.		OMG, Inc.
24.	Lite-Deck Plate	Galvalume stress plate	3" round	OMG, Inc.
25.	Olympic Fastener #12, #14 & #15	Insulation fastener.		OMG, Inc.
26.	Olympic CD-10	Insulation fastener.		OMG, Inc.
27.	Olympic Fluted Nail	Insulation fastener.		OMG, Inc.
28.	Olympic Standard	Galvalume AZ50 steel plate	3" round	OMG, Inc.
29.	Olympic Plastic	Polypropylene stress plate	3.25" round	OMG, Inc.
30.	Powerlite	Insulation fastener.		Powers Fasteners, Inc.
31.	Powerlite	Galvalume stress plate.	3" round	Powers Fasteners, Inc.
32.	Base-Lok Fasteners	Base sheet fastener for lightweight concrete, cwf and gypsum decks	1.75" long with 3" dia. head	Simplex Nails
33.	Turbo Tube-Lok Fasteners	Base sheet fastener for lightweight concrete, cwf and gypsum decks	1.75" long with 2" dia. head	Simplex Nails
34.	SFS Base-Lok Fasteners	Base sheet fastener for lightweight concrete, cwf and gypsum decks	1.75" long with 3" dia. head	SFS Intec, Inc.
35.	Insul-Fixx Fastener	Insulation fastener for wood, steel and concrete.		SFS Intec, Inc.
36.	Isofast Fasteners	Insulation fastener for wood, steel and concrete.		SFS Intec, Inc.
37.	Extra Load Fasteners #15	Fasteners for membrane attachment to steel or concrete decks.		SFS Intec, Inc.
38.	Insul-Fixx S Plate	Galvalume AZ50 steel plate	3" round	SFS Intec, Inc.
39.	Insul-Fixx P Plate	Polyethylene stress plate	3" round	SFS Intec, Inc.
40.	Isofast Plate	Square or oblong galvalume steel plates for use with Isofast fasteners		SFS Intec, Inc.



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
41.	ES-I Fastening Systems	Insulation fastening assembly with plate.	3" round	SFS Intec, Inc.
42.	#12, #14 & #15 Dekfast Fastener	Insulation fastener		SFS Intec
43.	Omega Fastener	Stainless steel insulation fastener		SFS Intec
44.	Dekfast Hex Plate	Galvalume AZ50 steel plate	2 7/8" x 3 1/4"	SFS Intec
45.	DekFlat Lock Plate	Polypropylene locking plate.	3" x 3 1/4"	SFS Intec
46.	Tru-Fast TL Fastener	Insulation fastener for lightweight concrete, CWF and gypsum decks		The Tru-Fast Corp.
47.	Tru-Fast Fastener	Insulation fastener for wood, steel and concrete.		The Tru-Fast Corp.
48.	Tru-Fast HD or EHD	Insulation fastener for wood, steel and concrete.		The Tru-Fast Corp.
49.	Tru-Fast MP-3	Galvalume AZ50 steel plate	3" round	The Tru-Fast Corp.
50.	Tru-Fast Metal	Galvalume AZ55 steel plate	3" round	The Tru-Fast Corp.
51.	Tru-Fast Plastic	Polypropylene plate	3" round	The Tru-Fast Corp.
52.	ES Products Batten Bar-TL	Batten bar		ES Products, Inc.
53.	#12 OMG Fastener	Insulation fastener		OMG, Inc.
54.	OMG Polymer Batten Strip	Modified polymer batten bar		OMG, Inc.
55.	OMG MAXLoad	Insulation fastener		OMG, Inc.
56.	Olympic Heavy Duty	Insulation fastener		OMG, Inc.
57.	Olympic ASAP 3P	Pre-assembled insulation fastener and plastic plate	3" round	OMG, Inc.
58.	Olympic ASAP 3S	Pre-assembled insulation fastener and steel plate	3" round	OMG, Inc.
59.	Isofast IF2	Insulation fastener		SFS Intec
60.	Isofast IF/IG	Galvalume AZ50 steel plate	82 x 40 mm	SFS Intec
61.	Isofast IFC/IW	Galvalume AZ50 steel plate	70 x70 mm	SFS Intec
62.	#15 Dekfast HS	Insulation fastener		SFS Intec
63.	Galvalume Steel 3" Round Insulation Plate	Galvalume AZ50 steel plate	3" round	SFS Intec
64.	K-Fast Fastener	Insulation Fastener		SFS Intec



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
65.	Dekfast Steel Batten Bar	Galvalume AZ50 steel		SFS Intec
66.	Dekfast Coiled Batten Strip	Batten bar		SFS Intec
67.	Soprafix #14 PAS-2" SB Stress Plate	Pre-assembled plate and fastener	2" diameter	Soprema, Inc.
68.	Soprema 3" Insulation Plate	Stress plate	3" diameter	Soprema, Inc.
69.	Soprafix 2" – SB Stress Plate	Stress plate	2" diameter	Soprema, Inc.
70.	Soprafix 2-3/8" – SB Stress Plate	Stress plate	2-3/8" diameter	Soprema, Inc.
71.	Soprafix (X) 2-3/4" Stress Plate	Stress plate	2-3/4" diameter	Soprema, Inc.
72.	Soprafix MBB-R	Metal Batten Bar		Soprema, Inc.
73.	Soprema #12, #14, #15 Fastener	Insulation and membrane fasteners		Soprema, Inc.
74.	Soprema PAS #12-3" Insulation Plate	Pre-assembled plate and fastener	3" diameter	Soprema, Inc.
75.	Soprafix #21-K Fastener	Insulation and membrane fastener		Soprema, Inc.
76.	Tru-Fast DP	Insulation fastener for wood, steel and concrete		The Tru-Fast Corp.
77.	Tru-Fast SHD	Insulation fastener for wood, steel and concrete		The Tru-Fast Corp.
78.	Tru-Fast MPH-3	Galvalume AZ50 steel plate	3" round	The Tru-Fast Corp.
79.	Tru-Fast MP-2000			The Tru-Fast Corp.
80.	Tru-Fast MPB-2000			The Tru-Fast Corp.
81.	Tru-Fast MPB-2400			The Tru-Fast Corp.
82.	Tru-Fast BB-18 Batten Bar	Galvalume AZ55 steel batten bar		The Tru-Fast Corp.
83.	Tru-Fast BB-18-R Batten Bar	Galvalume AZ55 steel batten bar with recessed holes		The Tru-Fast Corp.
84.	Tru-Fast Twin-Loc Batten Bar	Batten bar		The Tru-Fast Corp.



APPROVED SURFACING/COATING OPTIONS:

TABLE 4

System Number	Manufacturer	Application
1.	Generic	Gravel applied at 400 lbs/sq., adhered with flood coat of asphalt at 60 lbs/sq.
2.	Generic	Slag applied at 300 lbs/sq., adhered with flood coat of asphalt at 60 lbs/sq.
3.	Soprema	Gravel applied at 400 lbs/sq., adhered with FM Adhesive or FM Adhesive (VOC) at 4 gal/sq.
4.	Karnak Corporation	Karnak #97 Fibrated Aluminum Roof Coating applied at an application rate of 1.5 gal/sq.
5.	Soprema	Cural Aluminizer applied at an application rate of 2 gal/sq.
6.	Thermo Manufacturing Systems, LLC	Super Prep Roof Coating applied in two coats at an application rate of 1.5 gal/sq/coat.
7.	United Coatings Manufacturing Company	Roof Mate Coating, applied in one base coat at a rate of 1.5 gal/sq, and one finish coat at a rate of 1.5 gal/sq.
8.	Insulating Coatings Corporation	Astec 2000 Finish Coat applied in two base coats at a rate of 0.75 gal/sq/coat and two finish coats at a rate of 0.75 gal/sq/coat.
9.	Henry Company	HE280DC White Elastomeric Roof Coating applied in two coats at an application rate of 1 gal/sq/coat.
10.	National Coating	Acryshield® A500 applied in two coats at an application rate of 1 gal/sq/coat.



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Atlantic & Caribbean Roof Consulting, LLC	ACRC03008	Wind Uplift	07.11.03
Factory Mutual Research Corporation	J.I. 0PA2.AM	Wind Uplift Classification	11.29.89
	J.I. 2P2A7.AM	Wind Uplift Classification	11.29.89
	J.I. 1W8A1.AM	Wind Uplift Classification	07.15.93
	J.I. 1Z3A6.AM	Wind Uplift Classification	04.27.95
	J.I. 152A1.AM	Wind Uplift Classification	11.28.84
	J.I. 2D0A0.AM	Wind Uplift Classification	08.15.97
	J.I. 3001334	Wind Uplift Classification	01.25.00
	J.I. 3009814	Class 4470	09.06.02
	J.I. 3002351	Wind Uplift Classification	
	3014614	FM 4470	02.27.06
	3025860	FM 4470	04.17.06
	3026028	FM 4470	05.25.06
	3023749	FM 4470	09.28.06
	3029098	FM 4470	10.25.07
Dynatech Engineering Corp.	10.94.27	Wind Uplift	10.27.94
	2491-04.95	Wind Uplift	01.04.95
Exterior Research & Design, LLC.	2003.02.97-1	Wind Uplift	02.15.97
	2003-2.04.97-1	Wind Uplift	04.15.97
	2002.07.97-1	Wind Uplift	08.15.97
	2716.05.98-1	Wind Uplift	05.11.98
	2738.10.00-1	Wind Uplift	10.20.02
	2109.08.02	Wind Uplift	08.06.02
	2766.12.03	Wind Uplift	12.01.03
	2760.12.04-R1	Wind Uplift	12.23.04
	S6740.11.07	Physical Properties	11.02.07
ITS / Warnock Hersey		ASTM D 5147 Physical Property Testing	05.27.93
IRT of S. Florida, Inc.	990028	TAS 114	09.30.99
	02-031	Wind Uplift	09.06.02
IRT-Arcon, Inc.	IRT06002	TAS 114-J	02.18.06
	IRT06056	TAS 114-J	09.21.06



APPROVED ASSEMBLIES:

- Deck Type 4I:** Lightweight Concrete, Insulated
- Deck Description:** Cellular or Aggregate Lightweight Concrete, 300 psi. min
- System Type A:** Anchor sheet mechanically fastened; one or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
AC Foam II, AC Foam III, ENRGY-2, ENRGY-3, PSI-25, H-Shield Minimum 1.4" thick	N/A	N/A
Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Toprox Minimum 1" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
BP High Strength, FM-90 Traffic Top/High Density, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek Minimum 1/2" thick	N/A	N/A
GAFTEMP Permalite, Fesco Board Minimum 3/4" thick	N/A	N/A
DensDeck Minimum 1/4" thick	N/A	N/A
Fireguard, Type X gypsum Minimum 5/8" thick	N/A	N/A

Note: Apply optional top layer of insulation shall be adhered with approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

- Anchor Sheet:** One ply of Sopra-G, Modified Sopra-G, Sopraglass 100, Sopravent, Sopra 4897, Soprabase, GAFGLAS #75 or GAFGLAS Stratavent fastened to the deck as described below:
- Fastening #1:** Attach anchor sheet using Olympic CR Base Ply Fasteners or ES FM-90 spaced 7" o.c. in a 4" lap and 7" o.c. in two staggered rows in the center of the sheet.
(Maximum Design Pressure -52.5 psf - See General Limitation #7.)
- Fastening #2:** Attach anchor sheet using Simplex or SFS Stadler Base-Lok fasteners spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.
(Maximum Design Pressure -52.5 psf - See General Limitation #7.)
- Fastening #3:** Attach anchor sheet using Simplex Turbo Tube-Lok fasteners spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.
(Maximum Design Pressure -45 psf - See General Limitation #9.)



- Base Sheet:** (Optional) One or more plies of Sopra-G, Modified Sopra-G, Sopraglass 100, Sopra-IV, Sopra-VI, Soprabase, GAFGLAS #75 JM GlasBase, JM GlasPly IV or GlasPly Premier adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Ply Sheet:** (Optional, required if no base sheet used) One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded
- Or
- One ply of Elastophene Sanded, Elastophene FR, Elastophene 180 Sanded, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 PS*, Sopralene (180, 250 or 350) PS*, or Sopralene (180, 250 or 350) Sanded or one or more plies of ASTM D 2178 Type IV or VI ply sheets, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- *Requires heat welded cap membrane.
- Membrane:** Elastophene SP 2.2mm*, Elastophene SP 3.0mm*, Elastophene Flam GR, Elastophene Flam FR GR, FR+GR, Elastophene Flam LS FR GR, Soprastar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, FR+GR or Sopralast 50 TV Alu heat welded
- Or
- Elastophene Sanded*, Elastophene FR*, Elastophene 180 Sanded*, Sopralene (180, 250, 350) Sanded*, Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced ply membrane.
- *Requires approved Surfacing.
- Surfacing:** **Surfacing is Optional on granular surfaced field cap membranes.**
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system
- Maximum Design Pressure:** See Fastening Requirements above



Deck Type 4: Lightweight Concrete, Non-Insulated
Deck Description: Celcore Cellular Lightweight Insulating Concrete, Min. 200 psi
System Type C: All layers of insulation simultaneously attached.

All General and System Limitations apply.

Deck: Minimum 22 ga. type BW36-22 slotted steel decking attached to supports spaced 5' o.c. maximum using 5/8" puddle welds (every bottom flute). Steel deck side laps are attached with three Traxx 1 #10 evenly spaced between supports. Or structural concrete deck.

Insulation: Min. 1/8" thick Sopraboard, mechanically attached with Soprema #15 HL Fasteners at a rate of one fastener per 1.33 ft².

**Primer:
(Optional)** Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer

Base Sheet: One layer of Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, Colvent TG, Colvent 180 TG, heat welded

Or

One layer of Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS*, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 25 lbs./sq.

*Requires heat welded ply or cap membrane.

**Ply Sheet:
(Optional)** Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded

Or

Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS*, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 25 lbs./sq.

*Requires heat welded cap membrane.



Membrane:

One layer of Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Sopralene 180 SP 3.5mm*, Soprafix*, SopraStar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

One layer of Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR UW GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 25 lbs./sq. to sand surfaced base or ply membrane.

*Requires approved Surfacing.

Surfacing:

Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure:

-82.5 psf (See General Limitation #7.)



Deck Type 4: Lightweight Concrete, Non-Insulated
Deck Description: Cellular or Aggregate Lightweight Concrete, 250 psi. min.
System Type E(1): Base sheet mechanically fastened.

All General and System Limitations apply.

Base Sheet: One ply of Sopra-G, Modified Sopra-G, Sopraglass 100, Sopravent, Sopra 4897, Soprabase, GAFGLAS #75 or GAFGLAS Stratavent fastened to the deck as described below:

Fastening #1: Attach anchor sheet using Olympic CR Base Ply Fasteners or ES FM-90 spaced 7" o.c. in a 4" lap and 7" o.c. in two staggered rows in the center of the sheet.

(Maximum Design Pressure –52.5 psf – See General Limitation #7.)

Fastening #2: Attach anchor sheet using Simplex or SFS Stadler Base-Lok fasteners spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

(Maximum Design Pressure –52.5 psf – See General Limitation #7.)

Fastening #3: Attach anchor sheet using Simplex Turbo Tube-Lok fasteners spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

(Maximum Design Pressure –45 psf – See General Limitation #9.)

Ply Sheet: One ply of Elastophene Sanded, Elastophene FR, Elastophene 180 Sanded, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 PS*, Sopralene (180, 250 or 350) PS*, or Sopralene (180, 250 or 350) Sanded one or more plies of ASTM D 2178 Type IV or VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base membrane.

*Requires heat welded cap membrane.

Membrane: Elastophene SP 2.2mm*, Elastophene SP 3.0mm*, Elastophene Flam GR, Elastophene Flam FR GR, FR+GR, Elastophene Flam LS FR GR, Soprastar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, FR+GR, or Sopralast 50 TV Alu, heat welded

Or

Elastophene Sanded*, Elastophene FR*, Elastophene 180 Sanded*, Sopralene (180, 250, 350) Sanded*, Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced ply membrane.

*Requires approved Surfacing.

Surfacing: Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure:

See Fastening Requirements above



Deck Type 4: Lightweight Concrete, Non-Insulated
Deck Description: Cellular Concrete, LLC. Lightweight Insulating Concrete, 300 psi. min
System Type E(2): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: Minimum 22 ga., type BV steel decking attached to support spaced at 5' o.c. maximum using 3/8" puddle welds with washer (every bottom flute). Steel deck side laps are attached three Traxx 1 #10 evenly spaced between supports or structural concrete deck.

Base Sheet: One ply of Soprafix, Soprafix-e, Soprafix [S]*, Soprafix [F]*, Soprafix [X]* or Soprafix [H] fastened to the deck as described below:

Note: Soprafix [H] is for use with a self-adhered cap membrane.

*Requires heat welded cap membrane.

Fastening #1: Attach base sheet using Tri-Fixx Fasteners spaced 9" o.c. in a 5" lap. The side lap fastener row is encapsulated in the heat welded lap.

(Maximum Design Pressure –45 psf – See General Limitation #7.)

Fastening #2: Attach base sheet using Tri-Fixx Fasteners spaced 8" o.c. in a 5" lap and 8" o.c. in one center rows. The side lap fastener row is encapsulated in the heat welded lap and the center row is stripped-in with a 8" wide strip of torch applied membrane.

(Maximum Design Pressure –75 psf – See General Limitation #7.)

Ply Sheet: (Optional)

One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded.

*Requires heat welded cap membrane.

Membrane: Elastophene SP 2.2mm*, Elastophene SP 3.0mm*, Elastophene Flam GR, Elastophene Flam FR GR, FR+GR, Elastophene Flam LS FR GR, SopraStar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, FR+GR, or Sopralast 50 TV Alu, heat welded

Or

Colphene FR GR, Colphene GR, Colphene HR FR GR, self adhered to sand surfaced base or ply membrane.

Or

SopraStar Stick, self-adhered to Elastocol 600c primed sand surfaced base or ply membrane

*Requires approved Surfacing.

Surfacing: **Surfacing is Optional on granular surfaced field cap membranes.**
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure:

See Fastening Requirements above



Deck Type 4: Lightweight Concrete, Non-Insulated
Deck Description: Cellular Concrete, LLC. Lightweight Insulating Concrete, 300 psi. min
System Type E(3): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: Lightweight Concrete shall be cast over the following substrate: Minimum 18 ga., type 3N steel decking attached to minimum ½” thick, W14 x 43 purlins with an 8” wide top flange spaced maximum 9 ft. o.c. using ¾” puddle welds or Buildex Traxx 5 fasteners spaced 8” o.c. (every bottom flute). Two welds or screws per attachment point, spaced 4” apart. Steel deck side laps are attached 24” o.c. or Structural Concrete deck.

Base Sheet: One ply of Soprafix [X]* membrane or Sopralene 250 Flam* fastened through the lightweight concrete to the deck using SFS Stadler #15 Extra Load Fasteners HD and 70 mm round plates spaced 16” o.c. in a 5” wide lap and 16” o.c. in one center row. The side lap fastener row is encapsulated in the torched/heat fused lap and the center row is stripped-in with and 8” wide strip of heat welded membrane.
*Requires heat welded ply or cap membrane.

Ply Sheet: (Optional)
One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded.
*Requires heat welded cap membrane.

Membrane: Elastophene SP 2.2mm*, Elastophene SP 3.0mm*, Elastophene Flam GR, Elastophene Flam FR GR, FR+GR, Elastophene Flam LS FR GR, Soprastar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, FR+GR, or Sopralast 50 TV Alu, heat welded.
*Requires approved Surfacing.

Surfacing: **Surfacing is Optional on granular surfaced field cap membranes.**
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure: -112.5 psf (See General Limitation #7)



- Deck Type 4:** Lightweight Concrete, Non-Insulated
- Deck Description:** Elastizel Range II lightweight Insulating Concrete, 300 psi. min
- System Type E(4):** Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: Structural Concrete deck or Min. 22 ga., Type B steel decking over 1/4" thick steel supports spaced max. 5 ft o.c. attached 6" o.c. using min. 5/8" diameter puddle welds with washers or Traxx/5 fasteners. Deck side laps are attached 15" o.c. using Traxx/1 fasteners. Deck is covered with a Elastizel Range II lightweight concrete pour consisting of a 1/8" slurry coat, minimum 2" thick Holey Board and a minimum 3" thick top coat.

Base Sheet: One ply of Soprafix [S]*, Soprafix [F]*, Soprafix [X]* or Soprafix [H] fastened to the deck as described. Attach base sheet using Tri-Fixx Fasteners spaced 8" o.c. in a 5" lap and 8" o.c. in one center row. The side lap fastener row is encapsulated in the heat welded lap and the center row is stripped-in with a 6" wide strip of heat welded membrane.

Note: Soprafix [H] is for use with a self-adhered cap membrane.

*Requires heat welded ply or cap membrane.

Ply Sheet: **(Optional)** One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded.

*Requires heat welded cap membrane.

Membrane: Elastophene SP 2.2mm*, Elastophene SP 3.0mm*, Elastophene Flam GR, Elastophene Flam FR GR, FR+GR, Elastophene Flam LS FR GR, SopraStar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, FR+GR or Sopralast 50 TV Alu, heat welded

or

Colphene FR GR, Colphene GR or Colphene HR FR GR, self adhered to sand surfaced base or ply membrane.

Or

SopraStar Stick, self-adhered to Elastocol 600c primed sand surfaced base or ply membrane

*Requires approved Surfacing

Surfacing: **Surfacing is Optional on granular surfaced field cap membranes.**
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure: -112.5 psf (See General Limitation #7)



Deck Type 4: Lightweight Concrete, Non-Insulated
Deck Description: Cellular or Aggregate Lightweight Concrete, 300 psi. min.
System Type E(5): Base sheet mechanically fastened.

All General and System Limitations apply.

Base Sheet: One ply of Soprafix [S]*, Soprafix [F]*, Soprafix [X]* or Soprafix [H] fastened to the deck as described. Attach base sheet using Tri-Fixx Fasteners spaced 10" o.c. in a 5" lap. The side lap fastener row is encapsulated in the heat welded lap.

Note: Soprafix [H] is for use with a self-adhered cap membrane.

*Requires heat welded ply or cap membrane.

Ply Sheet: (Optional)

One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded.

*Requires heat welded cap membrane.

Membrane: Elastophene SP 2.2mm*, Elastophene SP 3.0mm*, Elastophene Flam GR, Elastophene Flam FR GR, FR+GR, Elastophene Flam LS FR GR, SopraStar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, FR+GR, or Sopralast 50 TV Alu, torch applied

or

Colphene FR GR, Colphene GR, Colphene HR FR GR or SopraStar Stick, self adhered to sand surfaced base or ply membrane.

*Requires approved Surfacing.

Surfacing: **Surfacing is Optional on granular surfaced field cap membranes.**
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure: -45 psf (See General Limitation #7)



- Deck Type 4:** Lightweight Concrete, Non-Insulated
- Deck Description:** Cellular or Aggregate Lightweight Concrete, 300 psi. min.
- System Type E(6):** Base sheet mechanically fastened.

All General and System Limitations apply.

Base Sheet: One ply of Sopra-G, Soprabase, GAFGLAS #75 or GAFGLAS Stratavent, Flex-I-Glas Base, All Weather/Empire, Parabase Plus or Vapor Chan fastened to the deck as described. Attach base sheet using ES Products Twin Loc-Nails spaced 9" o.c. in a 4" lap and 9" o.c. in two staggered rows in the center of the sheet.

Ply Sheet: (Optional)

One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded.

Or

One ply of Elastophene Sanded, Elastophene FR, Elastophene 180 Sanded, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 PS*, Sopralene (180, 250 or 350) PS*, or Sopralene (180, 250 or 350) Sanded one or more plies of ASTM D 2178 Type IV or VI ply sheets, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base membrane.

*Requires heat welded cap membrane.

Membrane: Elastophene SP 2.2mm*, Elastophene SP 3.0mm*, Elastophene Flam GR, Elastophene Flam FR GR, FR+GR, Elastophene Flam LS FR GR, SopraStar Flam, Sopralene (180, 250, 350) Flam GR, Sopralene (180, 250, 350) Flam FR GR, FR+GR, or Sopralast 50 TV Alu, heat welded

Or

Elastophene Sanded*, Elastophene FR*, Elastophene 180 Sanded*, Sopralene (180, 250, 350) Sanded*, Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base or ply membrane.

*Requires approved Surfacing.

Surfacing: **Surfacing is Optional on granular surfaced field cap membranes.**
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure: -60 psf (See General Limitation #7)



- Deck Type 4:** Lightweight Concrete, Non-Insulated
- Deck Description:** Cellular or Aggregate Lightweight Concrete, 300 psi. min.
- System Type E(7):** Base sheet mechanically fastened.

All General and System Limitations apply.

- Base Sheet:** One ply of Soprabase or Vapor Chan fastened to the deck as described. Attach base sheet using ES Products Twin Loc-nails spaced 9" o.c. in a 4" lap and 9" o.c. in two staggered rows in the center of the sheet.
- Ply Sheet:** One ply of Elastophene Sanded, Elastophene FR, Elastophene 180 Sanded, or Sopralene (180, 250 or 350) Sanded one or more plies of ASTM D 2178 Type IV or VI ply sheets, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base membrane.
- Membrane:** Elastophene Sanded*, Elastophene FR*, Elastophene 180 Sanded*, Sopralene (180, 250, 350) Sanded*, Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Sopralene (180, 250, 350) GR, or Sopralene (180, 250, 350) FR GR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced ply membrane.
*Requires approved Surfacing.
- Surfacing:** **Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system**
- Maximum Design Pressure:** -75 psf (See General Limitation #7)



- Deck Type 4:** Lightweight Concrete, Non-Insulated
- Deck Description:** Elastizell Range II Cellular/Hybrid Lightweight Insulating Concrete
Min. 200 psi, min. 2½” thick top coat
- System Type E(8):** Base sheet mechanically fastened.

All General and System Limitations apply.

- Deck:** Minimum 22 ga. type BW36-22 slotted steel decking attached to supports spaced 5’ o.c. maximum using 5/8” puddle welds (every bottom flute). Steel deck side laps are attached with three Traxx 1 #10 evenly spaced between supports. Or structural concrete deck.
- Primer:
(Optional)** Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer.
- Base Sheet:** One ply GAFGLAS #75, Sopra-G or Modified Sopra-G fastened to the deck as described. Attach base sheet using ES Products FM-90 Assembled Base Ply Fasteners or BSF 1.7 Fasteners spaced 9” o.c. in a 4” lap and 9” o.c. in two staggered rows in the center of the sheet.
- Ply Sheet:** One ply of Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.
- Or
- One ply of Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS* or one to three plies of ASTM D2178 Type IV or VI ply sheet, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq or in FM Adhesive or FM Adhesive (VOC) at 1.5 – 2.0 gallons/square to sand surfaced base membrane.

*Requires heat welded cap membrane.



Membrane:

One layer of Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Sopralene 180 SP 3.5mm*, Soprafix*, Soprastar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

One layer of Elastophene Sanded*, Elastophene FR*, Elastophene 180 Sanded*, Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene FR UW GR, Elastophene LS FR GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq or in FM Adhesive or FM Adhesive (VOC) at 1.5 – 2.0 gallons/square to sand surfaced ply membrane.

*Requires approved Surfacing.

Surfacing:

**Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system**

Maximum Design Pressure:

-52.5 psf (See General Limitation #7.)



- Deck Type 4:** Lightweight Concrete, Non-Insulated
- Deck Description:** Elastizell Range II Cellular Lightweight Insulating Concrete, Min. 200 psi, min. 2½” thick top coat or Cellular Concrete, LLC. (Mearlcrete) Lightweight Insulating Concrete, Min. 250 psi, min. 2” thick top coat
- System Type E(9):** Base sheet mechanically fastened.

All General and System Limitations apply.

- Deck:** Minimum 22 ga. type BW36-22 slotted steel decking attached to supports spaced 5’ o.c. maximum using 5/8” puddle welds (every bottom flute). Steel deck side laps are attached with three Traxx 1 #10 evenly spaced between supports. Or structural concrete deck.
- Primer:
(Optional)** Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer.
- Base Sheet:** One ply GAFGLAS #75, Sopra-G or Modified Sopra-G fastened to the deck as described. Attach base sheet using ES Products FM-90 Assembled Base Ply Fasteners or BSF 1.7 Fasteners spaced 7” o.c. in a 4” lap and 7” o.c. in two staggered rows in the center of the sheet.
- Ply Sheet:** One ply of Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.
- Or
- One ply of Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS* or one to three plies of ASTM D2178 Type IV or VI ply sheet, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq or in FM Adhesive or FM Adhesive (VOC) at 1.5 – 2.0 gallons/square to sand surfaced base membrane.

*Requires heat welded cap membrane.



Membrane:

One layer of Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Sopralene 180 SP 3.5mm*, Soprafix*, SopraStar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

Elastophene Sanded*, Elastophene FR*, Elastophene 180 Sanded*, Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR UW GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq or in FM Adhesive or FM Adhesive (VOC) at 1.5 – 2.0 gallons/square to sand surfaced ply membrane.

*Requires approved Surfacing.

Surfacing:

**Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system**

Maximum Design Pressure:

-45 psf (See General Limitation #7.)



Deck Type 4: Lightweight Concrete, Non-Insulated
Deck Description: Elastizell Range II Cellular Lightweight Insulating Concrete, Min. 200 psi, min. 2½” thick top coat or Cellular Concrete, LLC. (Mearlcrete) Lightweight Insulating Concrete, Min. 250 psi, min. 2” thick top coat

System Type E(10): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: Minimum 22 ga. type BW36-22 slotted steel decking attached to supports spaced 5’ o.c. maximum using 5/8” puddle welds (every bottom flute). Steel deck side laps are attached with three Traxx 1 #10 evenly spaced between supports. Or structural concrete deck.

Primer: Elastocol 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer
(Optional)

Base Sheet: One ply of Soprafix [S]*, Soprafix [F]* or Soprafix [X]*, Soprafix, or Soprafix-e, fastened to the deck as described below.

*Requires heat welded ply membrane.

Fastening #1: Attach base sheet using Tri-Fix Fastening System spaced 9” o.c. in a 5” lap. The side lap fastener row is encapsulated in the heat welded lap.

(Maximum Design Pressure –45 psf – See General Limitation #7.)

Fastening #2: Attach base sheet using Tri-Fix Fastening System spaced 8” o.c. in a 5” lap and 8” o.c. in one center row. The side lap fastener row is encapsulated in the heat welded lap and the center row is stripped-in with a min. 6” wide strip of heat welded membrane.

(Maximum Design Pressure –67.5 psf – See General Limitation #7.)

Ply Sheet: One ply of Elastophene Flam*, Elastophene Flam 2.2*, Sopralene (180, 250 or 350) Flam*, or Sopralene (180, 250 or 350) SP, heat welded

Or

One ply of Elastophene Sanded, Elastophene FR, Elastophene 180 Sanded, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 PS*, Sopralene (180, 250 or 350) PS*, or Sopralene (180, 250 or 350) Sanded or one to three plies of ASTM D2178 Type IV or VI ply sheet, adhered in FM Adhesive or FM Adhesive (VOC) at 1.5 – 2.0 gallons/square to sand surfaced base membrane.

*Requires heat welded cap membrane.



Membrane:

Elastophene SP 2.2mm*, Elastophene SP 3.0mm*, Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam FR UW GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Sopralene 180 SP 3.5mm*, Soprafix*, SopraStar Flam Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

Elastophene Sanded*, Elastophene FR*, Elastophene 180 Sanded*, Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR UW GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR, adhered in FM Adhesive or FM Adhesive (VOC) at 1.5 – 2.0 gallons/square to sand surfaced ply membrane.

*Requires approved surfacing.

Surfacing:

**Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system**

Maximum Design Pressure:

See Fastening Requirements above.



Deck Type 4:	Lightweight Concrete, Non-Insulated
Deck Description:	Elastizell Range II Cellular Lightweight Insulating Concrete, Min. 200 psi, min. 2½" thick top coat or Cellular Concrete, LLC. (Mearlcrete) Lightweight Insulating Concrete, Min. 250 psi, min. 2" thick top coat Celcore Cellular Lightweight Insulating Concrete, Min. 200 psi
System Type E(11):	Base sheet mechanically fastened
All General and System Limitations apply.	
Primer: (Optional)	Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer
Base Layer:	One layer Soprafix, Soprafix (X)*, Sopralene Flam 180* or Sopralene Flam 250*, mechanically attached with Twin-Loc Nails spaced 6" o.c. through OMG Polymer Batten Strip-TL, ES Products Batten Bar-TL, Tru-Fast Twin Loc Batten Bar or Dekfast Coiled Batten Strip, placed in the lap and in one row centered in the field. Center fastener row is covered with an 8" wide strip of Sopralene Flam Stick*, EPS Flam Stick*, Sopralene Stick, self-adhered. Or Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.
Ply Sheet: (Optional)	*Requires heat welded ply or cap membrane. One or more layers of Elastophene Flam HP*, Sopralene Flam 180*, Sopralene Flam 180 2.7mm*, Sopralene Flam 250* or Sopralene Flam 350*, heat welded *Requires heat welded cap membrane.
Membrane:	One layer of SopraStar Flam, Elastophene Flam HP FR GR, Sopralene 180 SP 3.5mm*, Soprafix*, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, heat welded. Or SopraStar Stick, self-adhered to Elastocol 600c primed sand surfaced base or ply membrane. *Requires approved Surfacing.
Surfacing:	Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system
Maximum Design Pressure:	-52.5 psf (with SopraStar Flam or SopraStar Stick as cap membrane) (See General Limitation #7) -82.5 psf (with all other cap membranes) (See General Limitation #7.)



Deck Type 4: Lightweight Concrete, Non-Insulated

Deck Description: Elastizell Range II Cellular Lightweight Insulating Concrete, Min. 200 psi, min. 2½" thick top coat or Cellular Concrete, LLC. (Mearlcrete) Lightweight Insulating Concrete, Min. 250 psi, min. 2" thick top coat

System Type E(12): Celcore Cellular Lightweight Insulating Concrete, Min. 200 psi

Base sheet mechanically fastened

All General and System Limitations apply.

Primer: (Optional) Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer

Base Layer: One layer Soprafix, Soprafix (X) or Soprafix-e, mechanically attached with Twin-Loc Nails spaced 6" o.c. through OMG Polymer Batten Strip-TL, ES Products Batten Bar-TL, Tru-Fast Twin Loc Batten Bar or Dekfast Coiled Batten Strip, placed in the lap and in one row centered in the field.

Center fastener row is covered with an 8" wide strip of Sopralene Flam Stick*, EPS Flam Stick*, Sopralene Stick, self-adhered

Or

Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.

*Requires heat welded ply or cap membrane.

Ply Sheet: (Optional) One or more layers of Sopralene Flam Stick*, EPS Flam Stick*, Sopralene Stick, self-adhered to sand surfaced base membrane

Or

Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded

Or

Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS*, adhered in hot asphalt at 25 lbs/sq. or applied in FM Adhesive or FM Adhesive (VOC) at a rate of 1.5 gal/sq. to sand surfaced base membrane.

*Requires heat welded cap membrane.



Membrane: One layer of Soprastar Stick, Colphene HR FR GR or Colphene FR GR, Colphene GR, self-adhered to sand surfaced base or ply membrane.

Or

One layer of Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Sopralene 180 SP 3.5mm*, Soprafix*, Soprastar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

One layer of Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR UW GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR, adhered in hot asphalt at 25 lbs/sq. or applied in FM Adhesive or FM Adhesive (VOC) at a rate of 1.5 gal/sq. to sand surfaced base or ply membrane.

*Requires approved Surfacing.

Surfacing: Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure:

-45 psf (See General Limitation #7.)



NOA No.: 07-1217.10
Expiration Date: 02/22/11
Approval Date: 04/24/08
Page 35 of 44

Deck Type 4: Lightweight Concrete, Non-Insulated

Deck Description: Elastizell Range II Cellular Lightweight Insulating Concrete, Min. 200 psi, min. 2½” thick top coat or Cellular Concrete, LLC. (Mearlcrete) Lightweight Insulating Concrete, Min. 250 psi, min. 2” thick top coat

Celcore Cellular Lightweight Insulating Concrete, Min. 200 psi

System Type E(13): Base sheet mechanically fastened

All General and System Limitations apply.

Primer: Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer

(Optional)

Base Layer: Elastophene Flam HP*, Sopralene Flam 180*, Sopralene Flam 180 2.7mm*, Sopralene 180 SP 3.5mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, Elastophene HP, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 2.2mm, Sopralene 180 Sanded 3.5mm, Sopralene 180 PS*, Sopralene 250 Sanded Sopralene 250 Sanded 3.5mm, Sopralene 250 PS*, Sopralene 250 PS 2.7mm*, Sopralene 350 Sanded or Sopralene 350 PS*, mechanically attached with 1.8” long Twin Loc-Nails spaced 6” o.c. in a min. 4” lap and 6” o.c. in two evenly spaced staggered rows in the field.

*Requires heat welded ply or cap membrane.

Ply Sheet: One or more layers of Sopralene Flam Stick*, EPS Flam Stick*, Sopralene Stick, self-adhered to sand surfaced base membrane.

(Optional)

Or

Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.

Or

Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS*, adhered in hot asphalt at 25 lbs/sq. or applied in FM Adhesive or FM Adhesive (VOC) at a rate of 1.5 gal/sq. to sand surfaced base membrane.

*Requires heat welded cap membrane.



Membrane:

One layer of Colphene HR FR GR or Colphene FR GR, Colphene GR, self-adhered to sand surfaced base or ply membrane

Or

SopraStar Stick, self-adhered to Elastocol 600c primed sand surfaced base or ply membrane

Or

One layer of Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Sopralene 180 SP 3.5mm*, Soprafix*, SopraStar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

One layer of Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR UW GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR, adhered in hot asphalt at 25 lbs/sq. or applied in FM Adhesive or FM Adhesive (VOC) at a rate of 1.5 gal/sq. to sand surfaced base or ply membrane.

*Requires approved Surfacing.

Surfacing:

**Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system**

Maximum Design Pressure:

-60 psf (See General Limitation #7.)



- Deck Type 4:** Lightweight Concrete, Non-Insulated
- Deck Description:** Concrecel Lightweight Insulating Concrete with ARBS Perimeter Blocking System
- System Type E(14):** Base sheet mechanically fastened.

All General and System Limitations apply.

- Deck:** Minimum 22 ga. vented B deck attached to supports spaced 6' o.c. maximum using washers and 5/8" puddle welds (at each 1.5" wide rib). Steel deck side laps are attached with Tek 1 screws #12-.75" maximum spacing 6" o.c.
- 16 ga. ARBS Perimeter Blocking System secured with .75" dia. Metal washers and #12-1.5" Tek 2 screws maximum spacing 12" o.c., additionally, ARBS lengths are joined with 6" concealed splice plates fastened with #8-5/8" Tek 2 screws (2 at each side).
- Primer:** Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer.
- (Optional)**
- Base Sheet:** One ply Soprabase base sheet fastened to the deck as described. Attach base sheet using Olympic Pre-assembled CR fasteners spaced 7" o.c. in a 4" lap and 7" o.c. in two staggered rows in the center of the sheet.
- Ply Sheet:** One ply of Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.

Or

One ply of Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0 mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0 mm, Elastophene HD, Elastophene HP, Elastophene PS*, Elastophene PS 3.0*, Elastophene 180 Sanded, Elastophene 180 PS*, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS* or one to three plies of ASTM D2178 Type IV or VI ply sheet, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq or in FM Adhesive or FM Adhesive (VOC) at 1.5 – 2.0 gallons/square to sand surfaced base membrane.

*Requires heat welded cap membrane.



Membrane:

One layer of Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Sopralene 180 SP 3.5mm*, Soprafix*, Soprarstar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

One layer of Elastophene Sanded*, Elastophene FR*, Elastophene 180 Sanded*, Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR UW GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq or in FM Adhesive or FM Adhesive (VOC) at 1.5 – 2.0 gallons/square to sand surfaced ply membrane.

*Requires approved Surfacing.

Surfacing:

**Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system**

Maximum Design Pressure:

-82.5 psf (See General Limitation #7.)



Deck Type 4: Lightweight Concrete, Non-Insulated
Deck Description: Concrecel Lightweight Insulating Concrete with ARBS Perimeter Blocking System

System Type E(15): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: Minimum 22 ga. vented B deck attached to supports spaced 5' o.c. maximum using washers and 5/8" puddle welds (at each 1.5" wide rib). Steel deck side laps are attached with Tek 1 screws #12-.75" maximum spacing 6" o.c.
16 ga. ARBS Perimeter Blocking System secured with .75" dia. Metal washers and #12-1.5" Tek 2 screws maximum spacing 12" o.c., additionally, ARBS lengths are joined with 6" concealed splice plates fastened with #8-³/₈" Tek 2 screws (2 at each side).

**Primer:
(Optional)** Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer

Base Sheet: One layer of Soprafix, Soprafix [S]*, [H], [F]* or [X]* fastened to the deck with #14 screws thru Batten Bar spaced 12" o.c. maximum at the lap of sheet.

*Requires heat welded ply or cap membrane.

Ply Sheet: Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.

*Requires heat welded cap membrane.

Membrane: One layer of Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Sopralene 180 SP 3.5mm*, Soprafix*, Soprastar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

*Requires approved Surfacing.

Surfacing: Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure:

-172.5 psf (See General Limitation #7.)



NOA No.: 07-1217.10
Expiration Date: 02/22/11
Approval Date: 04/24/08
Page 40 of 44

Deck Type 4: Lightweight Concrete, Non-Insulated
Deck Description: Celcore HS Cellular Concrete; minimum wet cast density of 38 lb/ft³, over 18-22 ga steel decking

System Type E(16): Base sheet mechanically fastened

All General and System Limitations apply.

Structural Deck: 18-22 ga. steel decking attached to supports spaced maximum 6' o.c. using 0.5" puddle welds and washers 6" o.c. Steel deck side laps are attached with three Traxx/1 fasteners spaced maximum 12" o.c.

LWC Deck: Celcore HS Cellular Concrete with a minimum wet cast density of 38 lb/ft³, minimum 2" thick top coat. Over a minimum 1" thick EPS Holey Board.

LWC Deck Preparation: Celcore PVA Curing Compound spray applied to lightweight concrete at a rate of 0.33 gal/sq.

Base Layer: One ply of Soprafix, Soprafix-e, mechanically attached through lightweight concrete to steel decking with Dekfast Galvalume Steel Round 2-3/8" 20-Ga Barbed Plates and Dekfast #15 HS fasteners space maximum 12" o.c. through minimum 5" wide laps and maximum 12" o.c. in one central row in the field. A minimum 6" wide strip of Sopralene Flam 180* is heat welded over field fasteners.

*Requires heat welded ply or cap membrane.

Ply Sheet:
(Optional) Elastophene Flam*, Elastophene Flam FR*, Elastophene Flam 2.2 mm*, Elastophene Flam HS FR*, Elastophene Flam HR 3.0 mm*, Elastophene Flam HP*, Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350*, Sopralene 350 SP, heat welded.

*Requires heat welded cap membrane.

Membrane: One layer of Elastophene SP*, Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Soprastar Flam, Sopralene Flam 180 GR, Sopralene Flam 250 GR, Sopralene Flam 350 GR, Sopralene Flam 180 FR GR, Sopralene Flam 250 FR GR, Sopralene Flam 350 FR GR, Sopralene 180 SP*, Sopralene 250 SP*, Sopralene 350 SP*, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast TV Copper, Sopralast TV Inox, heat welded with minimum 3" wide laps.

*Requires approved Surfacing.

Surfacing: Surfacing is Optional on granular surfaced field cap membranes.
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure: -60 psf (See General Limitation #7.)



NOA No.: 07-1217.10
Expiration Date: 02/22/11
Approval Date: 04/24/08
Page 41 of 44

Deck Type 4: Lightweight Concrete, Non-Insulated
Deck Description: Concrecel Lightweight Insulating Concrete, Min. 200 psi
Celcore Cellular Lightweight Insulating Concrete, Min. 200 psi

System Type F(1): Base sheet adhered to substrate

All General and System Limitations apply.

Primer: (Optional) Elastocol 400, 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any insulation, base or ply sheet prior to application of next layer

Base Layer: One layer Colvent SA, Colvent 180 SA, self-adhered.

Or

Colvent TG, Colvent 180 TG, heat welded.

*Requires heat welded cap membrane.

Ply Sheet: None

Membrane: One layer of Elastophene Flam GR, Elastophene Flam UW GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR UW GR, Elastophene Flam FR+ GR, Elastophene Flam FR+ UW GR, Elastophene Flam HR FR GR, Elastophene Flam HS FR GR, Elastophene Flam HS FR UW GR, Elastophene Flam HP FR GR, Sopralene 180 SP 3.5mm*, Soprafix*, SopraStar Flam, Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, Sopralene Flam Jardin, Sopralene Mammoth GR, Sopralast 50 TV Alu, Sopralast 50 TV Alu White, Sopralast Alu, Sopralast TV Copper, Sopralast Copper, Sopralast TV Inox or Sopralast Stainless Steel, heat welded.

Or

One layer of Elastophene GR, Elastophene UW GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR UW GR, Elastophene FR+ GR, Elastophene HD FR GR, Elastophene HR FR GR, Elastophene HS FR GR, Elastophene HS FR UW GR, Elastophene HP FR GR, Sopralene 180 Sanded*, Sopralene 180 GR, Sopralene 180 FR GR, Sopralene 180 FR UW GR, Sopralene 250 Sanded*, Sopralene 250 GR, Sopralene 250 FR GR, Sopralene 250 FR UW GR, Sopralene 350 Sanded*, Sopralene 350 GR or Sopralene 350 FR GR, adhered in hot asphalt at 25 lbs/sq. to sand surfaced base membrane.

*Requires approved Surfacing.

Surfacing: **Surfacing is Optional on granular surfaced field cap membranes.**
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

Maximum Design Pressure:

-60 psf (See General Limitation #7.)



- Deck Type 4:** Lightweight Concrete, Non-Insulated
- Deck Description:** Celcore Cellular Lightweight Insulating Concrete, Min. 300 psi over structural concrete deck.
- System Type F(2):** Base sheet adhered to substrate

All General and System Limitations apply.

- Deck:** Celcore MF Cellular Lightweight concrete shall have a minimum 2" thick top coat. Minimum 1" EPS is optional.
- Primer: (Optional)** ASTM D 41, Elastocol 400, Elastocol 500, Elastocol 600c or AquaTac applied at a rate of 1 gal/sq, to top surface of any base or ply sheet prior to application of next layer
- Vapor Retarder: (Optional)** One layer of Elastophene SP 2.2mm, Elastophene SP 3.0mm, Sopralene 180 SP 3.5mm, Soprafix, Sopralene 250 SP, or Sopralene 350 SP, heat welded
Or
Elastophene Sanded, Elastophene Sanded FR, Elastophene Sanded 3.0mm, Elastophene HS FR, Elastophene HR, Elastophene HR 3.0mm, Elastophene HD, Elastophene HP, Elastophene 180 Sanded, Sopralene 180 Sanded, Sopralene 180 Sanded 3.5mm, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5mm, Sopralene 350 Sanded, adhered in hot asphalt at 25 lbs/sq
- Base Layer:** One layer Colvent TG, Colvent 180 TG, heat welded to primed lightweight concrete.
*Requires heat welded ply or cap membrane.
- Ply Sheet: (Optional)** One or more layers of Sopralene Flam 180*, Sopralene Flam 180 2.7 mm*, Sopralene 180 SP 3.5 mm, Soprafix, Sopralene Flam 250*, Sopralene 250 SP, Sopralene Flam 350* or Sopralene 350 SP, heat welded
Or
Sopralene 180 Sanded, Sopralene 180 Sanded 3.5 mm, Sopralene 180 PS*, Sopralene 250 Sanded, Sopralene 250 Sanded 3.5 mm, Sopralene 250 PS*, Sopralene 250 PS 2.7 mm*, Sopralene 350 Sanded, Sopralene 350 PS*, adhered in hot asphalt at 25 lbs/sq to sand surfaced base membrane.
*Requires heat welded cap membrane.
- Membrane:** One layer of Sopralene Flam 180 GR, Sopralene Flam 180 FR GR, Sopralene Flam 180 FR UW GR, Sopralene Flam 180 FR+ GR, Sopralene 250 SP*, Sopralene Flam 250 GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 FR UW GR, Sopralene Flam 250 FR+ GR, Sopralene Flam 250 FR+ UW GR, Sopralene 350 SP*, Sopralene Flam 350 GR, Sopralene Flam 350 FR GR, heat welded.
*Requires approved Surfacing.
- Surfacing:** **Surfacing is Optional on granular surfaced field cap membranes.**
Surfacing is Required for smooth or sanded surfaced field cap membranes.
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system
- Maximum Design Pressure:** -262.5 psf (See General Limitation #9.)



LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117; calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant
(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).
(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)
- 10 All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 07-1217.10
Expiration Date: 02/22/11
Approval Date: 04/24/08
Page 44 of 44