



MIAMI-DADE COUNTY, FLORIDA
 METRO-DADE FLAGLER BUILDING
 140 WEST FLAGLER STREET, SUITE 1603
 MIAMI, FLORIDA 33130-1563
 (305) 375-2901 FAX (305) 372-6339
www.miamidade.gov/buildingcode

**BUILDING CODE COMPLIANCE OFFICE (BCCO)
 PRODUCT CONTROL DIVISION
 NOTICE OF ACCEPTANCE (NOA)**

Sunshine Windows Manufacturing, Inc.
 1745 W. 33rd Place
 Hialeah, FL 33012

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series 1650 Aluminum Horizontal Sliding Window – N.I.

APPROVAL DOCUMENT: Drawing No. **HS07-01**, titled "Series 1650 Aluminum Horizontal Sliding Window (XO) Non-Impact Resistant Glass", sheets 1 through 7 of 7, dated 12/17/07, prepared by manufacturer, signed and sealed by Francisco Hernandez, P.E., bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and Approval date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: None

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by **Manuel Perez, P.E.**



NOA No. 08-0107.07
 Expiration Date: April 10, 2013
 Approval Date: April 10, 2008
 Page 1

Sunshine Windows Manufacturing, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Manufacturer's die drawings and sections.
2. Drawing No **HS07-01**, titled "Series 1650 Aluminum Horizontal Sliding Window (XO) Non-Impact Resistant Glass", sheets 1 through 7 of 7, dated 12/17/07, prepared by manufacturer, signed and sealed by Francisco Hernandez, P.E.

B. TESTS

1. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Forced Entry Test, per FBC 2411 3.2.1, TAS 202-94
along with marked-up drawings and installation diagram of an alum. horiz. sliding window with 1/4" temp. glass, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-5376**, dated 08/24/07, signed and sealed by Carlos S. Rionda, P.E.
2. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Forced Entry Test, per FBC 2411 3.2.1, TAS 202-94
along with marked-up drawings and installation diagram of an alum. horiz. sliding window with 1/4" ann. glass, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-5060**, dated 02/28/07, signed and sealed by Carlos S. Rionda, P.E.
3. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Forced Entry Test, per FBC 2411 3.2.1, TAS 202-94
along with marked-up drawings and installation diagram of an alum. horiz. sliding window with 1/8" ann. glass, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-5058**, dated 01/30/07, signed and sealed by Carlos S. Rionda, P.E.
5. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Forced Entry Test, per FBC 2411 3.2.1, TAS 202-94
along with marked-up drawings and installation diagram of an alum. horiz. sliding window with 3/16" ann. glass, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-5057**, dated 03/02/07, signed and sealed by Carlos S. Rionda, P.E.

C. CALCULATIONS

1. Anchor verification calculations and structural analysis, complying with FBC-2004, prepared by Sunshine Windows Manufacturing, Inc., dated 12/15/07, signed and sealed by Francisco Hernandez, P.E.
Complies with ASTM E1300-02


Manuel Perez, P.E.
Product Control Examiner
NOA No. 08-0107.07

Expiration Date: April 10, 2013
Approval Date: April 10, 2008

Sunshine Windows Manufacturing, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

D. QUALITY ASSURANCE

1. Miami Dade Building Code Compliance Office (BCCO).

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS


1. Statement letter of conformance, dated December 15, 2007, signed and sealed by Francisco Hernandez, P.E.
2. Statement letter of no financial interest, dated December 15, 2007, signed and sealed by Francisco Hernandez, P.E.
3. Laboratory compliance letter for Test Report no. **FTL-5376**, issued by Fenestration Testing Laboratory, Inc., dated August 28, 2007, signed and sealed by Carlos S. Rionda, P.E.
4. Laboratory compliance letter for Test Report no. **FTL-5060**, issued by Fenestration Testing Laboratory, Inc., dated March 28, 2007, signed and sealed by Carlos S. Rionda, P.E.
5. Laboratory compliance letter for Test Report no. **FTL-5058**, issued by Fenestration Testing Laboratory, Inc., dated March 28, 2007, signed and sealed by Carlos S. Rionda, P.E.
6. Laboratory compliance letter for Test Report no. **FTL-5057**, issued by Fenestration Testing Laboratory, Inc., dated March 28, 2007, signed and sealed by Carlos S. Rionda, P.E.

G. OTHER

1. None



Manuel Perez, P.E.
Product Control Examiner
NOA No. 08-0107.07

Expiration Date: April 10, 2013
Approval Date: April 10, 2008



Sunshine Windows
Manufacturing, Inc.
1745 W. 33rd Place
Hialeah, Florida 33012
Ph: (305)364-9952
Fax: (305)828-5118

**SERIES 1650 ALUMINUM
HORIZONTAL SLIDING WINDOW (XO)
NON-IMPACT RESISTANT GLASS**



GENERAL NOTES: NON-IMPACT HORIZONTAL ROLLER WINDOW.

- 1.- CONFIGURATIONS OX AND XO
- 2.- FOR NUMBER OF ANCHORS FOR EACH UNIT SIZE REFER TO PAGE 2 OF 7.
- 3.- REFERENCES: TESTS REPPORTS FTL-5057,FTL-5058, FTL-5060 AND FTL-5376.
- 4.- THIS PRODUCT HAS BEEN DESIGNED & TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE 2004 EDITION FOR THE HIGH VELOCITY HURRICANE ZONE.
- 5.- FASTENERS MUST HAVE THEIR OWN NOTICE OF ACCEPTANCE AND MUST BE MADE OF STAINLESS STEEL OR HAVE ADEQUATE PROTECTION AGAINST CORROSION, PER DIN 50018. ALUMINUM CONTACTING METALS SHALL BE PROPERLY PROTECTED,

MIAMI-DADE IMPACT RESISTANT SHUTTERS REQUIRED

NON-IMPACT RESISTANT WINDOW

Approved as complying with the
Florida Building Code
Date: 04/10/2008
NOA#: 08-0107.07
Miami Dade Product Control
Division
By: *Manuel Perez*

Francisco Hernandez
12-18-07
FRANCISCO HERNANDEZ
FLORIDA PE # 51393

Drawn By: RF
Date: 12-17-07
Scale: 1/2"=1'
Revision:
Revision:

DRAWING NO.
HS07-01


SHEET
1 OF 7

DESIGN PRESSURE CHART - PSF

SERIES-1650
NON-IMPACT ALUMINUM HORIZONTAL SLIDING WINDOW (XO)

WINDOW DIMENSION	ANCHORS		1/8" ANNEALED GLASS		3/16" ANNEALED GLASS		1/4" ANNEALED GLASS		1/4" TEMPERED GLASS											
			1 3/4" SILL		3" SILL		1 3/4" SILL		3" SILL											
	WIDTH	HEIGHT	PER HEAD & SILL	PER JAMB	EXT.	INT.	EXT.	INT.	EXT.	INT.	EXT.	INT.	EXT.	INT.	EXT.	INT.	EXT.	INT.		
STANDARD SIZES	26 1/2" 37" 53 1/8" 74"	26"	3	3	50.00	145.00	70.00	145.00	53.33	210.00	70.00	210.00	53.33	210.00	70.00	210.00	53.33	210.00	70.00	210.00
			4		50.00	96.40	70.00	96.40	53.33	201.00	70.00	201.00	53.33	201.00	70.00	201.00	53.33	210.00	70.00	210.00
			6		50.00	72.90	70.00	72.90	53.33	131.00	70.00	131.00	53.33	186.00	70.00	186.00	53.33	210.00	70.00	210.00
			8		49.50	49.50	49.50	49.50	53.33	89.90	70.00	89.90	53.33	130.00	70.00	130.00	53.33	210.00	70.00	210.00
	26 1/2" 37" 53 1/8" 74"	38 3/8"	3	5	50.00	114.00	70.00	114.00	53.33	177.10	70.00	177.10	53.33	210.00	70.00	210.00	53.33	210.00	70.00	210.00
			4		50.00	59.20	59.20	59.20	53.33	130.46	70.00	130.46	53.33	199.00	70.00	199.00	53.33	210.00	70.00	210.00
			6		48.90	48.90	48.90	48.90	53.33	82.60	70.00	82.60	53.33	114.00	70.00	114.00	53.33	210.00	70.00	210.00
			8		-	-	-	-	53.33	63.00	63.00	63.00	53.33	81.50	70.00	81.50	53.33	168.45	70.00	168.45
	37" 53 1/8" 74"	50 5/8"	4	6	47.20	47.20	47.20	47.20	53.33	95.04	70.00	95.04	53.33	170.00	70.00	170.00	53.33	210.00	70.00	210.00
			6		-	-	-	-	53.33	60.10	60.10	60.10	53.33	84.70	70.00	84.70	53.33	154.60	70.00	154.60
			8		-	-	-	-	48.10	48.10	48.10	48.10	53.33	60.10	60.10	60.10	53.33	117.50	70.00	117.50
			4		-	-	-	-	53.33	74.59	70.00	74.59	53.33	153.00	70.00	153.00	53.33	167.82	70.00	167.82
53 1/8" 74"	63"	6	7	-	-	-	-	49.60	49.60	49.60	49.60	53.33	72.60	70.00	72.60	53.33	120.12	70.00	120.12	
		8		-	-	-	-	-	-	-	-	46.90	46.90	46.90	46.90	53.33	90.00	70.00	90.00	
		3		3	50.00	160.00	70.00	160.00	53.33	160.00	70.00	160.00	53.33	210.00	70.00	210.00	53.33	210.00	70.00	210.00
		4			50.00	110.00	70.00	110.00	53.33	153.46	70.00	153.46	53.33	153.46	70.00	153.46	53.33	153.40	70.00	153.46
5	50.00	83.80	70.00		83.80	53.33	126.98	70.00	126.98	53.33	126.98	70.00	126.98	53.33	126.98	70.00	126.98			
7	50.00	66.40	66.40		66.40	53.33	126.00	70.00	126.00	53.33	132.86	70.00	132.86	53.33	132.86	70.00	132.86			
8	50.00	52.20	52.20		52.20	53.33	103.00	70.00	103.00	53.33	121.22	70.00	121.22	53.33	121.22	70.00	121.22			
MODULAR SIZES	24" 36" 48" 60" 72"	24"	3	4	50.00	147.00	70.00	147.00	53.33	153.46	70.00	153.46	53.33	153.46	70.00	153.46	53.33	153.46	70.00	153.46
			4		50.00	66.50	66.50	66.50	53.33	135.42	70.00	135.42	53.33	135.42	70.00	135.42	53.33	135.42	70.00	135.42
			5		50.00	55.00	55.00	55.00	53.33	97.90	70.00	97.90	53.33	100.42	70.00	100.42	53.33	100.42	70.00	100.42
			7		49.40	49.40	49.40	49.40	53.33	80.60	70.00	80.60	53.33	99.93	70.00	99.93	53.33	99.93	70.00	99.93
			8		42.70	42.70	42.70	42.70	53.33	69.10	69.10	69.10	53.33	88.59	70.00	88.59	53.33	88.59	70.00	88.59
	36" 48" 60" 72"	48"	4	5	50.00	51.60	51.60	51.60	53.33	100.42	70.00	100.42	53.33	100.42	70.00	100.42	53.33	100.42	70.00	100.42
			5		-	-	-	-	53.33	73.60	70.00	73.60	53.33	93.87	70.00	93.87	53.33	93.87	70.00	93.87
			7		-	-	-	-	53.33	57.40	57.40	57.40	53.33	76.80	70.00	76.80	53.33	87.00	70.00	87.00
			8		-	-	-	-	51.40	51.40	51.40	51.40	53.33	65.80	65.80	65.80	53.33	74.30	70.00	74.30
			4		7	46.60	46.60	46.60	46.60	53.33	80.76	70.00	80.76	53.33	99.93	70.00	99.93	53.33	99.93	70.00
	5	-	-	-		-	53.33	61.30	61.30	61.30	53.33	87.00	70.00	87.00	53.33	87.00	70.00	87.00		
	7	-	-	-		-	44.00	44.00	44.00	44.00	53.33	61.00	61.00	61.00	53.33	83.40	70.00	83.40		
8	-	-	-	-		-	-	-	-	50.50	50.50	50.50	50.50	53.33	67.80	67.80	67.80			

NON-IMPACT RESISTANT WINDOW



Sunshine Windows Manufacturing, Inc.
1745 W. 33rd Place
Hialeah, Florida 33012
Ph: (305)364-9952
Fax: (305)828-5118


SERIES 1650 ALUMINUM
HORIZONTAL SLIDING WINDOW (XO)
NON-IMPACT RESISTANT GLASS

Approved as complying with the Florida Building Code
Date: 04/10/2008
NOA# 08-0107.07
Miami Date Product Control
Division By: *Manuel Perez*


Drawn By: RF
Date: 12-17-07
Scale: 1/2"=1'
Revision: _____
Revision: _____

FHA
12-18-07
FRANCISCO HERNANDEZ
FLORIDA PE # 51393


DRAWING NO.
HS07-02
SHEET
2 OF 7



HORIZONTAL SECTION




VERTICAL SECTION



VERTICAL SECTION WITH SILL RISER

NON-IMPACT RESISTANT WINDOW



Sunshine Windows
Manufacturing, Inc.
1745 W. 33rd Place
Hialeah, Florida 33012
Ph: (305)364-9952
Fax: (305)828-5118

SERIES 1650 ALUMINUM
HORIZONTAL SLIDING WINDOW (XO)
NON-IMPACT RESISTANT GLASS

Approved as complying with the
Florida Building Code
Date 04/10/2008
NOA# 08-0107.07
Miami Dade Product Control
Division
By Manuel Diaz

Drawn By: RF
Date: 12-17-07
Scale: 1/2"=1'
Revision:
Revision:

Full
12-18-07
FRANCISCO HERNANDEZ
FLORIDA PE # 51393


DRAWING NO.
HS07-03
SHEET
3 OF 7

MATERIAL LIST

ITEM #	PART #	REQD.	DESCRIPTION	MATERIAL
1	SW-019	1	FRAME HEAD	6063-T5
2	SW-019	1	FRAME SILL	6063-T5
3	SWxxx21	1	INSERT TRACK	6063-T5
4	SW-018	AS RQD	GLAZING BEAD	6063-T5
5	SW-012	2	SLIDER TOP/BOTTOM RAIL	6063-T5
6	SW3019	AS RQD	FIN SEAL PILE	FELT
7	SW1520	AS RQD	GLAZING TAPE	FOAM
8	SW321W	2	WHEEL	BRASS
9	SW-017	1	MOVING MEETING RAIL	6063-T5

MATERIAL LIST

ITEM #	PART #	REQD.	DESCRIPTION	MATERIAL
10	SW40111	1	FIXED MEETING RAIL	6063-T5
11	SW-AS	AS RQD	ASSEMBLY SCREWS	# 8X1" SMS.
12	SW-013	1	JAMB TO MOVING PANEL	6063-T5
13	SW-016	1	MOVING SIDE RAIL	6063-T5
14	SW3257	AS RQD	WEATHER STRIP BULB	VINYL
15	SW-667	AS RQD	LATCH	ZINC
16	SW-S10	2/SILL	RETICULATED FILTER	FOAM
17	SW40771	1	SILL RISER	6063-T5
18	SW-014	1	JAMB TO FIXED PANEL	6063-T5



Approved as complying with the Florida Building Code
 Date: *04/10/2008*
 NCAM: *08-0107.07*
 Miami Dade Product Control Division
 By: *Francisco Hernandez*

Sunshine Windows Manufacturing, Inc.
 1745 W. 33rd Place
 Hialeah, Florida 33012
 Ph: (305)364-9952
 Fax: (305)828-5118


**SERIES 1650 ALUMINUM
 HORIZONTAL SLIDING WINDOW (XO)
 NON-IMPACT RESISTANT GLASS**

Drawn By: RF
 Date: 12-17-07
 Scale: 1/2"=1"
 Revision: _____
 Revision: _____

Francisco Hernandez
 12-18-07
 FRANCISCO HERNANDEZ
 FLORIDA PE # 51393


DRAWING NO.
 HS07-04
 SHEET
 4 OF 7

NON-IMPACT RESISTANT WINDOW




TYPICAL ANCHORS
 1/4" TAPCONS 1 1/4" MIN. EMBEDMENT INTO MASONRY THROUGH 1" BY WOOD BUCK (FOR MAX. ANCHOR SPACING REFER TO SHEET 1 OF 7. FOR NUMBER OF ANCHORS REFER TO SHEET 2 OF 7.)

DETAIL A
 ATTACHMENT TO MASONRY



TYPICAL ANCHORS
 1/4" SMS 1 1/2" MIN. PENETRATION INTO WOOD. (FOR MAX. ANCHOR SPACING REFER TO SHEET 1 OF 7. FOR NUMBER OF ANCHORS REFER TO SHEET 2 OF 7.)

DETAIL B
 ATTACHMENT TO WOOD



TYPICAL ANCHORS
 1/4" SMS THROUGH METAL. (FOR MAX. ANCHOR SPACING REFER TO SHEET 1 OF 7. FOR NUMBER OF ANCHORS REFER TO SHEET 2 OF 7.)

DETAIL C
 ATTACHMENT TO METAL STRUCTURE DETAIL (STEEL OR ALUMI. 1/8" MIN. THICKNESS)

TYPICAL HEAD SECTIONS

Approved as complying with the Florida Building Code
 Date 04/10/2008
 NOA# 03-0107.07
 Miami Dade Product Control Division
 By *Manuel Perez*

FH
 12-18-07
 FRANCISCO HERNANDEZ
 FLORIDA PE # 51393

Sunshine Windows Manufacturing, Inc.
 1745 W. 33rd Place
 Hialeah, Florida 33012
 Ph: (305)364-9952
 Fax: (305)828-5118


SERIES 1650 ALUMINUM
 HORIZONTAL SLIDING WINDOW (XO)
 NON-IMPACT RESISTANT GLASS

Drawn By: RF
 Date: 12-17-07
 Scale: 1/2" = 1'
 Revision: _____
 Revision: _____

DRAWING NO.
 HS07-05


SHEET
 5 OF 7

NON-IMPACT RESISTANT WINDOW




Sunshine Windows
Manufacturing, Inc.
1745 W. 33rd Place
Hialeah, Florida 33012
Ph: (305)364-9952
Fax: (305)828-5118

SERIES 1650 ALUMINUM
HORIZONTAL SLIDING WINDOW (XO)
NON-IMPACT RESISTANT GLASS




1/4" TAPCONS 1 1/4" MIN. EMBEDMENT INTO MASONRY (FOR MAX. ANCHOR SPACING REFER TO SHEET 1 OF 7. FOR NUMBER OF ANCHORS REFER TO SHEET 2 OF 7.)

DETAIL D
ATTACHMENT TO PRE-CAST SILL




1/4" SMS 1 1/2" MIN. PENETRATION INTO WOOD. (FOR MAX. ANCHOR SPACING REFER TO SHEET 1 OF 7. FOR NUMBER OF ANCHORS REFER TO SHEET 2 OF 7.)

DETAIL F
ATTACHMENT TO WOOD



1/4" TAPCONS 1 1/4" MIN. EMBEDMENT INTO MASONRY THROUGH 1" BY WOOD BUCK OR NON SHRINK NON METALLIC GROUT (FOR MAX. ANCHOR SPACING REFER TO SHEET 1 OF 7. FOR NUMBER OF ANCHORS REFER TO SHEET 2 OF 7.)

DETAIL E
ATTACHMENT TO MASONRY



1/4" SMS THROUGH METAL. (FOR MAX. ANCHOR SPACING REFER TO SHEET 1 OF 7. FOR NUMBER OF ANCHORS REFER TO SHEET 2 OF 7.)

DETAIL G
ATTACHMENT TO METAL STRUCTURE
(STEEL OR ALUM. 1/8" MIN. THICKNESS)


TYPICAL SILL SECTIONS

NON-IMPACT RESISTANT WINDOW


Approved as complying with the Florida Building Code
Date: 04/10/2008
NOA#: 08-0107.07
Miami Dade Product Control
Division
By: *Manuel Perez*

Drawn By: RF
Date: 12-17-07
Scale: 1/2"=1'
Revision: _____
Revision: _____
DRAWING NO.
HS07-06
SHEET
6 OF 7


FHS
12-18-07
FRANCISCO HERNANDEZ
FLORIDA PE # 51393



DETAIL H
ATTACHMENT TO MASONRY




DETAIL I
ATTACHMENT TO WOOD




DETAIL J
ATTACHMENT TO METAL STRUCTURE
(STEEL OR ALUM. 1/8" MIN. THICKNESS)

TYPICAL ANCHORS
1/4" SMS THROUGH METAL
(FOR MAX. ANCHOR SPACING REFER TO SHEET 1 OF 7.
FOR NUMBER OF ANCHORS REFER TO SHEET 2 OF 7.)
DETAIL VALID FOR JAMBS, HEAD AND SILL




ATTACHMENT TO MULLIONS DETAIL

TYPICAL JAMB SECTIONS



NON-IMPACT RESISTANT WINDOW



Sunshine Windows
Manufacturing, Inc.
1745 W. 33rd Place
Hialeah, Florida 33012
Ph: (305)364-9952
Fax: (305)828-5118

**SERIES 1650 ALUMINUM
HORIZONTAL SLIDING WINDOW (XO)
NON-IMPACT RESISTANT GLASS**

Approved as complying with the
Florida Building Code
Date 04/10/2008
NOA# 08-0107.07
Miami Dade Product Control
Division
By Mauricio Perez

Drawn By: RF
Date: 12-17-07
Scale: 1/2"=1'
Revision: _____
Revision: _____

FHS
12-18-07
FRANCISCO HERNANDEZ
FLORIDA PE # 51393

DRAWING NO.
HS07-07
SHEET
7 OF 7