



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Guardian Building Products,
316 Business Parkway, Suite D,
Greer, South Carolina 29651**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: "Guardvent" Roof Ridge Vent

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 5.

The submitted documentation was reviewed by Fitz A. Harris, P.E..

Fitz A. Harris



**NOA No.: 08-0326.15
Expiration Date: 07/10/13
Approval Date: 07/10/08
Page 1 of 5**

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Roof Vent
Material: Plastic

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Guardvent	Ht. = 3/4"(19mm) Width=14-1/8" (357.7mm) Length = 48"(1219.2 mm)	TAS 100(A)	Plastic low profile attic ridge vent.

TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS.

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>	<u>Manufacturer</u>
3/8" Head nails	11ga x 2-1/2"	TAS114	Galvanized ring shanked nails.	Generic

EVIDENCE SUBMITTED

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name Report</u>	<u>Date</u>
PRI ConstructionMaterials Technologies	GLMC-002-02-01	TAS-100(A)	02/27/08
PRI Construction Materials Technologies	GLMC-001-02-05	ASTM G155	11/28/2007
ETC Laboratories	ETC-07-718-19330.0	ASTM D 1929 ASTM D635 ASTM D 2843	06/04/07 06/04/07 06/04/07



NOA No.: 08-0326.15
 Expiration Date: 07/10/13
 Approval Date:07/10/08
 Page 2 of 5

APPROVED APPLICATIONS:

Trade Name: Guardvent

System Type A: Mechanical attachment of static ridge vent over the plywood deck and under the roof cap shingles..

- Installation:**
1. Cut a 3-1/2" wide opening (1-3/4" on each side of ridge) centered in the deck at the ridge for ventilation. The slot shall terminate approximately 12" from the rake edges.
 2. Prepare vent by placing a 1/4" bead of roof cement along the length of the outside flange to seal the vent to the field shingles.
 3. Place Guardvent over the slot and fasten using min 11ga, 2-1/2", 3/8" head galvanized ring shanked nails. Locate the fasteners 1- 1/2" from the ends of the vent and 9" on center in marked nail line.
 4. Interlock the joints and seal with roof cement.
 5. Cover the vent with cap shingles. Fasten each cap shingle with two (2) 2-1/2" ring shanked galvanized nails. Use flashing cement to seal the outside edges where the vent meets the shingles.

Net Free Area: Refer to Manufacturer's Published Literature

Minimum Slope: 2:12


SYSTEM LIMITATIONS:

1. Refer to applicable Building code for required ventilation.
2. Ridge vent ventilators shall not be installed on roof mean heights greater than 33 ft.
3. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.
4. Ridge Vent shall comply with 1517.6 of the Florida Building Code (FBC).



NOA No.: 08-0326.15
Expiration Date: 07/10/13
Approval Date: 07/10/08
Page 3 of 5

Guardvent Roof Ridge Vent Detail Drawing



Guardvent Roof Ridge With Filter

END OF THIS ACCEPTANCE



NOA No.: 08-0326.15
 Expiration Date: 07/10/13
 Approval Date: 07/10/08
 Page 5 of 5