



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**CertainTeed Corporation (PA)
1400 Union Meeting Road, P.O. Box 1100
Blue Bell, PA 19422**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: CertainTeed Conventional Built-Up-Roof System over Poured Gypsum Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 08-022702 and consists of pages 1 through 12.
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 08-0410.02
Expiration Date: 04/28/13
Approval Date: 10/30/08
Page 1 of 12**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Built-Up Roofing
Material: Fiberglass
Deck Type: Poured Gypsum
Maximum Design Pressure -60 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

Product	Dimensions	Test Specification	Product Description
All Weather/Empire Base Sheet	36" x 65'10"; Roll weight: 86 lbs. (2 squares)	ASTM D 4601 Type II UL Type 15	Asphalt coated, fiberglass reinforced base sheet.
Flintglas® Mineral Surfaced Cap Sheet	36" X 32'10"; Roll Weight: 78 lbs. (1 square)	ASTM D 3909	Asphalt impregnated and coated inorganic glass fiber surfaced with mineral granules used as the top ply in conventional built-up roof membranes.
Flintglas® Mineral Surfaced Cap CoolStar	36" X 32'10"; Roll Weight: 78 lbs. (1 square)	ASTM D 3909	Asphalt impregnated and coated inorganic glass fiber surfaced with mineral granules used as the top ply in conventional built-up roof membranes. Covered with reflective CoolStar Coating.
Flintglas® Ply Sheet Type IV or VI	36" x 164'7"; Roll weight: 40/55 lbs. (5 squares)	ASTM D 2178 Type IV or VI UL Type G1	Fiberglass, asphalt impregnated ply sheet.
Flex-I-Glas or Flex-I-Glas FR Base Sheet	36" x 98'9"; Roll weight: 90 lbs. (3 squares)	ASTM D 5147	SBS Modified, fiberglass reinforced base sheet.
GlasBase™ Base Sheet	36" x 98'9"; Roll weight: 69 lbs. (3 squares)	ASTM D 4601 UL Type G2	Asphalt coated, fiberglass base sheet.
No. 15 Perforated Felt	36" x 144', Roll weight: 90 lbs. (4 square)	ASTM D 226 Type I	Organic asphalt saturated felt.
Yosemite® Buffer Base Sheet	36" x 32'10"; Roll weight: 90 lbs. (1 square)	ASTM D 3909 ASTM D 4897 UL Type 30	Mineral Surfaced fiberglass reinforced buffer sheet.



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
White Line	Polyisocyanurate foam insulation	Apache Products Co.
ACFoam II	Polyisocyanurate foam insulation	Atlas Energy Products
ISO 95+	Polyisocyanurate foam insulation	Firestone
High Density Wood Fiberboard	Wood fiber insulation board	generic
Perlite Insulation	Perlite insulation board	generic
Dens Deck, Dens Deck Prime	Water resistant gypsum board	G-P Gypsum Corp.
H-Shield	Polyisocyanurate foam insulation	Hunter Panels
ENRGY -3 & PSI 25, UltraGard Gold	Polyisocyanurate foam insulation	Johns Manville
Multi-Max & FA	Polyisocyanurate roof insulation	RMax, Inc.

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	FM-30, FM-45, FM-60, FM-90 Fasteners	Base ply fastening systems for lightweight concrete decks.		ES Products, Inc.
2.	Nail-Tite Type 'A', Type 'R'	Galvanized steel base ply fastener for gypsum decks		ES Products, Inc.
3.	Polymer Gyptec	Glass reinforced Nylon insulation fastener for gypsum & CWF decks.		OMG
4.	Polymer Gyptec Metal Plate	Galvalume stress plate	3" round	OMG
5.	NTB Magnum	Glass reinforced Nylon insulation fastener for gypsum & CWF decks with barbs.		OMG
6.	NTB Plate	Galvalume stress plate	3" round	OMG
7.	Lite-Deck	Insulation fastener for CWF and Gypsum decks.		OMG
8.	Lite-Deck Plate	Galvalume stress plate	3" round	OMG
9.	Powerlite	Insulation fastener for CWF and Gypsum decks.		Powers Fasteners, Inc.



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
10.	Powerlite Plates	Galvalume AZ55 steel plate	3" round	Powers Fasteners, Inc.
11.	Powerlite Lap Plates	Galvalume AZ55 steel plate	2" round	Powers Fasteners, Inc.
12.	Base-Lok Fastener	Nylon base sheet fastener.		Simplex Nails & Fasteners

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Applied Research Laboratories	Physical Properties	28013	06/02/87
Trinity ERD	TAS 117 (B)	3503.10.06	10/10/06
	TAS 117 (B)	O6490.04.07-R1	06/27/07
	TAS 117 (B)/ ASTM D 6862	C8500SC.11.07	11/30/07
	FM 4470, TAS 114	C8370.08.08	08/19/08
	ASTM Requirements	C10080.09.08	09/04/08
Momentum Technologies, Inc.	ASTM D 4601	AX31G8D	09/05/08
	ASTM D 3909/ D 4897	AX31G8C	09/05/08
Factory Mutual Research Corp.	Current Insulation Fastening Requirements	FMRC 1996	01/01/96
	FMRC 4470	J.I. #3Y8A1.AM	03/23/96
	FMRC 4454	J.I. 0D3A3.AM	04/04/97
	FMRC 4470	J.I. 2D0A0.AM	12/23/98
	FMRC 4470	J.I. 1D7A4.AM	11/09/98
Underwriters Laboratories, Inc.	Fire Classification Compliance	R11656	07/13/87
United States Testing Company	ASTM D 5147	97457-4	06/03/88
	ASTM D 5147	97-457-2R	12/02/87



APPROVED ASSEMBLIES

Deck Type 6I: Poured Gypsum, Insulated

Deck Description: Poured gypsum concrete

System Type A: Anchor sheet mechanically fastened, one or more layer of insulation adhered with approved asphalt.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners	Fastener Density/ft²
AC-Foam II, ENRGY 3 Multi-Max, H-Shield Minimum 1" thick	N/A	N/A
High Density Wood Fiber Minimum ½" thick	N/A	N/A
Perlite Minimum ¾" thick	N/A	N/A
(Optional) Top Insulation Layer	Insulation Fasteners	Fastener Density/ft²
High Density Wood Fiber Minimum ½" thick	N/A	N/A
Perlite Minimum ¾" thick	N/A	N/A
Dens Deck, Dens Deck Prime Minimum ¼" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.



- Anchor sheet: All Weather/Empire, Flex-I-Glas, Flex-I-Glas FR, GlasBase or Poly SMS base sheet installed as noted below.
- Fastening #1: (Poly SMS only) Nail-Tite Type A or Type R with minimum 1-5/8" diameter head or Simplex Base-Lok fasteners with minimum 1-5/8" diameter plate spaced 9" o.c. in min. 2" side lap and two staggered rows in center of the sheet, 18" o.c.
(Maximum Design Pressure –52.5 psf, See General Limitation #9.)
- Fastening #2: Nail-Tite Type A or Type R with FM-30 discs or FM-90 Base Ply Fasteners or Simplex Base-Lok fasteners with minimum 3" diameter plate spaced 9" o.c. in min. 2" side lap and two staggered rows in center of the sheet, 18" o.c.
(Maximum Design Pressure –52.5 psf, See General Limitation #9.)
- Fastening #3: Nail-Tite Type A or Type R with FM-30 discs or FM-90 Base Ply Fasteners or Simplex base-Lok fasteners with minimum 3" diameter plate spaced 7½" o.c. in min. 2" side lap and one row in center of the sheet, 7½" o.c.
(Maximum Design Pressure –45 psf, See General Limitation #9.)
- Fastening #4: Nail-Tite Type A or Type R with FM-30 discs or FM-90 Base Ply Fasteners or Simplex Base-Lok fasteners with minimum 3" diameter plate spaced 9" o.c. in min. 2" side lap and two staggered rows in center of the sheet, 12" o.c.
(Maximum Design Pressure –60 psf, See General Limitation #9.)
- Base Sheet: (Optional) Install one ply of All Weather/Empire, Flex-I-Glas or GlasBase base sheet directly over the top layer of insulation. Adhere with any approved mopping asphalt at an application rate of 20-35 lbs./sq.
- Ply Sheet: Two or more plies of Flintglas Ply Sheet (Type IV), Flintglas Premium Ply Sheet (Type VI) or #15 Asphalt Perforated Felt ply sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.
- Cap Sheet: (Optional) One ply of Flintglas Mineral Surface Cap Sheet or Flintglas Mineral Surfaced Cap CoolStar adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.
- Surfacing: (Required if no cap sheet is used) Install one of the following:
 1. Flood coat of hot asphalt with an application rate of 60 lbs./sq. ± 20%; plus gravel or slag with an application rate of 400 lbs./sq. & 300 lbs./sq., respectively.
 2. A two part coating consisting of a base coat of Static Asphalt Fibered Emulsion at rate of 3 gal./sq. or Monoform compound; surfaced with 1 gal./sq. Sta-Kool non-fibered aluminum coating or fibered APOC No. 212.
- Maximum Design Pressure: See fastening requirements above



Deck Type 6I: Poured Gypsum, Insulated
Deck Description: Poured gypsum concrete
System Type B: Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners	Fastener Density/ft²
ACFoam-II, UltraGard Gold Minimum 1.3" thick	3, 7 or 9	1:4 ft ²
ENRGY-3, PSI-25, H-Shield Minimum 1.4" thick	5	1:3 ft ²
Minimum 2" thick	3, 5, 7 or 9	1:4 ft ²
High Density Wood Fiber Minimum ½" thick	3, 5, 7 or 9	1:2 ft ²
Perlite Minimum ¾" thick	3, 5, 7 or 9	1:2 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

(Optional) Top Insulation Layer	Insulation Fasteners	Fastener Density/ft²
Any of the insulations listed for Base Layer, above.		
Dens Deck, Dens Deck Prime Minimum ¼" thick	N/A	N/A

Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: (Optional) Install one ply of All Weather/Empire, Flex-I-Glas or GlasBase base sheet directly over the top layer of insulation. Adhere with any approved mopping asphalt at an application rate of 20-35 lbs./sq.

Ply Sheet: Two or more plies of Flintglas Ply Sheet (Type IV), Flintglas Premium Ply Sheet (Type VI) or #15 Asphalt Perforated Felt ply sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.

Cap Sheet: (Optional) One ply of Flintglas Mineral Surface Cap Sheet or Flintglas Mineral Surfaced Cap CoolStar adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.



Surfacing:

(Required if no cap sheet is used) Install one of the following:

1. Flood coat of hot asphalt with an application rate of 60 lbs./sq. \pm 20%; plus gravel or slag with an application rate of 400 lbs./sq. & 300 lbs./sq., respectively.
2. A two part coating consisting of a base coat of Static Asphalt Fibered Emulsion at rate of 3 gal./sq. or Monoform compound; surfaced with 1 gal./sq. Sta-Kool non-fibered aluminum coating or fibered APOC No. 212.

Maximum Design
Pressure:

-45 psf (See General Limitation #9)



Deck Type 6I: Poured Gypsum, Insulated

Deck Description: Poured gypsum concrete

System Type C: All layers of insulation simultaneously fastened.

All General and System limitations apply.

One or more layers of any of the following insulations:

(Optional) Base Insulation Layer	Insulation Fasteners	Fastener Density/ft²
AC-Foam II, ENRGY 3, Multi-Max, H-Shield Minimum 1" thick	N/A	N/A
High Density Wood Fiber Minimum ½" thick	N/A	N/A
Perlite Minimum ¾" thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners	Fastener Density/ft²
ACFoam-II Minimum 1.3" thick	3, 5, 7 or 9	1:3 ft²
ENRGY-3, PSI-25, Iso 95 +, H-Shield Minimum 1.4" thick	3 or 5	1:3 ft²
High Density Wood Fiber Minimum ½" thick	3, 5, 7 or 9	1:2 ft²
Perlite Minimum ¾" thick	3, 5, 7 or 9	1:2 ft²
Dens Deck, Dens Deck Prime Minimum ¼" thick	3, 5, 7 or 9	1:1.77 ft²

Base Sheet: (Optional) Install one ply of All Weather/Empire, Flex-I-Glas or GlasBase base sheet directly over the top layer of insulation. Adhere with any approved mopping asphalt at an application rate of 20-35 lbs./sq.

Ply Sheet: Two or more plies of Flintglas Ply Sheet (Type IV), Flintglas Premium Ply Sheet (Type VI) or #15 Asphalt Perforated Felt ply sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.

Cap Sheet: (Optional) One ply of Flintglas Mineral Surface Cap Sheet or Flintglas Mineral Surfaced Cap CoolStar adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.



Surfacing:

(Required if no cap sheet is used) Install one of the following:

1. Flood coat of hot asphalt with an application rate of 60 lbs./sq. \pm 20%; plus gravel or slag with an application rate of 400 lbs./sq. & 300 lbs./sq., respectively.
2. A two part coating consisting of a base coat of Static Asphalt Fibered Emulsion at rate of 3 gal./sq. or Monoform compound; surfaced with 1 gal./sq. Sta-Kool non-fibered aluminum coating or fibered APOC No. 212.

Maximum Design
Pressure:

-45 psf (See General Limitation #9)



NOA No.: 08-0410.02
Expiration Date: 04/28/13
Approval Date: 10/30/08
Page 10 of 12

Deck Type 6: Poured Gypsum Concrete, Non-insulated

Deck Description: Poured gypsum concrete

System Type E: Base sheet mechanically fastened.

All General and System limitations apply.

Base sheet: All Weather/Empire, Flex-I-Glas, Flex-I-Glas FR, GlasBase or Poly SMS base sheet installed as noted below.

Fastening #1: (Poly SMS only) Nail-Tite Type A or Type R with minimum 1-5/8" diameter head or Simplex Base-Lok fasteners with minimum 1-5/8" diameter plate spaced 9" o.c. in min. 2" side lap and two staggered rows in center of the sheet, 18" o.c.
(Maximum Design Pressure –52.5 psf, See General Limitation #9.)

Fastening #2: Nail-Tite Type A or Type R with FM-30 discs or FM-90 Base Ply Fasteners or Simplex Base-Lok fasteners with minimum 3" diameter plate spaced 9" o.c. in min. 2" side lap and two staggered rows in center of the sheet, 18" o.c.
(Maximum Design Pressure –52.5 psf, See General Limitation #9.)

Fastening #3: Nail-Tite Type A or Type R with FM-30 discs or FM-90 Base Ply Fasteners or Simplex Base-Lok fasteners with minimum 3" diameter plate spaced 7½" o.c. in min. 2" side lap and one row in center of the sheet, 7½" o.c.
(Maximum Design Pressure –45 psf, See General Limitation #9.)

Fastening #4: Nail-Tite Type A or Type R with FM-30 discs or FM-90 Base Ply Fasteners or Simplex Base-Lok fasteners with minimum 3" diameter plate spaced 9" o.c. in min. 2" side lap and two staggered rows in center of the sheet, 12" o.c.
(Maximum Design Pressure –60 psf, See General Limitation #9.)

Ply Sheet: Two or more plies of Flintglas Ply Sheet (Type IV), Flintglas Premium Ply Sheet (Type VI) or #15 Asphalt Perforated Felt ply sheet adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.

Cap Sheet: (Optional) One ply of Flintglas Mineral Surface Cap Sheet or Flintglas Mineral Surfaced Cap CoolStar adhered in a full mopping of approved asphalt at an application rate of 20-35 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. Flood coat of hot asphalt with an application rate of 60 lbs./sq. ± 20%; plus gravel or slag with an application rate of 400 lbs./sq. & 300 lbs./sq., respectively.
2. A two part coating consisting of a base coat of Static Asphalt Fibered Emulsion at rate of 3 gal./sq. or Monoform compound; surfaced with 1 gal./sq. Sta-Kool non-fibered aluminum coating or fibered APOC No. 212.

Maximum Design Pressure: See Fastening Options Above.



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

END OF THIS ACCEPTANCE



NOA No.: 08-0410.02
Expiration Date: 04/28/13
Approval Date: 10/30/08
Page 12 of 12