



BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 372-6339

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/buldingcode

Sun-Tek Manufacturing, Inc.
10303 General Drive.
Orlando, Florida 32824

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Sun-Tek Tubular Skylight.

APPROVAL DOCUMENT: Drawing No. **22001**, titled "Tubular Skylights", sheets 1 through 7 of 7, prepared by Sun-Tek Industries, Inc., dated 09/21/98, 04 & 11/19/99, 11/20/99 & 09/20/90 with last revision on 10/01/96, signed and sealed by M. Martinez, P.E., bearing the Miami-Dade County Product Control renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **renews NOA # 03-0407.10** and consists of this page 1 and evidence page E-1, as well as approval document mentioned above.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**



[Handwritten Signature]
4/27/08

NOA No 08-0417.01
Expiration Date: May 26, 2009
Approval Date: May 22, 2008
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Drawing No. **22001**, titled "Tubular Skylights", sheets 1 through 7 of 7, prepared by Sun-Tek Industries, Inc., dated 09/21/98, 04 & 11/19/99, 11/20/99 & 09/20/90 with last revision on 10/01/96, signed and sealed by M. Martinez, P.E.
"Evidence submitted under NOA # 03-0407.10"

B. TESTS

1. Test report on Large Missile Impact Test, Cyclic Load Test and Uniform Static air Pressure Test on "Model 21 tube light polycarbonate Dome Skylight", prepared by National Certified Testing Laboratories, report No. NCTL 210-2195 (1-3), issued on 05/25/99, signed and sealed by B. D. Portnoy, P.E.
2. Test report on Large Missile Impact Test and Cyclic Load Test on "Model 21 tube light polycarbonate Dome Skylight", prepared by National Certified Testing Laboratories, report No. NCTL 210-2275 (1-3), issued on 01/03/00, signed and sealed by B. D. Portnoy, PE.
"Evidence submitted under NOA # 03-0407.10"

C. CALCULATIONS


1. Anchor calculations prepared by Product & Application Engineering, Inc. on 02/21/00, sheets 1 to 6, signed and sealed by M. Martinez, P.E.
2. Anchor calculations prepared by Product & Application Engineering, Inc. on 07/12/98, sheets 1 to 5, signed and sealed by M. Martinez, P.E.
"Evidence submitted under NOA # 03-0407.10"

D. QUALITY ASSURANCE

1. Miami Dade Building Code Compliance Office (BCCO)

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. 98-0515.03, issued to DSM Engineering Plastics Products, Inc., on 08/27/98 expiring on 08/27/2001.
"Evidence submitted under NOA # 03-0407.10"



4/27/08

Carlos M. Utrera, P.E.
Product Control Examiner
NOA No 08-0417.01
Expiration Date: May 26, 2009
Approval Date: May 22, 2008

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

F. STATEMENTS


1. No financial interest letter issued by Sun-Tek Skylights, on 08/04/99, signed by J. Feudner and notarized by M. A. Moore on 08/04/99.
2. Test compliance letter issued by National Certified Testing Laboratories, on 01/04/00, signed and sealed by B. Portnoy, PE.
3. No change letter issued on 06/23/03 by Sun-Tek Skylights and signed by J. Feudner.
“Evidence submitted under NOA # 03-0407.10”

G. OTHER

1. Notice of Acceptance No. **03-0407.10**, issued to Sun-Tek Manufacturing, Inc., approved on 07/24/03 and expiring on 05/26/08.
2. Proposed testing letter issued by National Certified Testing Laboratories, dated 03/27/08, signed Christopher Bennett.




Carlos M. Utrera, P.E.
Product Control Examiner
NOA No 08-0417.01
Expiration Date: May 26, 2009
Approval Date: May 22, 2008



NOTE:
(1) ALL ROOFING DETAILS SHALL COMPLY WITH CHAPTER 34 OF THE SOUTH FLORIDA BUILDING CODE.
(2) 4" MINIMUM DISTANCE FROM ANGLE LIP TO ROOF SURFACE IS FOR SHINGLE OR BUILT - UP ROOF WITH OUT INSULATION. FOR INSULATION AND TILE ADD THE TILE HEIGHT AND THE INSULATION THICKNESS TO THE 4" MINIMUM HEIGHT.

CURB TO DECK MOUNTING REQUIREMENTS
#10 X 2-1/2" DECK SCREWS
21" - 4 PER SIDE 16 TOTAL
POSITIVE DESIGN LOAD 65 PSF
NEGATIVE DESIGN LOAD 65 PSF
WATER TEST PRESSURE 15 PSF
DOME MATERIAL HYZOD 'SL'
ACCEPTANCE No. 98-0515.03



PRODUCT RENEWED
as complying with the Florida Building Code
Acceptance No. 03-0407.10
Expiration Date 05/26/08
By: [Signature]
Miami Dade Product Control Division

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE
DATE: May 26, 2000
BY: [Signature]
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 99-0823.03

PRODUCT RENEWED
as complying with the Florida Building Code
Acceptance No. 02-0417.01
Expiration Date 05/26/08
By: [Signature]
Miami Dade Product Control Division




REVISION:	REVISION:	PRODUCT NAME:	21" TUBE LIGHT
INI:	DATE:	INI:	DATE:
		DATE: 09/21/98	SCALE:
			DWG No. 22001

SUN-TEK INDUSTRIES, INC.

10303 GENERAL DRIVE
ORLANDO, FL 32824

6-12-00

NOTE:
MATERIAL .020 GALVANIZED SHEET



PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 08-0417.01
 Expiration Date 05/26/2009
 By *[Signature]*
 Miami Dade Product Control
 Division

APPROVED AS COMPLYING WITH THE
 SOUTH FLORIDA BUILDING CODE
 DATE 08/26/2000
 BY *[Signature]*
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 99-0823.03

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No. 03-0407.10
 Expiration Date 05/26/08
 By *[Signature]*
 Miami Dade Product Control
 Division

[Handwritten Signature]
 8-12-00


REVISION:	REVISION:
INI:	INI:
DATE:	DATE:

PRODUCT NAME:	TUBLAR SKYLIGHTS
DATE:	11/20/99
SCALE:	
DWG No.	22001

SUN-TEK
 INDUSTRIES, INC.

10303 GENERAL DRIVE
 ORLANDO, FL 32824

MATERIAL : HYZOD SL POLYCARBONATE
.187 THICK



PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 08-0417.01
Expiration Date 05/26/2009

[Signature]
Miami Dade Product Control
Division

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 03-0407.00
Expiration Date 03/26/08

[Signature]
Miami Dade Product Control
Division

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE May 26, 2000
BY: *[Signature]*
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 99-0823-03

[Signature]
6-12-00

REVISION:		REVISION:	
INI:	DATE:	INI:	DATE:


PRODUCT NAME:
CURB MOUNTED TUBULAR SKYLIGHT
DATE: 11/19/99 SCALE: DWG No. 22001

**SUN-TEK
INDUSTRIES, INC.**

10303 GENERAL DRIVE
ORLANDO, FL 32824

ITEM	PART NAME	DISCRIPTION	VENDOR
1	EXTERIOR DOME	HYZOD "SL" DOME	SHEFFIELD PLASTIC
2	* SEALING TAPE	DUCT TAPE 2"	VENTURE TAPE
3	* ELBOWS	EVERBRIGHT 95	ALCOA ALUMINUM
4	* CONNECTOR	EVERBRIGHT 95	ALCOA ALUMINUM
5	* GASKET	INTERIOR DOME	TEAM PLASTIC
6	* INTERIOR DOME	.125 PRISMATIC POLYCARBONATE	SHEFFIELD PLASTIC
7	* #6 X 1" PHS.	ANCHORS INTERIOR DOME	MERIT FASTENER
8	* SCREW COVERS	PLASTIC WHITE	OUTWATER PLASTIC
9	#10 PHS X 2"	FASTENERS EXTERIOR DOME	MERIT FASTENER
10	* #6 X1/2"HEX TEK	TUBE FASTENERS	MERIT FASTENER
11	#10 X2-1/2" DECK SCREWS	CURB ANCHORS	MERIT FASTENER
12	3/16 X3/8"RIVETS	DECO RING FASTENER	Mc MASTER-CARR
13	* .020 GALV.	TUBE RETAINER	
14	DECO RING	EXTRUSION	

* THIS APPROVAL IS LIMITED TO THE DOME AND THE ATTACHMENT TO THE STRUCTURE AND THE ROOF. ALL OTHERS ARE NOT PART OF THIS APPROVAL.



DOME SPECIFICATIONS

21" DOME HEIGHT 9"
14" DOME HEIGHT 7-1/8"
10" DOME HEIGHT 5-1/8"

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 03-0417.01
Expiration Date 05/26/2009
By [Signature]
Miami Dade Product Control
Division

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 03-0407.10
Expiration Date 03/26/08
By [Signature]
Miami Dade Product Control
Division

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE May 26, 2000
BY [Signature]
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 99-0823.03




[Signature]
6-12-00

REVISION:	REVISION:
INI:	INI:
DATE:	DATE:

PRODUCT NAME:	TUBULAR SKYLIGHT
DATE:	04/19/99
SCALE:	
DWG No.	22001

SUN-TEK
INDUSTRIES, INC.

10303 GENERAL DRIVE
ORLANDO, FL 32824



NOTE:
 (1) ALL ROOFING DETAILS SHALL COMPLY WITH CHAPTER 34 OF THE SOUTH FLORIDA BUILDING CODE.
 (2) 4" MINIMUM DISTANCE FROM ANGLE LIP TO ROOF SURFACE IS FOR SHINGLE OR BUILT - UP ROOF WITHOUT INSULATION. FOR INSULATION AND TILE ADD THE TILE HEIGHT AND INSULATION THICKNESS TO THE 4" MINIMUM HEIGHT. CURB TO DECK MOUNTING REQUIREMENTS
 #10 X 2-1/2" DECK SCREWS
 10" - 2 PER SIDE 8 TOTAL
 POSITIVE DESIGN LOAD 65 PSF
 NEGATIVE DESIGN LOAD 65 PSF
 WATER TEST PRESSURE 15 PSF
 DOME MATERIAL HYZOD 'SL'
 ACCEPTANCE No. 98-0515.03

PRODUCT RENEWED
 as complying with the Florida Building Code
 Acceptance No. 03-0407.10
 Expiration Date 05/26/08
 By: [Signature]
 Miami Dade Product Control Division

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE
 DATE May 30, 2000
 BY: [Signature]
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 99-0823.03




PRODUCT RENEWED
 as complying with the Florida Building Code
 Acceptance No. 08-0417.01
 Expiration Date 05/26/2009
 By: [Signature]
 Miami Dade Product Control Division

6-12-00

REVISION:	REVISION:
INI:	INI:
DATE:	DATE:

PRODUCT NAME:	10" TUBE LIGHT
DATE:	09/21/98
SCALE:	
DWG No.	22001

SUN-TEK INDUSTRIES, INC. 10303 GENERAL DRIVE ORLANDO, FL 32824



NOTE:
 (1) ALL ROOFING DETAILS SHALL COMPLY WITH CHAPTER 34 OF THE SOUTH FLORIDA BUILDING CODE.
 (2) 4" MINIMUM DISTANCE FROM ANGLE LIP TO ROOF SURFACE IS FOR SHINGLE OR BUILT - UP ROOF WITH OUT INSULATION. FOR INSULATION AND TILE ADD THE TILE HEIGHT AND THE INSULATION THICKNESS TO 4" MINIMUM HEIGHT.
 CURB TO DECK MOUNTING REQUIREMENTS:
 #10 X 2-1/2" DECK SCREWS
 14" - 3 PER SIDE 12 TOTAL
 POSITIVE DESIGN LOAD 65 PSF
 NEGATIVE DESIGN LOAD 65 PSF
 WATER TEST PRESSURE 15 PSF
 DOME MATERIAL HYZOD 'SL'
 ACCEPTANCE No. 98-0515.03

PRODUCT RENEWED
 as complying with the Florida Building Code
 Acceptance No. 03-0407.10
 Expiration Date 05/26/08
 By [Signature]
 Miami Dade Product Control Division

APPROVED AS COMPLYING WITH THE SOUTH FLORIDA BUILDING CODE
 DATE May 26, 2000
 BY [Signature]
 PRODUCT CONTROL DIVISION
 BUILDING CODE COMPLIANCE OFFICE
 ACCEPTANCE NO. 99-0823.03

PRODUCT RENEWED
 as complying with the Florida Building Code
 Acceptance No. 09-0417.01
 Expiration Date 05/26/2009
 By [Signature]
 Miami Dade Product Control Division

REVISION:	REVISION:	PRODUCT NAME:
INI:	DATE:	14" TUBE LIGHT
INI:	DATE:	DATE: 09/21/98 SCALE:
		DWG No. 22001

SUN-TEK INDUSTRIES, INC.

10303 GENERAL DRIVE
 ORLANDO, FL 32824