



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

**Elastomeric Roofing Systems  
6900 Bleck Drive  
Rockford, MN 55373**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: ER-Foam 903072-1 over Recover Deck.**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 5.

The submitted documentation was reviewed by Jorge L. Acebo



**NOA No.: 08-0715.07  
Expiration Date: 08/10/13  
Approval Date: 10/02/08  
Page 1 of 5**

**ROOFING SYSTEM APPROVAL**

Category: Roofing  
Sub-Category: Spray Applied Polyurethane Foam  
Material: Polyurethane Foam  
Deck Type: Recover  
Maximum Design Pressure -135 psf

**TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
ER-Foam 903072-1	3.0 lb/ft <sup>3</sup> density	TAS 110	Polyurethane spray applied foam that utilizes an HFC blowing agent intended for roofing applications.

**TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS:**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Manufacturer</u>
Any Miami-Dade County Approved Roof Coating	Various	As Required by Miami-Dade County PCA	Generic. (with current PCA)

**EVIDENCE SUBMITTED:**

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Trinity Engineering, Inc.	#4680.11.95-1	TAS 114 Appendix "D"	11/29/95
Underwriters Laboratories Inc.	R12134 (N)	UL 1897	12/09/93
	90NK28403	UL 790	03/22/91
Center for Applied Engineering	257497	TAS 129 - TAS 143	06/06/96
Celotex Corporation Testing Services	257994	ASTM E 96	04/23/97
		ASTM D 1623	
		ASTM C 273	
Factory Mutual	528639	ASTM D 2842	10/12/98
		ASTM D 2126	
		ASTM D 1621	
		ASTM D 1621	
Factory Mutual	3016938	4470	01/13/05
	3022954		03/24/05
	3026505		03/21/06



**AMBIENT HUMIDITY APPLICATION LIMITS SPRAYED POLYURETHANE FOAM:**

**Table 1**

Maximum Wet Bulb and Relative Humidity for a Given Dry Bulb Reading						
Dry Bulb Temp. (°F)	Wet Bulb Temp. (°F)	R.H. (%)		Dry Bulb Temp. (°F)	Wet Bulb Temp. (°F)	R.H. (%)
45	43	81		73	69	82
46	44	81		74	70	82
47	45	81		75	71	82
48	46	81		76	72	82
49	47	81		77	73	82
50	48	81		78	73	82
51	48	81		79	74	82
52	49	81		80	75	82
53	50	81		81	76	82
54	51	81		82	77	82
55	52	81		83	78	82
56	52	81		84	79	82
57	53	81		85	80	82
58	54	81		86	81	82
59	55	81		87	82	82
60	56	81		88	83	82
61	57	81		89	84	82
62	58	82		90	85	82
63	59	82		91	86	82
64	60	82		92	87	82
65	61	82		93	88	82
66	62	82		94	89	82
67	63	82		95	90	82
68	64	82		96	91	82
69	65	82		97	92	82
70	66	82		98	93	82
71	67	82		99	94	82
72	68	82		100	95	82

**NOTE: ER Foam 903072-1 shall not be sprayed when environmental conditions are beyond the temperature and relative humidity limits listed in this Table, (see System Limitations 1).**



NOA No.: 08-0715.07  
 Expiration Date: 08/10/13  
 Approval Date: 10/02/08

**APPROVED SYSTEMS:**

- Deck Type 7:** Recover
- Deck Description:** Wood, Steel, Concrete, Granule Surfaced Modified Bitumen, Smooth Surface BUR
- System Type:** Sprayed polyurethane foam covered with an approved coating.

**All General and System Limitations apply.**

**Deck Requirements:** Deck and attachment thereof shall be in compliance with the relevant decking Chapter of the Florida Building Code.

**Surface Preparation:** For recover applications, existing roof shall be in compliance with applicable Building Codes and Roofing Application Standard RAS 109.

Substrate shall be free of loose dirt, grease, oil or other contaminants prior to priming or foam application. Remove loose dirt or debris by use of compressed air, vacuum or brooming. No washing shall be permitted. Oil, grease, release agents or other contaminants shall be removed with proper cleaning solutions.

Primers shall be applied in accordance with the manufacturers instructions. All primers must be thoroughly dry and cured prior to foam application.

**Polyurethane Foam Application:** The ER Foam 903072-1 shall be applied directly and uniformly over the entire surface at the specified thickness in compliance with the requirements set forth in Dade County Roofing Application Standard RAS 109. The sprayed ER Foam 903072-1 shall be feathered at the edges to produce a smooth transition.

**Protective Coating Application:  
(Choose One)** Apply a Miami-Dade County approved roof coating with a current NOA, that is compatible with this system and is applied in accordance with the guidelines listed in the products NOA.

ER Foam 903072-1 surface shall be free of moisture, dust, debris, oils, tars, grease or other materials that will impair adhesion of the protective coverings. Any damage or defects to the ER Foam 903072-1 surface shall be repaired prior to the coating application. The base coat shall be applied the same day as the foam when possible. If more than 72 hours elapse prior to the application of the base coat, the polyurethane foam shall be inspected for UV degradation.

**Maximum Design Pressure:** -135 psf; (See General Limitation #4).



### **SYSTEM LIMITATIONS:**

1. ER Foam 903072-1 foam shall not be sprayed when environmental conditions are beyond the temperature and relative humidity limits listed in Table 1 of this approval. Contractor shall monitor and record environmental conditions in job log in compliance with RAS 109. Job log shall be maintained at the job site and accessible to The Building Official.
2. Existing low slope roof systems shall be tested for uplift resistance in compliance with Testing Application Standard TAS 124 to the calculated design pressures of the field, perimeter and corner areas, determined in compliance with applicable Building Code.
3. Adhesion testing of foam to substrate and coating to foam shall be performed in compliance with Roofing Application Standard RAS 109.

### **GENERAL LIMITATIONS:**

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. All work shall performed by a Elastomeric Roofing Systems' trained and approved applicator familiar with the details and specifications published by Polythane Systems.
3. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
4. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).
5. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.: 08-0715.07  
Expiration Date: 08/10/13  
Approval Date: 10/02/08