



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Johns Manville Corporation
717 17th Street
Denver, CO 80202**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Johns Manville Built-Up Roofing Systems Over Gypsum Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 07-1126.06 and consists of pages 1 through 13.
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 08-0729.09
Expiration Date: 07/19/11
Approval Date: 10/23/08
Page 1 of 13**

ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub-Category: Built-up Roofing
Deck Type: Poured Gypsum
Maximum Design Pressure -75 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Bestile Flashing Cement		ASTM D 4586	A trowel grade, cutback bitumen flashing grade cement mixture including inorganic fibers and mineral stabilizers.
DynaClad	39-3/8" x 33' 10"	N/A	A foil surfaced fiberglass reinforced elastomeric modified bitumen membrane for use as a cap or flashing sheet.
DynaFlex	36" x 25' long	ASTM D 5147	SBS modified bitumen composite flashing with fiber glass scrim and two-ply polyester reinforcement, for use in conventional and modified bitumen built-up roofing assemblies for base flashings.
Expand-O-Flash	Various	N/A	Expansion joint covers manufactured from non-reinforced, form-supported elastomeric bellows with a bifurcated waterproof attachment to metal flanges. Available in various standard configurations and may be custom manufactured to specific dimensions.
Expand-O-Guard	Various	N/A	Elastomeric expansion joint cover for vertical expansion and seismic joints. Manufactured from non-reinforced, form-supported elastomeric bellows with a bifurcated waterproof attachment to metal flanges. Available in various standard configurations and may be custom manufactured to specific dimensions.
FP-10 Vents	10" deck flange, base diameter of 4" and a height of 6".	N/A	One-way roof vent, designed for use in various roof systems, for the release of pressure created by gases or moisture vapor trapped within the roofing system.
FesCant Plus Cant Strips, and Taper Edge.	Various	TAS 110	Factory pre-fabricated cant strips and taper edge, manufactured from expanded perlite insulation.



NOA No.: 08-0729.09
 Expiration Date: 07/19/11
 Approval Date: 10/23/08
 Page 2 of 13

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Flex-I-Drain	Various sizes from 3" to 6"	BOCA 76-61 SBCCI 89204 UBC 3236	Two piece flexible drain system composed of a Noryl deck flange, a flexible neoprene bellows and no hub connection. Available in various sizes and styles for most retro-fit applications.
GlasBase Plus	36" x 108'	ASTM D 4601	Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
GlasKap	36" x 36'	ASTM D 3909	Asphalt impregnated and coated felt surfaced with mineral granules used as the top ply in conventional built-up roof membranes.
GlasKap CR	36" x 36'	ASTM D 3909	White mineral surfaced, white acrylic coated, fiber glass cap sheet for use as the top ply in conventional built-up roof membranes
GlasKap Plus	39-3/8" x 34'	ASTM D 5147	SBS Modified Asphaltic cap sheet used as the top ply in conventional built-up roof membranes.
GlasPly IV	36" x 177'	ASTM D 4601 Type IV	Type IV asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.
GlasPly Premier	36" x 177'	ASTM D 2178 Type VI	Type VI asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.
GlasTite Flexible	36" x 25' long	ASTM D 1668	Asphalt composite flashing with fiberglass scrim and two-ply polyester reinforcement, for use in conventional built-up roofing assemblies for base flashings.
Bestile Industrial Roof Cement	N/A	ASTM D 4586 Type II	General purpose medium trowel grade, cement cutback asphalt mastic reinforced with non-asbestos fibers and mineral stabilizers.
MBR Flashing Cement Activator	N/A	Proprietary	Activator component for use with MBR Flashing Cement Base
MBR Flashing Cement Base	N/A	Proprietary	A two-component elastomeric, cold application adhesive, consisting of a modified proprietary compound with an asphalt base.
MBR Utility Cement	N/A	ASTM D 4586	General purpose trowel grade, cutback bitumen cement mixture including inorganic fibers and mineral stabilizers.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
PermaPly 28	36" x 108'	ASTM D 4601	Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
Presto Lok Fascia and Flashing System	Various	TAS 114	A multi-piece fascia and flashing system for built-up and modified bitumen roofing systems manufactured from aluminum or steel. Extender plates available for wide fascia applications. This assembly meets the criteria of FMRC 1-49 for wind resistance perimeter flashing.
Ventsulation Felt	36" x 36'	ASTM D 4897 Type II	Heavy duty fiber glass base sheet impregnated and coated on both sides with asphalt with or without fine mineral stabilizer. Surfaced on the bottom side with coarse mineral granules embedded in asphaltic coating.

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ENRGY 3, JM ISO 3, PSI-25	Isocyanurate Insulation.	Johns Manville
Fesco Foam, Dura Foam	Isocyanurate Insulation with perlite facer	Johns Manville
Retro-Fit Board, DuraBoard	A high-density perlite roof insulation.	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
ACFoam Composite	Isocyanurate Insulation with perlite facer	Atlas Roofing Corp.
ACFoam II	Isocyanurate Insulation	Atlas Roofing Corp.
Styrofoam	Extruded polystyrene insulation	Dow
Dens Deck	Silicon treated gypsum	G-P Products
Sturdi-Top	Wood fiber insulation board.	G-P Products
Wood Fiberboard	Regular wood fiber insulation	Generic
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic
Perlite Insulation Board	Perlite Insulation	Generic



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
Perlite/Urethane Composite	Perlite / urethane composite board insulation	Generic
Type X Gypsum	Gypsum Wallboard	Generic
XPS	Extruded polystyrene	Generic
Structodeck	High Density Wood Fiber insulation board.	Masonite
Multi-Max	Polyisocyanurate foam insulation	RMax, Inc.
Fiber Base	Asphalt coated wood fiber insulation	Temple Inland Forest Products Corp.

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Polymer Gyptec	Glass reinforced nylon gypsum & CWF decks fastener		OMG
2.	Polymer Gyptec Metal Plate	Square galvalume AZ55 steel plate	3" square	OMG
3.	Polymer Auger Fastener	Glass reinforced Nylon insulation fastener for gypsum & CWF decks.		Johns Manville
4.	NTB Plastic plate	Polypropylene plastic plate	3" round	Johns Manville
5.	NTB Plate	Round galvalume AZ55 steel plate	3" round	Johns Manville
6.	Powerlite Fastener	Glass reinforced Zytel Nylon insulation fastener for gypsum & CWF decks.		Powers Fasteners, Inc.
7.	Powerlite Plate	Round galvalume AZ55 steel plate	3" round	Powers Fasteners, Inc.
8.	Twin Loc-Nail	Base sheet fastener with integrated Plate.	2.7" dia. plate	ES Products, Inc.



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	J.I. # 3001629	Class 4470	09.10.98
	J.I. # 3D4A4.AM	Class 4470	09.28.98
	J.I. # 3000949	Class 4470	06.05.98
	J.I. # 3001482	Class 4470	08.11.98
	J.I. # OZ8A9.AM	Class 4470	09.10.98
	FMRC 1999	Current Insulation Fastening Requirements	01.01.99
	3009499	Class 4470	04.04.01
	3014090	Class 4470	09.05.02
	3012974	Class 4450	06.03.02
	3011248	Class 4470	11.01.02
	3026130	Class 4470	04.26.06
Trinity ERD	# 10390A.10.97-1	TAS 114	10.97
	# 4361-02.04-1	TAS 114	04.97
	# 10390A.12.97-1	TAS 114	12.97
	10391.01.03	TAS 114 / FM 4470	01.03
	J7670.06.08	ASTM D3909	06.16.08
Underwriters Laboratories, Inc.	R 10167 (N)	Fire Classification Listing	01.01.95
Dynatech Engineering, Inc.	4360.03.95-1	TAS 114	3.95
	4360.03.95-2	TAS 114	3.95
	4361.5.95-1	TAS 114	5.95
Independent Roof Testing & Consulting of South Florida, Inc.	IRT 99001.1.20.99	TAS 114	1.20.99
	IRT 99002.1.20.99		
	IRT 99003.1.20.99		
IRT-ARCON, Inc.	02-026	TAS 114	07.26.02
	02-011	TAS 114	02.06.02



APPROVED ASSEMBLIES

Membrane Type: BUR

Deck Type 6I: Poured Gypsum, Insulated

Deck Description: Poured Gypsum Concrete

System Type A: Anchor sheet mechanically fastened; one or more layers of insulation adhered with approved asphalt.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, JM ISO 3, Fesco Foam, Dura Foam Minimum 1.4" thick	N/A	N/A
Retro-Fit Board, DuraBoard Minimum 1/2" thick	N/A	N/A
Fesco Board Minimum 3/4" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
Tapered Fesco Board Tapered ENRGY 3, Tapered JM ISO 3 Minimum 3/4" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Anchor sheet: DynaBase, GlasBase Plus, Ventsulation Felt, PermaPly 28, GlasPly Premier or GlasPly IV base sheet applied to the deck as described below:

Fastening: *(Option #1)* One ply of GlasPly Premier fastened with ES Products 1.8" Twin Loc-Nail fasteners spaced 9" o.c. at the 3" side lap and two rows staggered 12" o.c. in the field.

(Maximum Design Pressure -75 psf, See General Limitation #7)

(Option #2) Any approved fastener listed in this approval (with a current PCA) for use in poured gypsum decks, attachment at 9" o.c. at the 4" side lap and two staggered rows of 12" in the center of the sheet.

(Maximum Design Pressure -55 psf, See General Limitation #9)



Base Sheet: (Optional) Install one ply of GlasBase, GlasBase Plus, PermaPly 28, GlasPly Premier or GlasPly IV directly over the top layer of insulation. Adhere in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; see General Limitation #4.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier Ply VI adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. 2-3 gallons/sq. TopGard A or B emulsion or 2 gallons/sq. aluminum coating. Coatings shall be applied according to the manufacturers' recommendations regarding specific application rates and weathering.
2. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: See Fastening Options Above



Membrane Type: BUR
Deck Type 6I: Poured Gypsum, Insulated
Deck Description: Poured Gypsum Concrete
System Type B: Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

All General and System limitations apply.
 One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, JM ISO 3 Minimum 1.3" thick	1, 3, 6 or 8	1:2.67 ft ²
Fesco Board, DuraBoard Minimum ¾" thick	1, 3, 6 or 8	1:2 ft ²
Note: Base layers of insulation shall be mechanically attached using the fastener density listed. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.		
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²

Any of the insulation listed for Base Layer, above

Retro-Fit Board, DuraBoard Minimum ½" thick	N/A	N/A
Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.		

Base Sheet: (Optional) Install one ply of GlasBase Plus, GlasPly Premier, GlasPly IV or PermaPly 28 directly to the insulated substrate. Adhere in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; see General Limitation #4.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. 2-3 gallons/sq. TopGard A or B emulsion or 2 gallons/sq. aluminum coating. Coatings shall be applied according to the manufacturers' recommendations regarding specific application rates and weathering.
2. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -55 psf (See General Limitation #9)



Membrane Type: BUR
Deck Type 6I: Poured Gypsum, Insulated
Deck Description: Poured Gypsum Concrete
System Type C: All layers of insulation simultaneously fastened.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3, JM ISO 3 Minimum 1.4" thick	N/A	N/A
Fesco Foam, Dura Foam Minimum 1.5" thick	N/A	N/A
Fesco Board, DuraBoard Minimum ¾" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3, JM ISO 3 Minimum 1.3" thick	1, 6 or 8	1:2.67 ft ²
Fesco Board Minimum ¾" thick	1, 3, 6 or 8	1:2.67 ft ²
Retro-Fit Board, DuraBoard Minimum ½" thick	1, 3, 6 or 8	1:2.67 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) Install one ply of DynaBase, GlasBase Plus or PermaPly 28 directly over the top layer of insulation. Adhere in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; see General Limitation #4.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. 2-3 gallons/sq. TopGard A or B emulsion or 2 gallons/sq. aluminum coating. Coatings shall be applied according to the manufacturers' recommendations regarding specific application rates and weathering.
2. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -55 psf (See General Limitation #9)



NOA No.: 08-0729.09
 Expiration Date: 07/19/11
 Approval Date: 10/23/08
 Page 10 of 13

Membrane Type: BUR

Deck Type 6: Poured Gypsum, Non-Insulated

Deck Description: Poured gypsum concrete.

System Type E(1): Base sheet mechanically fastened.

All General and System Limitations apply.

Base Sheet: One ply of GlasPly Premier fastened to the deck as described below:

Fastening : Attach base sheet with ES Products 1.8" Twin Loc-Nail fasteners spaced 9" o.c. at the 3" side lap and two rows staggered 12" o.c. in the field.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier ply sheet adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. 2-3 gallons/sq. TopGard A or B emulsion or 2 gallons/sq. aluminum coating. Coatings shall be applied according to the manufacturers' recommendations regarding specific application rates and weathering.
2. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design

Pressure: -75 psf (See General Limitations #7).



Membrane Type: BUR
Deck Type 6: Poured Gypsum, Non-Insulated
Deck Description: Poured gypsum concrete.
System Type E(2): Base sheet mechanically fastened.

All General and System limitations apply.

Base Sheet: Install one ply of DynaBase, Ventsulation Felt, GlasBase Plus, GlasPly Premier, GlasPly IV or PermaPly 28 base sheet mechanically fastened as described below.

Fastening: Any approved fastener listed in this approval (with a current PCA) for use in gypsum decks, attachment at 9" o.c. at the lap and two staggered rows of 12" in the center of the sheet.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. 2-3 gallons/sq. TopGard A or B emulsion or 2 gallons/sq. aluminum coating. Coatings shall be applied according to the manufacturers' recommendations regarding specific application rates and weathering.
2. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -55 psf (See General Limitation #9)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.
Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

END OF THIS ACCEPTANCE



NOA No.: 08-0729.09
Expiration Date: 07/19/11
Approval Date: 10/23/08
Page 13 of 13