



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**South Florida Rolling Door, Inc.
8900 NW 119th Street
Hialeah Gardens, FL 33018**

Scope. This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida building Code including the High Velocity Hurricane Zone.

DESCRIPTION: 16' wide Roll-Up Door.

APPROVAL DOCUMENT: Drawing No. 07-162, dated 06/14/07 with last revision on 09/25/08, titled "16'-0" Max 0.031" Slat Roll-Up Door", sheets 1 through 3 of 3, prepared by Tilteco, Inc. signed and sealed by W. A. Tillit, PE, bearing the Miami-Dade County Product Control renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Large and Small Missile Impact

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **renews NOA # 07-0626.01** and, consists of this page, evidence page E1, as well as approval document mentioned above.

The submitted documentation was reviewed by **Mohammed Iqbal Shaikh, P.E.**



**NOA No. 08-0820.08
Expiration Date: 10/16/ 13
Approval Date: 11/06/08
Page 1**

South Florida Rolling Door, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE PAGE

A DRAWINGS:

Drawing No. 07-162, dated 06/14/07 with last revision on 09/25/08, titled "16'-0" Max 0.031" Slat Roll-Up Door", sheets 1 through 3 of 3, prepared by Tilteco, Inc. signed and sealed By Walter Tillit, P.E.

B TESTS:

1. Test report on Uniform Static Air Pressure per PA 202, Large Missile Impact Test per PA 201 and Cyclic Wind Pressure Test per PA 203 of "22 GA. ROLL- UP DOORS", prepared by Hurricane Test Laboratory, Inc., report No. 0204-0520-01, dated 05/31-06/14/01, signed and sealed by V. J. Abraham, PE.

C CALCULATIONS:

1. Calculations prepared by Tillit Testing & Engineering Company, sheets 1 to 26 for "16' Roll-Up Door", signed and sealed by W. A. Tillit, PE. on 06/25/01.
2. Calculations prepared by Tilteco Inc. sheets 1 through 6 of 16'0" Max 0.031" Slat Roll-Up Door, signed and sealed by W. A. Tillit PE on 09/30/05.

D QUALITY ASSURANCE:

1. Miami-Dade County. Building Code Compliance Office.

E STATEMENTS:

1. No Financial interest letter issued by Tilteco, Inc., on 09/25/08, signed and sealed by W. A. Tillit Jr. PE.
2. Code Compliance letter issued by Tilteco, Inc., on 09/25/08, signed and sealed by W. A. Tillit, Jr. PE.
3. Letter from Walter Tillit, P.E. stating that he is the Engineer of Record for this product and he continues to be in the business

F MATERIAL CERTIFICATIONS:


1. Test Report on Tensile Test per ASTM E-8, of 1 sample Job # 0204-0520-01 (Specimen # 1), prepared by Q. C. Metallurgical, dated 07/06/01, signed and sealed by R. Kelly.
2. Report of Test and Analysis prepared by Bethlehem Steel Corporation, dated 06/28/2000 and signed by C. R. Richard.
3. Product Control Notice of Acceptance issued to Dylast Products, LLC. on 02/28/08, expiring on 01/11/12.

G OTHERS:

1. NOA# 07-0626.01




Mohammed Iqbal Shaikh, P.E.
Senior Building Code Compliance Specialist
NOA No. 08-0820.08
Expiration Date: 10/16/13
Approval Date: 11/06/08




TYPICAL DOOR ELEVATION
N.T.S.

SECTION A-A
N.T.S.

② INSULATED FLAT SLAT
SCALE: 1/2"=1"



SECTIONS C-C
SCALE: 1/4"=1"



SECTIONS B-B
SCALE: 1/4"=1"

GENERAL NOTES:

1- ROLL-UP DOOR SHOWN ON THIS PRODUCT APPROVAL DOCUMENT (P.A.D.) HAS BEEN VERIFIED FOR CODE COMPLIANCE IN ACCORDANCE WITH THE 2004 EDITION OF THE FLORIDA BUILDING CODE WITH THE 2005 AND 2006 SUPPLEMENTS. DESIGN WIND LOADS SHALL BE DETERMINED AS PER SECTION 1620 OF THE ABOVE MENTIONED CODE. ROLL-UP DOOR'S ADEQUACY FOR IMPACT AND FATIGUE RESISTANCE HAS BEEN VERIFIED IN ACCORDANCE WITH SECTION 1609.1.4 OF THE ABOVE MENTIONED CODE AS PER HTL REPORT # 0204-0520-01, PER TAS-201, TAS-202 & TAS-203 PROTOCOLS.

DESIGN PRESSURE RATING: +60.0, -60.0 PSF

2- SLAT TO BE A.S.T.M. A-653 GR 50 STRUCTURAL QUALITY STEEL WITH A MINIMUM Fy=50.0 KSI AND G-90 GALVANIZING PER A.S.T.M. A-653, OR A.I.S.I. 304 SERIES STAINLESS STEEL MANUFACTURED WITH A MINIMUM YIELD STRENGTH OF Fy=50.0 KSI.

3- ALL STEEL ANGLES AND CHANNELS TO BE A.S.T.M. A-36 DESIGNATION, SHOP PRIMED AGAINST CORROSION PRIOR TO INSTALLATION.

4- ALL ASSEMBLY BOLTS TO BE S.A.E. GRADE 2 CADMIUM PLATED OR GALVANIZED STEEL.

5- STEEL WINDBARS TO BE A.S.T.M. A-36 DESIGNATION, SHOP PRIMED PRIOR TO INSTALLATION.

6- WINDLOCKS TO BE CAST IRON AS PER A.S.T.M. A47 GRADE 32510 WITH A MINIMUM TENSILE STRENGTH OF 50000 PSI., AND A MINIMUM YIELD STRENGTH OF 32500 PSI.

7- HOOD TO BE 24 GA. A.S.T.M. A-653 DESIGNATION G-90 FINISH TYPE COATING.

8- ALL RIVETS TO BE A.I.S.I. 1006 STEEL, CADMIUM PLATED, STAINLESS STEEL OR ZINC PLATED, WITH Fy=37,000 psi.

9- CONCRETE ANCHORS TO BE AS MANUFACTURED BY HILTI, INC AND SHALL BE INSTALLED FOLLOWING ALL OF THE RECOMMENDATIONS AND SPECIFICATIONS OF THE ANCHOR'S MANUFACTURER.

10- ALL WELDING TO CONFORM TO AMERICAN WELDING SOCIETY'S AWS D1.1 REGULATIONS. USE A.W.S. A5.1 OR A5.5 E60XX ELECTRODES WITH MIN. 3/16" FILLET SIZE.

11- INSULATION MATERIAL SHALL BE EPS-EXPANDED POLYSTYRENE INSULATION, MANUFACTURED BY DYPLAST PRODUCTS LLC., NOTICE OF ACCEPTANCE # 07-1107.08.

12- THIS DOOR MAY BE INSTALLED WITH SLATS CONCAVE SIDE FACING OUTSIDE OR INSIDE OF BUILDING.

13- IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY THAT THE EXISTING STRUCTURE IS DESIGNED TO SUPPORT Vx AND Vy FORCES AT BOTH JAMBS. SEE SHEET 3 OF 3, TABLE 1 FOR Vx & Vy VALUES.

14- ROLL-UP MECHANISM NOT PART OF THIS APPROVAL, BUT SHALL BE CERTIFIED BY AN INDEPENDENT TESTING AGENCY.

15- (A) THIS P.A.D. PREPARED BY THIS ENGINEER IS GENERIC AND DOES NOT PROVIDE INFORMATION FOR A SITE SPECIFIC PROJECT; I.E. WHERE THE SITE CONDITIONS DEVIATE FROM THE P.A.D.

(B) CONTRACTOR TO BE RESPONSIBLE FOR THE SELECTION, PURCHASE AND INSTALLATION INCLUDING LIFE SAFETY OF THIS PRODUCT BASED ON THIS P.A.D. PROVIDED HE/SHE DOES NOT DEVIATE FROM THE CONDITIONS DETAILED ON THIS DOCUMENT. CONSTRUCTION SAFETY AT SITE IS THE CONTRACTOR'S RESPONSIBILITY.

(C) THIS P.A.D. WILL BE CONSIDERED INVALID IF MODIFIED.

(D) SITE SPECIFIC PROJECTS SHALL BE PREPARED BY A FLORIDA REGISTERED ENGINEER OR ARCHITECT WHICH WILL BECOME THE ENGINEER OF RECORD (E.O.R) FOR THE PROJECT AND WHO WILL BE RESPONSIBLE FOR THE PROPER USE OF THE P.A.D.


(E) THIS P.A.D. SHALL COMPLY WITH SECTION 2: 61G15 OF THE FLORIDA ADMINISTRATIVE CODE.

F.B.C. (High Velocity Hurricane Zone)

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No 08-0820-08
Expiration Date 10/16/13
By [Signature]
Miami Dade Product Control
Division


 TILTECO INC. TILLIT TESTING & ENGINEERING COMPANY 6355 N.W. 36th St., Ste. 305, VIRGINIA GARDENS, FL 33166 Phone: (305)871-1530, Fax: (305)871-1531 EB-0006719 WALTER A. TILLIT Jr. P. E. FLORIDA Lic. # 44167		16'-0" Max. 0.031" SLAT ROLL-UP DOOR		I.A./F.P. DRAWN BY:		
		SOUTH FLORIDA ROLLING DOOR, INC. 8900 N.W. 119th STREET HIALEAH GARDENS, FLORIDA 33018 PHONE: (305) 362-9477, FAX: (305) 362-9417		06/14/07 DATE		
REV. NO		DESCRIPTION	DATE	REV. No	DESCRIPTION	DATE
1	OLD 05-304		06/14/07	3		
2	GENERAL NOTE # 11		09/25/08	4		
DRAWING No 07-162						
SHEET 1 OF 3						

SEP 25 2008




TYPICAL WINDLOCK W-1 DETAIL

SCALE : 3/8" = 1"



TYPICAL WINDLOCKS W - 2 DETAIL


SCALE : 3/8" = 1"



(ELEVATION)

DETAIL 1

SCALE : 3/16" = 1"



SECTION XI


③ BOTTOM BAR DETAIL

SCALE : 3/8" = 1"

SECTION X2

BOTTOM ANGLE DETAIL

SCALE : 3/8" = 1"



ELEVATION

BOTTOM BAR ③ W/ BRACKET

SCALE : 3/8" = 1"

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No 08-0820.08
Expiration Date 10/16/13
By *M. H. Hall*
Miami Dade Product Control
Division



F.B.C. (High Velocity Hurricane Zone)

SEP 25 2008

		16'-0" Max. 0.031" SLAT ROLL-UP DOOR				IA DRAWN BY:
		SOUTH FLORIDA ROLLING DOOR, INC. 8900 N.W. 119th STREET HIALEAH GARDENS, FLORIDA 33018 PHONE: (305) 362-9477, FAX: (305) 362-9417				06/14/07 DATE
TILIT TESTING & ENGINEERING COMPANY 8355 N.W. 36th St., Ste. 305, VIRGINIA GARDENS, FL 33186 Phone: (305)871-1530 Fax: (305)871-1531 EB-0006719 WALTER A. TILIT Jr. P. E. FLORIDA Lic. # 44167		REV. NO. DESCRIPTION DATE REV. No. DESCRIPTION DATE 1 OLD 05-304 06/14/07 3 2				07-162 DRAWING No
						SHEET 2 OF 3

Vx & Vy REACTIONS & ANCHOR SCHEDULE

MAXIMUM DESIGN LOAD (PSF)	DOOR WIDTH (Ft)	SLIP (In)	Vx (Lb/Ft)	Vy (Lb/Ft)	ANCHOR SPACING *		REQUIRED ENGAGEMENT (In)
					FOR Min. f'c = 3000 psi CONCRETE	FOR Min. f'c = 4000 psi CONCRETE	
+50.0, -50.0	10'-0"	1/8"	1229	250	12" O.C.	12" O.C.	2 1/16"
	12'-0"	1/4"	1379	300	10 1/2" O.C.	12" O.C.	2 3/16"
	14'-0"	7/16"	1467	350	9 1/2" O.C.	11" O.C.	2 3/8"
	16'-0"	11/16"	1537	400	9" O.C.	10 1/2" O.C.	2 5/8"
+60.0, -60.0	10'-0"	1/8"	1677	300	9" O.C.	10 1/2" O.C.	2 1/16"
	12'-0"	1/4"	1795	360	8 1/2" O.C.	9 1/2" O.C.	2 3/16"
	14'-0"	7/16"	1864	420	7 1/2" O.C.	9" O.C.	2 3/8"
	16'-0"	11/16"	1923	480	7" O.C.	8 1/2" O.C.	2 5/8"



* HILTI HSL-R M16 W/ 4 1/8" MINIMUM EMBEDMENT DEPTH & 6 1/4" Min. EDGE DISTANCE.

PRODUCT REVIEWED
 in compliance with the Florida
 Building Code
 Acceptance No. 08-0820-08
 Expiration Date 12/16/13
 By *M. Thaler*
 Miami Dade Product Control
 Division

F.B.C. (High Velocity Hurricane Zone)

 TILTECO INC. <small>TILLIT TESTING & ENGINEERING COMPANY 6355 N.W. 38th St., Ste. 305, VIRGINIA GARDENS, FL 33188 Phone: (305)871-1530 • Fax: (305)871-1531 EB-0006719 WALTER A. TILLIT Jr. P. E. FLORIDA Lic. # 44167</small>	16'-0" Max. 0.031" SLAT ROLL-UP DOOR	LA DRAWN BY:
	SOUTH FLORIDA ROLLING DOOR, INC. <small>8900 N.W. 119th STREET HIALEAH GARDENS, FLORIDA 33018 PHONE: (305) 362-9477, FAX: (305) 362-9417</small>	06/14/07 DATE
		07-162 DRAWING No
		SHEET 3 OF 3

SEP 25 2008