



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

**IB Roof Systems  
2877 Chad Drive  
Eugene, OR 97408**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: IB Single Ply PVC Roof Systems over Lightweight Concrete Decks**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 06-1113.10 and consists of pages 1 through 13.  
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 08-1103.06  
Expiration Date: 03/16/11  
Approval Date: 12/31/08  
Page 1 of 13**

**ROOFING SYSTEM APPROVAL**

Category: Roofing  
Sub-Category: Single Ply  
Material: PVC  
Deck Type: Lightweight Concrete  
Maximum Design Pressure -242.5 psf

**TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:**

**TABLE 1**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
IB Single Ply		CGSB-37.54-95	Polyester reinforced PVC membrane.
IB Single Ply Fleecebacked		CGSB-37.54-95	Polyester reinforced PVC membrane with a non-woven polyester fleeceback.

**APPROVED INSULATIONS:**

**TABLE 2**

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
Pyrox	Isocyanurate Insulation	Apache Products Co.
ACFoam II, ACFoam III	Isocyanurate Insulation	Atlas Roofing Corp.
Polystyrene	Polystyrene insulation	Generic
DensDeck, DensDeck Prime, DensDeck DuraGuard	Gypsum insulation	GP Gypsum
ENRGY 2, ENERGY 3	Isocyanurate Insulation	Johns Manville
Securock	Gypsum insulation	US Gypsum

**EVIDENCE SUBMITTED:**

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Underwriters Laboratories, Inc.	UL 790	97NK38018	07/22/98
Underwriters Laboratories, Inc.	CGSB-37.54-95	02NK18635	11/12/03
Exterior Research & Design, LLC	03900.05.05-1	Wind Uplift, TAS 114 (FM Standard 4470)	05/19/05
Exterior Research & Design, LLC	02764.09.05	Wind Uplift, TAS 114 (FM Standard 4470)	09/09/05



NOA No.: 08-1103.06  
 Expiration Date: 03/16/11  
 Approval Date: 12/31/08  
 Page 2 of 13

**APPROVED ASSEMBLIES**

- Membrane Type:** Single Ply, Thermoplastic PVC, Insulated
- Deck Type 4I:** Lightweight Concrete
- Deck Description:** Min. 200 psi Mearlcrete, Celcore or Elastizell cellular LWC cast over concrete deck
- System Type A(1):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply.**

One or more layers of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam II, Multi-Max FA</b> Minimum 1.5" thick	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck, Securock</b> Minimum 0.25" thick	N/A	N/A

**Note: All insulation shall be adhered to the deck or subsequent layers of insulation in 3" to 3.5" wide beads 12" o.c. of TITE-SET Roofing Adhesive or Fastac Roofing Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** IB Single Ply or IB Single Ply Fleecebacked roof cover adhered to the insulation with Pliobond 7008 at 280 ft<sup>2</sup> per gallon.

**Maximum Design Pressure:** -117.5 psf (See General Limitation #9)



**Membrane Type:** Single Ply, Thermoplastic PVC, Insulated  
**Deck Type 4I:** Lightweight Concrete  
**Deck Description:** Min. 200 psi Elastizell cellular LWC cast over concrete deck  
**System Type A(2):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply.**

One or more layers of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam II, Multi-Max FA, ASTM C578</b> Minimum 1.5" thick	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck, Dens Deck Prime, Securock</b> Minimum 0.25" thick	N/A	N/A

**Note: All insulation shall be adhered to the deck or subsequent layers of insulation in 3" to 3.5" wide beads 12" o.c. of TITE-SET Roofing Adhesive or Fastac Roofing Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** IB Single Ply or IB Single Ply Fleecebacked roof cover adhered to the insulation with Pliobond 7008 at 280 ft<sup>2</sup> per gallon.

**Maximum Design Pressure:** -180 psf (See General Limitation #9)



**Membrane Type:** Single Ply, Thermoplastic PVC, Insulated  
**Deck Type 4I:** Lightweight Concrete  
**Deck Description:** Min. 200 psi Elastizell cellular LWC cast over concrete deck  
**System Type A(3):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply.**

One or more layers of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Type IX expanded polystyrene (min. 1.8 pcf) (Flat)</b> Minimum 1.5" thick	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck, Dens Deck Prime, Securock</b> Minimum 0.25" thick	N/A	N/A

**Note: All insulation shall be adhered to the deck or subsequent layers of insulation in 3" to 3.5" wide beads 12" o.c. of TITE-SET Roofing Adhesive or Fastac Roofing Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** IB Single Ply or IB Single Ply Fleecebacked roof cover adhered to the insulation with Pliobond 7008 at 280 ft<sup>2</sup> per gallon.

**Maximum Design Pressure:** -180 psf (See General Limitation #9)



**Membrane Type:** Single Ply, Thermoplastic PVC, Insulated  
**Deck Type 4I:** Lightweight Concrete  
**Deck Description:** Min. 200 psi Mearlcrete or Celcore cellular LWC cast over concrete deck  
**System Type A(4):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply.**

One or more layers of the following insulations:

	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam II, Multi-Max FA (Flat)</b> Minimum 1.5" thick	N/A	N/A

**Note: All insulation shall be adhered to the deck or subsequent layers of insulation in 3" to 3.5" wide beads 12" o.c. of TITE-SET Roofing Adhesive or Fastac Roofing Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** IB Single Ply or IB Single Ply Fleecebacked roof cover adhered to the insulation with Pliobond 7008 at 280 ft<sup>2</sup> per gallon.

**Maximum Design Pressure:** -215 psf (See General Limitation #9)



**Membrane Type:** Single Ply, Thermoplastic PVC, Insulated  
**Deck Type 4I:** Lightweight Concrete  
**Deck Description:** Min. 200 psi Celcore cellular LWC cast over concrete deck  
**System Type A(5):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply.**

One or more layers of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoamII, Multi-Max FA, ASTM C578</b> Minimum 1.5" thick	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck, Dens Deck Prime, Securock</b> Minimum 0.25" thick	N/A	N/A

**Note: All insulation shall be adhered to the deck or subsequent layers of insulation in 3" to 3.5" wide beads 12" o.c. of TITE-SET Roofing Adhesive or Fastac Roofing Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** IB Single Ply or IB Single Ply Fleecebacked roof cover adhered to the insulation with Pliobond 7008 at 280 ft<sup>2</sup> per gallon.

**Maximum Design Pressure:** -225 psf (See General Limitation #9)



**Membrane Type:** Single Ply, Thermoplastic PVC, Insulated  
**Deck Type 4I:** Lightweight Concrete  
**Deck Description:** Min. 200 psi Celcore cellular LWC cast over concrete deck  
**System Type A(6):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply.**

One or more layers of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Type IX expanded Polystyrene (min 1.8 pcf) (Flat)</b> Minimum 1.5" thick	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck, Dens Deck Prime, Securock</b> Minimum 0.25" thick	N/A	N/A

**Note: All insulation shall be adhered to the deck or subsequent layers of insulation in 3" to 3.5" wide beads 12" o.c. of TITE-SET Roofing Adhesive or Fastac Roofing Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** IB Single Ply or IB Single Ply Fleecebacked roof cover adhered to the insulation with Pliobond 7008 at 280 ft<sup>2</sup> per gallon.

**Maximum Design Pressure:** -222.5 psf (See General Limitation #9)



**Membrane Type:** Single Ply, Thermoplastic PVC, Insulated  
**Deck Type 4I:** Lightweight Concrete  
**Deck Description:** Min. 200 psi Mearlcrete cellular LWC cast over concrete deck  
**System Type A(7):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply.**

One or more layers of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoamII, Multi-Max FA, ASTM C578</b> Minimum 1.5" thick	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck, Dens Deck Prime, Securock</b> Minimum 0.25" thick	N/A	N/A

**Note: All insulation shall be adhered to the deck or subsequent layers of insulation in 3" to 3.5" wide beads 12" o.c. of TITE-SET Roofing Adhesive or Fastac Roofing Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** IB Single Ply or IB Single Ply Fleecebacked roof cover adhered to the insulation with Pliobond 7008 at 280 ft<sup>2</sup> per gallon.

**Maximum Design Pressure:** -240 psf (See General Limitation #9)



**Membrane Type:** Single Ply, Thermoplastic PVC, Insulated  
**Deck Type 4I:** Lightweight Concrete  
**Deck Description:** Min. 200 psi Mearlecrete cellular LWC cast over concrete deck  
**System Type A(8):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply.**

One or more layers of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Type IX expanded Polystyrene (min 1.8 pcf) (Flat)</b> Minimum 1.5" thick	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck, Dens Deck Prime, Securock</b> Minimum 0.25" thick	N/A	N/A

**Note: All insulation shall be adhered to the deck or subsequent layers of insulation in 3" to 3.5" wide beads 12" o.c. of TITE-SET Roofing Adhesive or Fastac Roofing Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** IB Single Ply or IB Single Ply Fleecebacked roof cover adhered to the insulation with Pliobond 7008 at 280 ft<sup>2</sup> per gallon.

**Maximum Design Pressure:** -240 psf (See General Limitation #9)



**Membrane Type:** Single Ply, Thermoplastic PVC, Insulated

**Deck Type 4:** Lightweight Concrete

**Deck Description:** Min. 200 psi Cellular LWC cast over steel or concrete deck

**System Type D(1):** Membrane mechanically attached through LWC to structural deck

**Deck:** 18-22 ga., type B, Grade 80 steel decking secured to minimum 0.25 in. thick structural steel supports spaced a maximum of 6 ft o.c. with ITW Buildex Traxx/5 fasteners as maximum of 6" o.c. at each structural steel support. The deck side laps are secured with ITW Buildex Traxx/1 fasteners a maximum of 24" o.c.

**Lightweight Concrete:** Min. 200 psi, approved cellular lightweight concrete deck applied with an optional minimum 1/8" slurry coat (required if EPS is used) followed by optional minimum 1" thick minimum 1.0 pcf Apache EPS Board or approved EPS board and a minimum 2" thick top coat.

**Barrier:** IB FireSheet, IB Separation Sheet, Atlas FR-50, or Elk Versashield 1S or 2S, loose laid.

**Membrane:** IB Single Ply mechanically fastened through the insulation as specified below:

**Fastening #1:** Install maximum 72" wide sheets with a 5" overlap fastened 6" o.c. using Olympic XHD Fasteners and XHD Plates or Dekfast #15 Fasteners, SFS Extra Load Fasteners and HS Plates. The roof cover outer 1-1/2" side lap is heat welded.  
**Maximum Design Pressure –60 psf (See General Limitation #7)**

**Fastening #2:** Install maximum 72" wide sheets with a 5" overlap fastened 12" o.c. using Olympic XHD Fasteners and XHD Plates or Dekfast #15 Fasteners, SFS Extra Load Fasteners and HS Plates. The roof cover outer 1-1/2" side lap is heat welded.  
**Maximum Design Pressure –45 psf (See General Limitation #7)**

**Maximum Design Pressure:** See Fastening Options Above



**Deck Type 4:** Lightweight Concrete, Non-insulated  
**Deck Description:** Min 200 psi, Cellular Lightweight Concrete  
**System Type F(1):** Membrane fully adhered to deck.

**All General and System Limitations apply.**

**Deck:** Minimum 2500 psi structural concrete  
**Lightweight Concrete:** Minimum 200 psi, Approved cellular lightweight concrete deck applied with an optional minimum 1/8" slurry coat (required if EPS is used) followed by optional minimum 1" thick minimum 1.0 pcf Apache EPS Board or approved EPS board and a minimum 2" thick top coat.  
**Membrane:** IB Single Ply or IB Single Ply Fleecebacked roof cover adhered to the lightweight concrete with Pliobond 7008 at 280 ft<sup>2</sup> per gallon.  
**Maximum Design Pressure:** -242.5 psf; (See General Limitation #9.)



## LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.  
**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117 and/or RAS 137.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
- 10 All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.: 08-1103.06  
Expiration Date: 03/16/11  
Approval Date: 12/31/08  
Page 13 of 13