



MIAMI-DADE COUNTY, FLORIDA
 METRO-DADE FLAGLER BUILDING
 140 WEST FLAGLER STREET, SUITE 1603
 MIAMI, FLORIDA 33130-1563
 (305) 375-2901 FAX (305) 372-6339

BUILDING CODE COMPLIANCE OFFICE (BCCO)
 PRODUCT CONTROL DIVISION

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/buildingcode

AWP, LLC
 8130 NW 74th Avenue
 Medley, FL 33166

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series "1700 Impact View" Aluminum Single Hung Window – L.M.I.

APPROVAL DOCUMENT: Drawing No. **W03-105**, titled "Series-1700 Impact View Alum Single Hung Wdw.", sheets 1 through 6 of 6, prepared by Al-Farooq Corporation, dated 11/19/03, with revision "E" dated 11/19/08, signed and sealed by Humayoun Farooq, P.E, bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises and renews** NOA # **07-1018.04** and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by **Fitz A. Harris, P.E.**

Fitz A. Harris

3.26.09



NOA No. 09- 0121.24
 Expiration Date: April 29, 2014
 Approval Date: April 15, 2009

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Manufacturer's die drawings and sections.
2. Drawing No **W03-105**, titled "Series-1700 Impact View Alum Single Hung Wdw.", sheets 1 through 6 of 6, prepared by Al-Farooq Corporation, dated 11/19/03, with revision "E" dated 11/19/08, signed and sealed by Humayoun Farooq, P.E.

B. TESTS

1. Test reports on:
 - 1) Air Infiltration Test, per FBC, TAS 202-94
 - 2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
 - 3) Water Resistance Test, per FBC, TAS 202-94
 - 4) Large Missile Impact Test per FBC, TAS 201-94
 - 5) Cyclic Wind Pressure Loading per FBC, TAS 203-94
 - 6) Forced Entry Test, per FBC 2411 3.2.1, TAS 202-94

Along with marked-up drawings and installation diagram aluminum single hung window, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-3822**, dated 07/10/03, signed and sealed by Joseph C. Chan, P.E.

"Submitted under NOA# 05-0311.01"

2. Test reports on:
 - 1) Air Infiltration Test, per FBC, TAS 202-94
 - 2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
 - 3) Water Resistance Test, per FBC, TAS 202-94
 - 4) Large Missile Impact Test per FBC, TAS 201-94
 - 5) Cyclic Wind Pressure Loading per FBC, TAS 203-94
 - 6) Forced Entry Test, per FBC 2411 3.2.1, TAS 202-94

Along with marked-up drawings and installation diagram aluminum single hung window, OXO configuration, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL- 4332**, dated 12/09/04, signed and sealed by Edmundo Largaespada, P.E. *(For Reference Only)*.

"Submitted under NOA# 05-0311.01"


C. CALCULATIONS

1. Anchor verification calculations and structural analysis, complying with FBC-2007, prepared by Al-Farooq Corporation, dated 12/01/08, signed and sealed by Humayoun Farooq, P.E.

Complies with ASTM E1300-02

D. QUALITY ASSURANCE

1. Miami Dade Building Code Compliance Office (BCCO).



Fitz A. Harris, P.E.

Product Control Examiner

NOA No. 09-0121.24

Expiration Date: April 29, 2014

Approval Date: April 15, 2009

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

E. MATERIAL CERTIFICATIONS


1. Notice of Acceptance No. **05-1208.02** issued to E.I. DuPont DeNemours Nemours & Co., Inc. for “**DuPont Butacite PVB**” dated January 5, 2006, expiring on December 11, 2010.
2. Notice of Acceptance No. **06-0216.06** issued to Solutia Inc. for their “**Saflex III G Clear or colored interlayer**” dated 05/04/06, expiring on 05/21/11.

STATEMENTS

1. Statement letter of conformance, dated December 1, 2008, signed and sealed by Humayoun Farooq, P.E.
2. Statement letter of no financial interest, dated December 1, 2008, signed and sealed by Humayoun Farooq, P.E.
3. Statement letter of compliance, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL- 4332**, dated 01/04/05, signed and sealed by Edmundo Largaespada, P.E.
4. Asset purchase agreement dated November 03, 2006, signed by Mr. Manuel Valladares and Mr. Leon Silverstein.

G. OTHER

1. Notice of Acceptance No. **07-1018.04** issued to AWP, LLC for their Series “1700 Impact View” Aluminum Single Hung Window – L.M.I.”, approved on 01/31/08 and expiring on 04/29/09.





Fitz A. Harris, P.E.

Product Control Examiner

NOA No. 09-0121.24

Expiration Date: April 29, 2014

Approval Date: April 15, 2009



TYPICAL ELEVATION
TESTED UNIT

SERIES-1700 IMPACT VIEW
ALUMINUM SINGLE HUNG WINDOW

DESIGN LOAD RATINGS FOR THESE WINDOWS TO BE AS PER CHARTS SHOWN ON SHEETS 2 & 3.

APPROVAL APPLIES TO SINGLE UNITS OR SIDE BY SIDE COMBINATIONS OF S.H./S.H. OR SINGLE HUNG WITH OTHER MIAMI-DADE COUNTY APPROVED WINDOWS USING MIAMI-DADE COUNTY APPROVED MULLIONS IN BETWEEN.

LOWER DESIGN PRESSURE FROM WINDOWS OR MULLION APPROVAL WILL APPLY TO ENTIRE SYSTEM.

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE 2004/2007 EDITION INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).

WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.

ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS, ANCHORS EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

ANCHORING OR LOADING CONDITIONS NOT SHOWN IN THESE DETAILS ARE NOT PART OF THIS APPROVAL.

A LOAD DURATION INCREASE IS USED IN DESIGN OF ANCHORS INTO WOOD ONLY.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF 2004/2007 FLORIDA BLDG. CODE SECTION 2003.8.4.

THESE WINDOWS ARE RATED FOR LARGE MISSILE IMPACT. SHUTTERS ARE NOT REQUIRED.

Engr: DR. HUMAYOUN FAROOQ
STRUCTURES
FLA. FE # 16557
C.A.N. 3538

MAR 24 2009

FLORIDA REVISOR
as complying with the Florida Building Code
Acceptance No 09-0121-24
Registration Date 4-29-2004
By *Ditz Harris*
Miami Dade Product Control
Division

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W03-105YO

SERIES-1700 IMPACT VIEW ALUM SINGLE HUNG WDW.
AWP, LLC.
8130 N.W. 74TH AVE.
MEDLEY, FL. 33166
TEL. (305) 887-2646 FAX (305) 883-1309

no	date	by	description
B	01.21.05		GLASS OPTIONS ADDED
C	05.18.06		UPDATED FOR 2004 FBC
D	10.01.07		MANF. NAME REV.
E	11.19.08		UPDATED FOR 2007 FBC
F	03.24.09		NO CHANGE THIS SHEET






date: 11-19-03
scale: 1/2"=1'-0"
dr. by: HAMID
chk. by:
drawing no. **W03-105**
sheet 1 of 6

EQUAL LITES WINDOWS DESIGN LOAD CAPACITY - PSF				
WINDOW DIMS.		GLASS TYPES 'A', 'C' OR 'D'		
WIDTH	HEIGHT	EXT.(+)	INT.(-)	
19-1/8"	26"	90.0	140.0	
26-1/2"		90.0	140.0	
32"		90.0	140.0	
37"		(4)	90.0	140.0
42"		90.0	140.0	
48"		90.0	140.0	
53-1/8"		90.0	140.0	
19-1/8"	38-3/8"	90.0	140.0	
26-1/2"		90.0	140.0	
32"		90.0	140.0	
37"		(4)	90.0	140.0
42"		90.0	140.0	
48"		90.0	140.0	
53-1/8"		90.0	127.1	
19-1/8"	50-5/8"	90.0	140.0	
26-1/2"		90.0	140.0	
32"		90.0	140.0	
37"		(6)	90.0	140.0
42"		90.0	140.0	
48"		90.0	140.0	
53-1/8"		90.0	139.7	
19-1/8"	63"	90.0	140.0	
26-1/2"		90.0	140.0	
32"		90.0	140.0	
37"		(6)	90.0	140.0
42"		90.0	140.0	
48"		90.0	128.6	
53-1/8"		90.0	116.2	
19-1/8"	74-1/4"	90.0	140.0	
26-1/2"		90.0	140.0	
32"		90.0	140.0	
37"		(6)	90.0	140.0
42"		90.0	124.7	
48"		90.0	109.1	
53-1/8"		90.0	98.6	
42"	63"	90.0	140.0	
48"		(7)	90.0	140.0
53-1/8"		90.0	135.5	
42"	74-1/4"	90.0	140.0	
48"		(7)	90.0	127.3
53-1/8"		90.0	115.0	

EQUAL LITES WINDOWS DESIGN LOAD CAPACITY - PSF				
WINDOW DIMS.		GLASS TYPES 'A', 'C' OR 'D'		
WIDTH	HEIGHT	EXT.(+)	INT.(-)	
19-1/8"	50-5/8"	90.0	140.0	
26-1/2"		90.0	140.0	
32"		90.0	140.0	
37"		(5)	90.0	140.0
42"		90.0	140.0	
48"		90.0	133.3	
53-1/8"		90.0	120.5	
19-1/8"	63"	90.0	140.0	
26-1/2"		90.0	140.0	
32"		90.0	140.0	
37"		(6)	90.0	140.0
42"		90.0	140.0	
48"		90.0	140.0	
53-1/8"		90.0	140.0	
19-1/8"	74-1/4"	90.0	140.0	
26-1/2"		90.0	140.0	
32"		(7)	90.0	140.0

* NO. IN PARENTHESIS INDICATE NO. OF ANCHORS PER JAMB.

WINDOWS WITHOUT SILL ANCHORS



GLAZING OPTIONS

NOTE:
GLASS CAPACITIES ON THIS SHEET ARE BASED ON ASTM E1300-02/04 (3 SEC. GUSTS) AND FLORIDA BUILDING COMMISSION DECLARATORY STATEMENT DCA05-DEC-219

Engr: DR. HUMAYCUN FAROOQ
STRUCTURES
FLA. PE # 16557
C.A.N. 3538
MAR 24 2009

PRODUCT REVIEWED
as complying with the Florida
Building Code
Acceptance No 09-0121-24
Expiration Date 4-29-2014
By *John Harris*
Miami Code Product Control
Division

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANI\W03-105YO


SERIES-1700 IMPACT VIEW ALUM SINGLE HUNG WDW.
AWP, LLC.
8130 N.W. 74TH AVE.
MEDLEY, FL. 33166
TEL. (305) 887-2646 FAX (305) 883-1309

no	date	by	description
B	01.21.05		GLASS OPTIONS ADDED
C	05.18.06		UPDATED FOR 2004 FBC
D	10.01.07		MANF. NAME REV.
E	11.19.08		NOTE REV.
F	03.24.09		REV. PER BCCO COMMENTS

date: 11-19-03
scale: 1/2" = 1"
dr. by: HAMID
chk. by:
drawing no.
W03-105
sheet 2 of 6

EQUAL LITES WINDOWS DESIGN LOAD CAPACITY - PSF			
WINDOW DIMS.		GLASS TYPES 'A', 'C' OR 'D'	
WIDTH	HEIGHT	EXT.(+)	INT.(-)
19-1/8"	26" (4)	90.0	140.0
26-1/2"		90.0	140.0
32"		90.0	140.0
37"		90.0	140.0
42"		90.0	140.0
48"		90.0	140.0
53-1/8"		90.0	140.0
19-1/8"	38-3/8" (4)	90.0	140.0
26-1/2"		90.0	140.0
32"		90.0	140.0
37"		90.0	140.0
42"		90.0	140.0
48"		90.0	140.0
53-1/8"		90.0	140.0
19-1/8"	50-5/8" (6)	90.0	140.0
26-1/2"		90.0	140.0
32"		90.0	140.0
37"		90.0	140.0
42"		90.0	140.0
48"		90.0	140.0
53-1/8"		90.0	139.7
19-1/8"	63" (6)	90.0	140.0
26-1/2"		90.0	140.0
32"		90.0	140.0
37"		90.0	140.0
42"		90.0	140.0
48"		90.0	140.0
53-1/8"		90.0	122.6
19-1/8"	74-1/4" (6)	90.0	140.0
26-1/2"		90.0	140.0
32"		90.0	140.0
37"		90.0	140.0
42"		90.0	140.0
48"		90.0	136.3
53-1/8"		90.0	113.6
42"	63" (7)	90.0	140.0
48"		90.0	140.0
53-1/8"		90.0	140.0
42"	74-1/4" (7)	90.0	140.0
48"		90.0	140.0
53-1/8"		90.0	135.4


* NO. IN PARENTHESIS INDICATE
NO. OF ANCHORS PER JAMB.



EQUAL LITES WINDOWS DESIGN LOAD CAPACITY - PSF			
WINDOW DIMS.		GLASS TYPES 'A', 'C' OR 'D'	
WIDTH	HEIGHT	EXT.(+)	INT.(-)
19-1/8"	50-5/8" (5)	90.0	140.0
26-1/2"		90.0	140.0
32"		90.0	140.0
37"		90.0	140.0
42"		90.0	140.0
48"		90.0	140.0
53-1/8"		90.0	140.0
19-1/8"	63" (6)	90.0	140.0
26-1/2"		90.0	140.0
32"		90.0	140.0
37"		90.0	140.0
42"		90.0	140.0
19-1/8"	74-1/4" (7)	90.0	140.0
26-1/2"		90.0	140.0
32"		90.0	140.0

* NO. IN PARENTHESIS INDICATE
NO. OF ANCHORS PER JAMB.

WINDOWS WITH
SILL ANCHORS



NOTE:
GLASS CAPACITIES ON THIS SHEET ARE
BASED ON ASTM E1300-02/04 (3 SEC. GUSTS)
AND FLORIDA BUILDING COMMISSION
DECLARATORY STATEMENT DCA05-DEC-219

Engr: DR. HUMAYUN FAROOQ
STRUCTURES
FLA. PE # 16557
C.A.N. 3538

MAR 24 2009

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 09-0121-24
Expiration Date 4-29-2014
By *Dity Harris*
Miami Date Product Control
Division





afC
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
12395 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W03-105YO

SERIES-1700 IMPACT VIEW ALUM SINGLE HUNG WDW.
AWP, LLC.
8130 N.W. 74TH AVE.
MEDLEY, FL. 33166
TEL. (305) 887-2646 FAX (305) 883-1309

no	date	description
B	01.21.05	GLASS OPTIONS ADDED
C	05.18.06	UPDATED FOR 2004 FBC
D	10.01.07	MANF. NAME REV.
E	11.19.08	NOTE REV.
F	03.24.09	NO CHANGE THIS SHEET

date: 11-19-03
scale: 1/2" = 1"
dr. by: HAMID
chk. by:

drawing no.
W03-105
sheet 3 of 6



WOOD BUCKS AND METAL STRUCTURE NOT BY AWP WDW. MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM AND TRANSFER THEM TO THE BUILDING STRUCTURE.

TYPICAL ANCHORS: SEE ELEV. FOR SPACING
1/4" DIA. ULTRACON BY 'ELCO' (Fu=177 KSI, Fy=155 KSI)
 INTO 2BY WOOD BUCKS OR WOOD STRUCTURES
 1-3/8" MIN. PENETRATION INTO WOOD
 THRU 1BY BUCKS INTO CONC. OR MASONRY
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY
 DIRECTLY INTO CONC. OR MASONRY
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY
1/4" DIA. SELF DRILLING SCREWS (GRADE 2 CRS)
 INTO METAL STRUCTURES
 STEEL : 12 GA. MIN. (Fy = 36 KSI MIN.)
 ALUMINUM : 1/8" THK. MIN. (6063-T5 MIN.)
 (STEEL IN CONTACT WITH ALUMINUM TO BE PLATED OR PAINTED)

#12 SMS OR SELF DRILLING SCREWS
 INTO MIAMI-DADE COUNTY APPROVED MULLIONS (MIN. THK. = .090")
 (NO SHIM SPACE)

TYPICAL EDGE DISTANCE
 INTO CONCRETE AND MASONRY = 2-1/2" MIN.
 INTO WOOD STRUCTURE = 1" MIN.
 INTO METAL STRUCTURE = 3/4" MIN.

CONCRETE f'c = 3000 PSI MIN.
 MASONRY f'm = 1500 PSI MIN.


PRODUCT REVISED
 as complying with the Florida
 Building Code
 Acceptance No 09-0121-24
 Expiration Date 4-29-2014
 By Jody Harris
 Miami Dade Product Control
 Division

SEALANTS:

FRAME AND VENT CORNERS AND INSTALLATION SCREWS AT SILL SEALED WITH WHITE/ALUMINUM COLORED SEALANT.

WEEPHOLES:

W1 = 3/4" WEEP NOTCH AT EACH END
 W2 = 1" WEEP NOTCH AT EACH END



Engr: DR. HUMAYOON FAROOQ
 STRUCTURES
 FLA. PE # 16557
 C.A.N. 3538
 MAR 24 2009

af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W03-105YO

SERIES-1700 IMPACT VIEW ALUM SINGLE HUNG WDW.
AWP, LLC.
 8130 N.W. 74TH AVE.
 MEDLEY, FL. 33166
 TEL. (305) 887-2646 FAX (305) 883-1309

no	date	by	description
B	01.21.05		GLASS OPTIONS ADDED
C	05.18.06		UPDATED FOR 2004 FBC
D	10.01.07		MANF. NAME REV.
E	11.19.08		NO CHANGE THIS SHEET
F	03.24.09		NO CHANGE THIS SHEET

date: 11-19-03
 scale: 1/2" = 1"
 dr. by: HAMID
 chk. by:

drawing no.
W03-105
 sheet 4 of 6

ITEM #	PART #	REQD.	DESCRIPTION	MATERIAL	MANF./SUPPLIER/REMARKS
1	YE-1700	1	FRAME HEAD	6063-T5	-
2	YE-1701	1	FRAME SILL	6063-T5	-
3	YE-1702	2	FRAME JAMB	6063-T5	-
4	YE-1703	1	FIXED MTG. RAIL	6063-T5	-
5	YE-1704	1	VENT TOP RAIL	6063-T5	-
6	YE-1705	1	VENT BOTTOM RAIL	6063-T5	-
7	YE-1706	2	VENT SIDE RAIL	6063-T5	-
8	YE-1707	AS REQD.	GLAZING BEAD	6063-T5	-
9	YH-1607	2	REINFORCING BARS, FULL LENGTH	STEEL	1/4" X 1"
10	YE-1706	2/VENT	VENT LATCH @ 6" FROM ENDS	6063-T5	-
11	-	2	LATCH SPRING	-	-
12	YH-715	2/ VENT	CAM LOCK @ 11" FROM EACH END	-	-
13	YF-62	2/ LATCH	CAM LOCK SCREWS	-	-
14	YH-622	AS REQD.	BULB PILE W'STRIPPING	-	SULLIVAN & SULLIVAN
15	YH-6009	AS REQD.	FIN SEAL W'STRIPPING	-	ULTRAFAB
16	YF-10	AS REQD.	FRAME/VENT ASSEMBLY SCREWS	-	#8 X 1" P.H. SMS
17	-	AS REQD.	FIX. MTG. RAIL ASSEMBLY SCREWS	-	#10 X 1" P.H. SMS
18	-	2	VENT GUIDE	PLASTIC	-
19	-	2	GUIDE SCREWS	-	SMS
20	-	2/VENT	SPRING AND PULLEY BALANCE	-	CALDWELL
21	-	2	OPEN CELL FOAM PAD (1" X 1/2" X 1-1/2")	-	YALE

af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W03-105YO

SERIES-1700 IMPACT VIEW ALUM SINGLE HUNG WDW.
 AWP, LLC.
 8130 N.W. 74TH AVE.
 MEDLEY, FL. 33166
 TEL. (305) 887-2646 FAX (305) 883-1309

no	date	description
B	01.21.05	NO CHANGE THIS SHEET
C	05.18.06	UPDATED FOR 2004 FBC
D	10.01.07	MANF. NAME REV.
E	11.19.08	NO CHANGE THIS SHEET
F	03.24.09	NO CHANGE THIS SHEET



PRODUCT REVISED
 as complying with the Florida
 Building Code
 Acceptance No 09-0121-24
 Expiration Date 4-29-2014
 By *Jito Harris*
 Miami Dade Product Control
 Division


Engr: DR. HUMAYOUN FAROOQ
 STRUCTURES
 FLA. PE # 16557
 C.A.N. 3538

MAR 24 2009


date: 11-19-03
 scale: 1/2" = 1"
 dr. by: HAMID
 chk. by:

drawing no.
W03-105
 sheet 5 of 6







FRAME HEAD




FRAME JAMB




MEETING RAIL




VENT LATCH




GLAZING BEAD




VENT TOP RAIL




VENT SIDE RAIL




VENT BOTTOM RAIL





FRAME SILL



VENT CORNER DETAIL



FRAME CORNERS DETAIL



PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 09-0121-24
Expiration Date 4-29-2014

By Jay Harris
Miami Dade Product Control
Division

Engr: DR. HUMAYOUN FAROOQ
STRUCTURES
FLA. FE # 16557
C.A.N. 3538

MAR 24 2009

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W03-105YO

SERIES-1700 IMPACT VIEW ALUM SINGLE HUNG WDW.
AWP, LLC.
8130 N.W. 74TH AVE.
MEDLEY, FL. 33166
TEL. (305) 887-2646 FAX (305) 883-1309

no.	date	description	by
B	01.21.05	NO CHANGE THIS SHEET	
C	05.18.06	UPDATED FOR 2004 FBC	
D	10.01.07	MANF. NAME REV.	
E	11.19.08	NO CHANGE THIS SHEET	
F	03.24.09	NO CHANGE THIS SHEET	

date: 11-19-03
scale: 1/2" = 1"
dr. by: HAMID
chk. by:

drawing no.
W03-105
sheet 6 of 6