



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**LymTal International, Inc.
4150 South Lapeer Road
Lake Orion, MI 48359**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Iso-Flex 780/750 and Iso Flex 760 Systems

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 6.

The submitted documentation was reviewed by Alex Tigera.



**NOA No.: 09-0305.01
Expiration Date: 04/22/14
Approval Date: 04/22/09**

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Material: Elastomeric
Maximum Design Pressure N/A
Fire Classification: See Limitation #1

1. SCOPE

This approves "Iso-Flex 780/750 and Iso-Flex 760 Systems" as a maintenance roof coating as manufactured by Lyntal International, Inc., as described in this Notice of Acceptance, designed to comply with the Florida Building Code.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Iso-Flex Primer 750	10 gal & 110 gal	ASTM C 957	Primer used in conjunction with Iso-Flex 780/750 maintenance coating system.
Iso-Flex Primer 757	5 qt & 5 gal	ASTM C 957	Primer used in conjunction with Iso-Flex 760 maintenance coating system.
Iso-Flex 780 Base Coat	5 gal & 53 gal	ASTM C 957	Cold, liquid applied, urethane elastomeric base coat.
Iso-Flex 750 Base Coat	5 gal	ASTM C 957	Cold, liquid applied, urethane elastomeric base coat.
Iso-Flex 750 Top Coat	5 gal & 53 gal	ASTM C 957	Cold, liquid applied, urethane elastomeric top coat.
Iso-Flex 760 Top Coat	5 gal	ASTM C 957	Cold, liquid applied, urethane elastomeric top coat.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Momentum Technologies, Inc.	AX30F8A	ASTM C 957	02/18/09
Trinity ERD	M11660.03.09	TAS 114/ASTM C 957	03/12/09



PHYSICAL PROPERTIES OF COMPONENTS

Trade names: **Iso-Flex Primer 750**
Thickness: See System Approvals Below
Specifications: None
Description: An urethane primer.
Container Size: 10 and 110 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: **Iso-Flex Primer 757**
Thickness: See System Approvals Below
Specifications: None
Description: An epoxy resin primer.
Container Size: 5 qt and 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: **Iso-Flex 780 Base Coat**
Thickness: See System Approvals Below
Specifications: ASTM C 957
Description: Elastomeric urethane base coat.
Container Size: 5 qt and 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.



Trade names: **Iso-Flex 750 Base Coat**
Thickness: See System Approvals Below
Specifications: ASTM C 957
Description: Elastomeric urethane base coat.

Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: **Iso-Flex 750 Top Coat**
Thickness: See System Approvals Below
Specifications: ASTM C 957
Description: Elastomeric urethane top coat.

Container Size: 5 and 53 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: **Iso-Flex 760 Top Coat**
Thickness: See System Approvals Below
Specifications: ASTM C 957
Description: Elastomeric urethane top coat.

Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.



EXISTING SUBSTRATES:

System: Iso-Flex 780/750 System
Substrate: New or Existing concrete.
Preparations: The surface shall be clean, sound and dry prior to application. All surface preparation shall be in compliance with the coating manufacturer's published application instructions and current Miami-Dade County Product Control Notice of Acceptance.
First Coat: Apply Iso-Flex Primer 750 at 250 – 300 sq ft per gallon.
Second Coat: Apply Iso-Flex 780 Base Coat at 70 sq ft per gallon.
Finish Coat: Apply Iso-Flex 750 Top Coat at 80 - 100 sq ft per gallon.
Maximum Design Pressure: N/A

System: Iso-Flex 760 System
Substrate: New or Existing concrete.
Preparations: The surface shall be clean, sound and dry prior to application. All surface preparation shall be in compliance with the coating manufacturer's published application instructions and current Miami-Dade County Product Control Notice of Acceptance.
First Coat: Apply Iso-Flex Primer 757 at 200 – 250 sq ft per gallon.
Second Coat: Apply Iso-Flex 750 Base Coat at 60 sq ft per gallon.
Finish Coat: Apply Iso-Flex 760 Top Coat at 90 - 110 sq ft per gallon.
Maximum Design Pressure: N/A



LIMITATIONS

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. Iso-Flex 780/750 and Iso-Flex 760 systems shall not be applied in inclement weather conditions.
3. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
4. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.
5. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



6. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
7. Iso-Flex 780/750 and Iso-Flex 760 systems shall be applied in accordance with manufacturer's published application instructions.
8. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

