



BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

GAF Material Corporation
1361 Alps Road
Wayne, NJ 07470

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: GAF Conventional Built-Up Roof System for Cementitious Wood Fiber Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 08-0221.07 and consists of pages 1 through 9.
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 09-0402.19
Expiration Date: 11/04/13
Approval Date: 11/25/09
Page 1 of 9

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: BUR
Deck Type: Cementitious Wood Fiber
Maximum Design Pressure -82.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1			
<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
LeakBuster™ Matrix™ 307 Premium Asphalt Primer	5, 55 gallons	ASTM D 41	Asphalt concrete primer used to promote adhesion of asphalt in built-up roofing.
GAF Mineral Shield® Granules	60 lb. bags	ASTM D 1863	Granules for surfacing of exposed asphalt, cold process cement or emulsion. GAF Mineral Shield® Granules shall be used for flashing applications only.
LeakBuster™ Matrix™ 305 Fibered Asphalt Emulsion	5 gallons	ASTM 1227	Surface coating for smooth surfaced roofs.
LeakBuster™ Matrix™ 303 Premium Fibered Aluminum Roof Coating	1, 5 gallons	ASTM D 2824	Fibered aluminum coating.
LeakBuster™ Matrix™ 203 Plastic Roof Cement	1, 5 gallons	ASTM D 3019 ASTM D 3409	Refined asphalt blended with a mineral stabilizer and fibers. Permits adhesion to wet and dry surfaces.
LeakBuster™ Matrix™ 304 Non-Fibered Aluminum Roof Coatings	5 gallons	ASTM D2824, Type I	Non-fibered. Aluminum pigmented, asphalt roof coating
RUBEROID® Modified Bitumen Flashing Cement	5 gallons	ASTM D 4586	Fiber reinforced, polymer modified Flashing cement
LeakBuster™ Matrix™ 202 SBS Flashing Cement	5 gallons	ASTM D4586	Cold Applied Modified SEBS Asphalt Adhesive – Flashing Grade.
GAFGLAS® #75 Base Sheet	39.37” (1 meter) wide	ASTM D 4601	Asphalt impregnated and coated glass mat base sheet.
GAFGLAS® #80 Ultima Base Sheet	39.37” (1 meter) wide	ASTM D 4601	Asphalt impregnated and coated, fiberglass base sheet
GAFGLAS® Flex Ply™ 6	39.37” (1 meter) wide	ASTM D 2178	Type VI asphalt impregnated glass felt with asphalt coating.



GAFGLAS® Ply 4	39.37" (1 meter) wide	ASTM D 2178	Type IV asphalt impregnated glass felt with asphalt coating.
GAFGLAS® Mineral Surfaced Cap Sheet	39.37" (1 meter) wide	ASTM D 3909	Asphalt coated, glass fiber mat cap sheet surfaced with mineral granules.
GAFGLAS® EnergyCap BUR Mineral Surfaced Cap Sheet	39.37" (1 meter) wide	ASTM D 3909	Asphalt coated, glass fiber mat cap sheet surfaced with mineral granules.
GAFGLAS® STRATAVENT® Eliminator™ Perforated	39.37" (1 meter) wide	ASTM D 4897 ASTM D 3672	Fiberglass base sheet impregnated and coated on both sides with asphalt. Surfaced on the bottom side with mineral granules embedded in asphaltic coating with factory perforations.
GAFGLAS® Flashing	Various		Asphalt coated glass fiber mat flashing sheet available in three sizes.
GAFGLAS® STRATAVENT® Eliminator™ Nailable	39.37" (1 meter) wide	ASTM D 4897 ASTM D 3672	Fiberglass base sheet impregnated and coated on both sides with asphalt. Surfaced on the bottom side with mineral granules embedded in asphaltic coating.
RUBEROID® EnergyCap™ SBS Heat Weld Plus FR	39.37" (1 meter) wide	ASTM D 6164	Fire retarding modified bitumen cap sheet.
RUBEROID® SBS Heat-Weld™ Smooth	39.37" (1 meter) wide	ASTM D 6164	Non-Woven Polyester mat coated with polymer-modified asphalt and smooth surfaced.
RUBEROID® SBS Heat-Weld™ Granule	39.37" (1 meter) wide	ASTM D 6164	Non-Woven Polyester mat coated with polymer modified asphalt and surfaced with mineral granules.
RUBEROID® SBS Heat-Weld™ 170 FR	39.37" (1 meter) wide	ASTM D 6164	Non-Woven Polyester mat coated with fire retardant polymer modified asphalt and surfaced with mineral granules.
RUBEROID® SBS Heat-Weld™ PLUS	39.37" (1 meter) wide	ASTM D 6164	Non-Woven Polyester mat coated with polymer modified asphalt and surfaced with mineral granules.
RUBEROID® SBS Heat-Weld™ PLUS FR	39.37" (1 meter) wide	ASTM D 6164	Non-Woven Polyester mat coated with fire retardant polymer modified asphalt and surfaced with mineral granules.
RUBEROID® SBS Heat-Weld™ 25	39.37" (1 meter) wide	ASTM D 6164	Non-Woven Polyester mat coated with polymer modified asphalt and smooth surfaced.
RUBEROID® Modified Base Sheet	39.37" (1 meter) wide	ASTM D 4601 Type II, UL Type G2 BUR	Premium glass fiber reinforced SBS-modified base sheet



RUBEROID® 20	39.37" (1 meter) wide	ASTM D 6163 ASTM D 5147	SBS modified asphalt base sheet and interply sheet reinforce with a glass fiber mat.
RUBEROID® Mop Granule	39.37" (1 meter) wide	ASTM D 6222 ASTM D 5147	Non-woven polyester mat coated with polymer modified asphalt and surfaced with mineral granules.
RUBEROID® Mop Plus (Granule)	39.37" (1 meter) wide	ASTM D 6222 ASTM D 5147	Non-woven polyester mat coated with polymer modified asphalt and surfaced with mineral granules.
RUBEROID® MOP Smooth	39.37" (1 meter) wide	ASTM D 6164 ASTM D 5147	Non-woven polyester mat coated with polymer modified asphalt and smooth surfaced.
RUBEROID® MOP 170FR	39.37" (1 meter) wide	ASTM D 6164 ASTM D 5147	Non-Woven polyester mat coated with fire retardant polymer modified asphalt and surfaced with mineral granules.
RUBEROID® MOP FR	39.37" (1 meter) wide	ASTM D 6164 ASTM D 5147	Non-Woven polyester mat coated with fire retardant polymer modified asphalt and surfaced with mineral granules.
RUBEROID® TORCH Smooth	39.37" (1 meter) wide	ASTM D 6222 ASTM D 5147	Heavy duty, polyester reinforced, asphalt modified bitumen membrane, smooth surface.
RUBEROID® TORCH Granule	39.37" (1 meter) wide	ASTM D 6222 ASTM D 5147	Asphalt impregnated, coated felt, surfaced with mineral granule.
RUBEROID® TORCH FR	39.37" (1 meter) wide	ASTM D 6222 ASTM D 5147	Non-woven polyester mat coated with fire retardant polymer modified asphalt surfaced with mineral granules.
RUBEROID® 30	39.37" (1 meter) wide	ASTM D 6163 ASTM D 5147	Non woven fiberglass mat coated with polymer modified asphalt and surfaced with mineral granules.
RUBEROID® 30 FR	39.37" (1 meter) wide	ASTM D 6163 ASTM D 5147	Non woven fiberglass mat coated with fire retardant polymer modified asphalt and surfaced with mineral granules.
RUBEROID® ULTRACLAD® SBS	39.37" (1 meter) wide	ASTM D 6298 ASTM D 5147	Woven fiberglass mat coated with Polymer modified asphalt and surfaced with aluminum, copper or stainless steel foil.
RUBEROID® Dual FR	39.37" (1 meter) wide	ASTM D 6164 ASTM D 5147	Non-woven polyester and fiberglass mat coated with fire retardant, polymer modified asphalt and surfaced with mineral granules.
Vent Stacks (metal and plastic)		TAS 100(A) ASTM D 1929 ASTM D 635	One way valve vent used to relieve built-up pressure within the roof system. GAF Vent Stacks are available in metal or plastic.
GAF Built-Up Roofing Asphalt	100 lb. cartons, bulk	ASTM D 312	Interply mopping and surfacing asphalt Types I, II, III and IV



RUBEROID MOD Asphalt, Asphalt L & Asphalt P	60 lb. kegs		SEBS modified asphalt
TOPCOAT® Surface Seal SB	5 gallons		Surface coating for smooth surfaced and mineral surfaced roofs.
TOPCOAT® MB Plus	5 gallons		Surface coating for smooth surfaced and mineral surfaced roofs.
Matrix Low VOC	5 gallons		Surface coating for smooth surfaced and mineral surfaced roofs.
LeakBuster™ Matrix™ 531 Weathercote Elastomeric Flashing	5 gallons		Surface coating for smooth surfaced and mineral surfaced roofs.
LeakBuster™ Matrix™ 102 SBS Adhesive	5 gallons	ASTM D 3019	Cold Applied Modified SEBS Asphalt Adhesive
LeakBuster™ Matrix™ 201 Premium SBS Flashing Cement	5 gallons	ASTM D 3019	Cold Applied Modified SEBS Asphalt Adhesive – Flashing Grade.
LeakBuster™ Matrix™ 202 SBS Flashing Cement	5 gallons	ASTM D 3019	Cold Applied Modified SEBS Asphalt Adhesive.
LeakBuster™ Matrix™ 202 SBS Flashing Cement	5 gallons	ASTM D 4586	Cold Applied Modified SEBS Asphalt Adhesive – Flashing Grade.
LeakBuster™ Matrix™ 203 Plastic Roof Cement	5 gallons	ASTM D 4586	Standard Plastic Asphalt Roofing Cement
LeakBuster™ Matrix™ 213 Gun Grade Plastic Cement	5 gallons	ASTM D 4586	Standard Plastic Asphalt Roofing Cement Caulk Grade.
Leak Buster™ Matrix™ 103 Cold Process Adhesive	5 gallons	ASTM D 3019	Cold Applied Asphalt Adhesive.
RUBEROID® Modified Bitumen Adhesive	5 gallons	ASTM D 3019	Fiber reinforced, rubberized Adhesive Type III
StormSafe™ Anchor Sheet	48" wide	Proprietary	Synthetic Underlayment



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
EnergyGuard™, RA, RN & Composite	Polyisocyanurate foam insulation	GAF Materials Corp.
EnergyGuard™ Composite, Composite A & N	Polyisocyanurate foam insulation with high density fiberboard or Permalite perlite insulation.	GAF Materials Corp.
EnergyGuard™ Fiberboard	Fiberboard insulation.	GAF Materials Corp.
EnergyGuard™ Perlite	Perlite insulation board.	GAF Materials Corp.
EnergyGuard™ GAFCANT™	Cut perlite board	GAF Materials Corp.
EnergyGuard™ Perlite Recover Board	Perlite recover board	GAF Materials Corp.
EnergyGuard™ Tapered Edge Strip	Tapered perlite board	GAF Materials Corp.
Dens Deck®, Dens Deck Prime® & Dens Deck DuraGuard®	Water resistant gypsum board	GAF Materials Corp.
Structodek® TD	Flame Resistant High Density Wood Fiber board Insulation board	Knight-Celotex
Structodek®	High Density Wood Fiber board Insulation board	Knight-Celotex
SECUROCK®	A solid, fiber-reinforced gypsum board with no facer.	Gypsum

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Drill-Tec II NTB	Glass reinforced Nylon insulation fastener for gypsum & CWF decks with barbs.		GAF Materials Corp.
2.	Drill-Tec NTB Plate	Galvalume stress plate	3" round	GAF Materials Corp.
3.	Drill-Tec CR 1.2 Base Sheet Fastener	Base sheet fastening only		GAF Materials Corp.
4.	Drill-Tec™ Locking Impact Nail	Base sheet fastener with integrated Plate.	1.8" long w/ 2.7" dia. plate	GAF Materials Corp.



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Factory Mutual Research Corp.	FMRC 1996	Current Insulation Attachment Requirements	01.01.96
	J.I. 2B8A4.AM	FMRC 4470	07.02.97
	J.I. 3B9Q1.AM		01.08.98
	J.I. 0D0A8.AM		07.09.99
	J.I. 0D1A8.AM	FMRC 4470	07.29.94
	J.I. 0Y9Q5.AM		04.01.98
	3036980		08.14.09
Underwriters Laboratories, Inc.	R1306, 00NK07638	UL 790 - TAS 114	07.17.00
Dynatech Engineering Corp.	#3600.02.95-1	TAS 114	02.02.95
	#4482.02.95-1	TAS 114	
IRT-ARCON, Inc.	02-026	TAS 114	07.26.02,
	G6850.08.07-1	ASTM D 3909	08.13.07
Trinity ERD	G6850.08.08	ASTM D 6164	08.29.08
	G121110.12.08	Physical Properties	12.02.08



APPROVED ASSEMBLIES

Deck Type 5: Cementitious Wood Fiber

Deck Description: Cementitious wood fiber

System Type E: Anchor sheet mechanically fastened

All General and System Limitations shall apply.

Anchor Sheet: Install one ply of GAFGLAS® #75 base sheet, GAFGLAS® #80 Ultima™ Base Sheet, GAFGLAS® Flex Ply™ 6, GAFGLAS® STRATAVENT® Eliminator™ Nailable, RUBEROID® Mop Smooth, RUBEROID® 20, RUBEROID® Modified Base Sheet, RUBEROID® SBS Heat-Weld™ Smooth, RUBEROID® EnergyCap™ SBS Heat Weld Plus FR or RUBEROID® SBS Heat-Weld 25 base sheet mechanically fastened with 1.8" Drill-Tec™ Locking Impact Nail fastened at 9" o.c. at the 3" side lap and in two 12" o.c. staggered rows in the field

Ply Sheet: One or more plies GAFGLAS® PLY 4®, or GAFGLAS® Flex Ply™ 6 sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GAFGLAS® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surface Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq. or applied in a flood coat of Leak Buster™ Matrix™ 103 Cold Process Adhesive applied at a rate of 3 gal./sq.
2. Leak Buster™ Matrix™ 303 Premium Fibered Aluminum Roof Coating, at 1.5 gal./sq.
3. Leak Buster™ Matrix™ 322, TOPCOAT® MB Plus, TOPCOAT® Fireshield Elastomeric Roofing Membrane, applied at 1 to 1.5 gal./sq.
4. EnergyCote™ roof coating applied at 1 to 1.5 gal./sq.
5. TOPCOAT® Surface Seal SB, TOPCOAT® Fireshield® SB Solvent based Elastomeric Roofing Membrane applied at 1 to 1.5 gal./sq.
6. Advance Green Technologies Photovoltaic Laminate solar energy collector auxiliary roof equipment installed in compliance with manufacturer's specifications and applicable Building Codes.

Note: Chosen surfacing components must be applied according to manufacturer's application instructions.

Maximum Design

Pressure: -82.5 psf (See General Limitation #7)



NOA No.: 09-0402.19
Expiration Date: 11/04/13
Approval Date: 11/25/09
Page 8 of 9

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.
Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 09-0402.19
Expiration Date: 11/04/13
Approval Date: 11/25/09
Page 9 of 9