



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Soprema, Inc.
1675 Haggerty
Dummonville, Quebec J2C 5P7 Canada**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Lastobond Products

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 08-0303.03 and consists of pages 1 through 4
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 09-0407.11
Expiration Date: 09/29/10
Approval Date: 06/17/09
Page 1 of 4**

ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: SBS

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

| <u>Product</u> | <u>Dimensions</u> | <u>Test Specification</u> | <u>Product Description</u> |
|---------------------|--|---------------------------|---|
| Lastobond Shield | 36" x 75' rolls or 45" x 75' rolls | ASTM D1970 | SBS self-adhering asphalt sheet material for use as an underlayment for Ice Dam Protection in sloped roof assemblies. **Available as Lastobond Shield 36 and Lastobond Shiled 45 for the 36" wide and 45" wide rolls. |
| Lastobond Pro HT-N | 36" x 65' rolls | ASTM D1970 | SBS self-adhering asphalt sheet material for use as an underlayment for Ice Dam Protection in sloped roof assemblies. |
| Lastobond Shield HT | 36" x 75' rolls | ASTM D1970 | SBS self-adhering asphalt sheet material for use as an underlayment for Ice Dam Protection in sloped roof assemblies. |
| Lastobond Pro HT-S | 36" x 65' rolls | ASTM D1970 | SBS self-adhering asphalt sheet material for use as an underlayment for Ice Dam Protection in sloped roof assemblies. |
| Lastobond TU | 36" x 65' rolls | TAS 103 | SBS self-adhering asphalt sheet with a non-woven polyester fabric top surface for use as an underlayment for tile roofs. |

EVIDENCE SUBMITTED:

| <u>Test Agency</u> | <u>Test Identifier</u> | <u>Test Name/Report</u> | <u>Date</u> |
|---------------------------------|------------------------|-------------------------|-------------|
| Exterior Research & Design, LLC | 2968.05.04-2 | ASTM D1970 | 05/17/04 |
| Underwriters Laboratories, Inc. | R21824 | Follow Up Service | 08/31/05 |
| Trinity ERD | S7120.11.07-2 | TAS 103 | 11/02/07 |
| | S13190.02.09 | ASTM D4798 / ASTM D1970 | 02/11/09 |



APPROVED ASSEMBLIES:

- Deck Type 1:** Wood, non-insulated, new construction
- Deck Description:** $1\frac{9}{32}$ " or greater plywood or wood plank
- System E(1):** Base sheet mechanically fastened, membrane adhered.
- Base Sheet:** One or more plies of ASTM D 226 Type II or ASTM D 2626 with a minimum 4" side lap and a 6" end lap mechanically fastened to deck with approved nails and tin caps 6" o.c. at the laps and two staggered rows 12" o.c. the field of the roll.
- Membrane:** One ply of Lastobond Shield, Lastobond Pro HT-N, Lastobond Shield HT Lastobond Pro HT-S or Lastobond TU with minimum 3-inch side laps and 6-inch end laps. Starting at the first course, parallel to the eave, align the membrane carefully by completely unrolling and setting it exactly where it will be installed. Once aligned, rewind one half of the length. Gently score the release paper on the high side of this roll, ensuring not to cut through the membrane's thickness. Unroll this first half by evenly peeling back the release paper while simultaneously and slowly pushing out the membrane. Repeat process for remaining one half of the length. Once installed, the membrane must be pressure rolled with a metal or rubber roller. Pressure shall be applied over the entire surface, paying particular attention to all side and end laps.
- Surfacing:** Approved for Mechanically Fastened Metal Roofing, Wood Shake & Shingles, Asphalt Shingles, Slate, Simulated Slate.
- Deck Type 1:** Wood, non-insulated, new construction
- Deck Description:** $1\frac{9}{32}$ " or greater plywood or wood plank
- System E(2):** Base sheet mechanically fastened, membrane adhered.
- Base Sheet:** One or more plies of ASTM D 226 Type II or ASTM D 2626 with a minimum 4" side lap and a 6" end lap mechanically fastened to deck with approved nails and tin caps 6" o.c. at the laps and two staggered rows 12" o.c. the field of the roll.
- Membrane:** One ply of Lastobond TU with minimum 3-inch side laps and 6-inch end laps. Starting at the first course, parallel to the eave, align the membrane carefully by completely unrolling and setting it exactly where it will be installed. Once aligned, rewind one half of the length. Gently score the release paper on the high side of this roll, ensuring not to cut through the membrane's thickness. Unroll this first half by evenly peeling back the release paper while simultaneously and slowly pushing out the membrane. Repeat process for remaining one half of the length. Once installed, the membrane must be pressure rolled with a metal or rubber roller. Pressure shall be applied over the entire surface, paying particular attention to all side and end laps.
- The Lastobond TU shall be back nailed to deck with approved annular ring shank nails and tin caps at a maximum 12" o.c. at the side laps and 6" o.c. at the end laps. No nails or tin caps shall be exposed.
- Surfacing:** Approved for Mechanically Fastened Cement or Clay Roof tiles.

LIMITATIONS:

1. Fire classification is not part of this acceptance.
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with the applicable building code. Lastobond Shield, Lastobond Pro HT-N, Lastobond Shield HT, Lastobond Pro HT-S and Lastobond TU shall be installed in strict compliance with the applicable building code.
3. Lastobond Shield, Lastobond Pro HT-N, Lastobond Shield HT, Lastobond Pro HT-S and Lastobond TU shall be applied to a smooth, clean and dry surface, free from irregularities. Re-fasten any loose decking panels, and check for protruding nail heads. Sweep the substrate thoroughly to remove any dust and debris prior to application. When a smooth, clean and/or dry surface cannot be obtained, the substrate shall be primed with Elastocol Stick prior to application.
4. Lastobond Shield, Lastobond Pro HT-N, Lastobond Shield HT, Lastobond Pro HT-S and Lastobond TU shall not be applied over an existing roof membrane as a recover system but may be applied over a roofing Base/Anchor sheet underlayment.
5. Lastobond Shield, Lastobond Pro HT-N, Lastobond Pro HT-S and Lastobond TU shall not be left exposed as a temporary roof for longer than 30 days.
6. Lastobond Shield HT shall not be left exposed as a temporary roof for longer than 90 days.
7. Lastobond Shield, Lastobond Pro HT-N, Lastobond Shield HT, Lastobond Pro HT-S and Lastobond TU may be used with any approved roof covering listing Lastobond Shield, Lastobond Pro HT-N, Lastobond Shield HT, Lastobond Pro HT-S and Lastobond TU within the Product Approval. If Lastobond Shield, Lastobond Pro HT-N, Lastobond Shield HT, Lastobond Pro HT-S or Lastobond TU is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval based on the necessary documentation to detail compatibility of the products, wind uplift resistance and fire resistance results.
8. When applying the membrane in the valley, start at the low point and work to the high point, rolling the membrane from the center outward in both directions. For ridge applications, center the membrane and roll from the center outwards in both directions.
9. Membrane shall be applied to protrusions, slope changes, valley, curb, and other roof top penetration details before any other sections of the roof.
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.
11. Tiles must be staged onto Lastobond TU not to exceed 10-high, to the standard maximum roof pitch of 5:12 for flat tiles and 6:12 for lugged tiles. At roof slopes greater than the preceding limitations all tiles shall be loaded onto a nominal 1" x 2" horizontal batten to prevent slippage.
12. All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE



NOA No.: 09-0407.11
Expiration Date: 09/29/10
Approval Date: 06/17/09
Page 4 of 4