MIAMI-DADE

BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

American Weatherstar, LLC
P.O. Box 6256
Mobile, AL 36660

SCOPE:
This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Acrylic 211

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This new NOA consists of pages 1 through 4.
The submitted documentation was reviewed by Jorge L. Acebo.

MIAMI-DADE COUNTY APPROVED

ROOFING COMPONENT APPROVAL

Category:	Roofing
Sub-Category:	Cement-Adhesive-Coatings
Materials:	Elastomeric

SCOPE:

This approves "Acrylic 211" as a roof maintenance coating, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

EVIDENCE SUBMITTED:

Test Agency	Test Identifier	Test Name/Report	Date
PRI Asphalt Technologies, Inc.	UCMC-004-02-01 Revised	ASTM D 6083	03/30/04
	UCMC-004-02-02 Revised	ASTM D 6083 Fed. Spec. TTC-555B	06/22/04

MANUFACTURING LOCATIONS

1. Spokane Valley, WA

PHYSICAL PROPERTIES OF COMPONENTS

Trade names:	**Acrylic 211**
Thickness:	See System Approvals Below
Specifications:	ASTM D 6083
Description:	A acrylic elastomeric coating that is applied as specified within the application table: • Foam Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft^2 and Finish Coat at a rate of 1.5 gal/100 ft^2.
Container Size:	5 and 55 gallons. Note all precautions on container.
Systems Approvals:	Methods of application and quantities shall comply specific Roof Assembly, Product Control Notice of Acceptance.

M

Trade names:	**Acrylic 211**
Thickness:	See System Approvals Below
Specifications:	ASTM D 6083
Description:	A water-based elastomeric coating that is applied as specified within the application table: • Galvanized Metal Roofs: Apply Base Coat at a minimum rate of 1 gal/100 ft^2 and Finish Coat at a rate of 1 gal/100 ft^2. • EPDM, PVC and TPO Membranes: Apply Base Coat at a minimum rate of 1 gal/100 ft^2 and Finish Coat at a rate of 1.5 gal/100 ft^2. • Modified Bitumen (SBS & APP) and Built-Up-Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft^2 and Finish Coat at a rate of 1.5 gal/100 ft^2.
Container Size:	5 and 55 gallons. Note all precautions on container.
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

MAINTENANCE COATING APPLICATION:

Surface Preparation:	All surfaces to be prepared and cleaned in accordance with manufacturers published specifications.
Base Coat / Primer:	Coat the clean and dry existing roof surface with the appropriate basecoat or primer as specified within the application table below.
Finish Coat:	Apply Finish Coat in multiple layers onto the appropriate base coat or primer as specified within the application table below and in accordance with manufacturers published specifications.

Substrate	Base Coat / Primer		Finish Coat			Total System Minimum Dry mil thickness
	Product	Application Rate gal/100 ft^2	Product	First Layer Application Rate gal/100 ft^2	Second Layer Application Rate gal/100 ft^2	
Modified Bitumen (SBS & APP) Granule	Acrylic Base Coat 205	1.0 – 1.5	Acrylic 211	1.5	1.5	25
BUR Smooth	Acrylic Base Coat 205	1.0 – 1.5	Acrylic 211	1.5	1.5	25
PVC	Acrylic Base Coat 205	1.0 – 1.5	Acrylic 211	1.0	1.5	20
TPO	Acrylic Base Coat 205	1.0 – 1.5	Acrylic 211	1.0	1.5	20
EPDM	Etching Prime 920	.2	Acrylic 211	1.5	1.5	20
Spray Polyurethane Foam Roof	None	N/A	Acrylic 211	1.5	1.5	28
Galv. Metal	None	N/A	Acrylic 211	1.0	1.0	15

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. Acrylic 211 shall not be applied in inclement weather conditions.
3. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
4. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.
5. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
6. Acrylic 211 shall be applied in accordance with manufacturer's published application instructions.
7. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.
8. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.

MIAMI-DADE COUNTY APPROVED

END OF THIS ACCEPTANCE