



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Cooley Roofing Systems, Inc.
50 Esten Avenue
Pawtucket, RI 02860**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Cooley C3, C3FB and C3Plus PVC Single Ply Roof Systems over Recover Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 06-0418.04 and consists of pages 1 through 19.
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 09-0608.05
Expiration Date: 08/03/11
Approval Date: 07/15/09
Page 1 of 19**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply
Material: PVC
Deck Type: Recover
Maximum Design Pressure See specific system assemblies

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Cooley C-3 40-100 Mil Membrane	78" x 108"	ASTMD 4434	40-100 mil thermoplastic alloy membrane field membrane.
Cooley C-3 40-100 Mil Perimeter Sheet	39" x 108'	ASTM D 4434	40-100 mil thermoplastic alloy membrane perimeter sheet.
Cooley C-3 40-Roofing Membrane	52" x 108'	ASTM D 4434	40-100 mil thermoplastic alloy membrane field membrane.
Cooley C-3 Plus 40-100 Mil Membrane	78" x 100'	ASTMD 4434	40-100 mil thermoplastic alloy membrane field membrane
Cooley C-3 Plus 40-100 Mil Perimeter Sheet	39" x 100'	ASTMD 4434	40-100 mil thermoplastic alloy membrane perimeter sheet
Cooley C-3 Plus 40-Roofing Membrane	52" x 100'	ASTMD 4434	40-100 mil thermoplastic alloy membrane field membrane.
Cooley C-3 Reinforced Flashing Membrane	6", 8", 12", 18" & 24" variable length rolls	ASTM D 4434	40-100 mil thermoplastic flashing membrane.
Cooley C-3 Unreinforced 55 - 75 Mil Membrane Back RAM	24" x 36' LF 72 ft. ² roll	ASTM D 4434	55 mil unreinforced flashing membrane
Cooley C-3 Coated Metal	4' x 8' 4' x 10' sheets	US Commercial Standard CS-245-62	C-3 membrane laminated 24 Ga. galvanized steel.
Cooley C-3 Fleece Back RAM Universal Corners	14" x 14"	ASTM D 4434	Thermoplastic fleece back membrane. Adhered applications.
Cooley C-3 Fleece Back RAM	76" x 100' 39" x 100' 325 ft. ² roll	ASTM D 4434	Thermoplastic fleece back membrane. Adhered applications.
Cooley C-3 Fleece Back RAM Flashing	12" x 100' 100 ft. ² roll 24" x 100' 200 ft. ² roll	ASTM D 4434	Thermoplastic fleece back membrane flashing material.
Cooley C3 Bonding Adhesive	5 gallon pails	proprietary	Solvent based adhesive for fully adhered RAM systems and C3PLUS roofing membrane.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Cooley PVC Adhesive	N/A	proprietary	Solvent based adhesive for fully adhered C3PLUS Roofing Membrane
Cooley WB Bonding Adhesive	N/A	proprietary	Water Based adhesive for fully adhered C3PLUS Roofing Membrane
Cooley Low VOC PVC Adhesive	N/A	proprietary	Low VOC solvent based adhesive for fully adhered C3PLUS Roofing Membrane
Cooley Aluminum Termination Bar	1/8" x 1" x 10	TAS 114	Flat termination bar.
Cooley Coolgrip Walkway	0.072" x 36" x 60'	proprietary	Walkway pad (roll configuration)
Cooley Coolgrip Heavy Duty Walkway	0.150" x 36" x 60'	proprietary	Walkway pad (roll configuration)
C3 Bonding Adhesive	N/A	proprietary	Contact adhesive for membrane flashing.
Cooley PVC Adhesive	N/A	proprietary	Adhesive for membrane flashing
Cooley WB Bonding Adhesive	N/A	proprietary	Adhesive for membrane flashing
Cooley Low VOC PVC Adhesive	N/A	proprietary	Adhesive for membrane flashing

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
Pyrox, White Line	Isocyanurate Insulation	Apache Products Co.
ACFoam II, III	Isocyanurate Insulation	Atlas Roofing Corp.
Conperl	Perlite insulation board.	Conglas
Hytherm, Hytherm AP	Isocyanurate Insulation	Dow Chemical
Styrofoam	Extruded Polystyrene.	Dow Chemical
ISO 95+, ISO 95+ GL	Polyisocyanurate foam insulation	Firestone
EnergyGuard High Density Fiberboard	High density wood fiberboard insulation.	GAF Materials Corp.
EnergyGuard Perlite	Perlite insulation board.	GAF Materials Corp.
Armor Board High Density	Wood fiber insulation board.	Honeywell International
Dens Deck, Dens Deck Prime	Silicon treated gypsum	G-P Products
Sturdi-Top, Roof Insulation Board	Wood fiber insulation board.	G-P Products
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
Perlite Insulation Board	Perlite Insulation	Generic
Type X Gypsum, Gypsum	Gypsum Wallboard	Generic
EPS or XPS Insulation	Expanded or Extruded Polystyrene.	Generic
Ultra/M-II	Isocyanurate Insulation	Homasote Co.
H-Shield	Isocyanurate Insulation	Hunter Panels
ENRGY 2, ENERGY 3, PSI-25 UltraGuard	Isocyanurate Insulation	Johns Manville
Fesco Foam, DuraFoam	Isocyanurate Insulation with perlite facer	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
Strataguard	Gypsum Wallboard	Owens Corning
Multi-Max, Multi-Max FA, Thermarroof Plus	Polyisocyanurate foam insulation	Rmax, Inc.
Fiberbase HD1, HD6	Asphalt coated wood fiber insulation	Temple Inland Forest Products Corp.
Structodeck	High Density Wood Fiber insulation board.	Wood Fiber Industries

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Olympic Fasteners #12, #14	Insulation and membrane fastener	Various	Olympic Mfg. Group
2.	Olympic Standard	Galvalume AZ55 stress plate	3" round	Olympic Mfg. Group
3.	Olympic XHD Fastening System	Insulation and membrane fastener consisting of a steel seam plate and screw.	2-3/8" plate & #15 Screw	Olympic Mfg. Group
4.	Olympic Plastic	Plastic plates for fasteners.	3" round	Olympic Mfg. Group
5.	Dekfast Fasteners #14, #15	Insulation and membrane fastener	Various	SFS Intec, Inc.
6.	Omega	Stainless steel insulation / membrane fasteners.	Various	SFS Intec, Inc.
7.	Dekfast Hex Plate	Galvalume AZ50 stress plate	2-7/8" x 3-1/4"	SFS Intec, Inc.
8.	Dekfast HS Membrane Plate	Galvalume stress plate	2-1/2"	SFS Intec, Inc.



NOA No.: 09-0608.05
 Expiration Date: 08/03/11
 Approval Date: 07/15/09
 Page 4 of 19

9.	Dekfast HS Fasteners	Insulation and membrane fastener	Various	SFS Intec, Inc
10.	Dekfast Lock Plate	Polypropylene stress plate.	3" x 3-1/4"	SFS Intec, Inc.
11.	Insul-Fixx Fastener	Insulation fastener	Various	SFS Intec, Inc.
12.	Isofast Plate	Square or oblong Galvalume steel plates for use with Isofast fasteners	Various	SFS Intec, Inc.
13.	Isofast Fasteners	Insulation fastener for steel and wood decks	Various	SFS Intec, Inc
14.	Insul-Fixx S	Galvalume AZ55 stress plate	3" round	SFS Intec, Inc.
15.	Insul-Fixx P	Polyethylene stress plate	3" round	SFS Intec, Inc.
16.	Roof Grip Fastener	Insulation and membrane fastener	#15	ITW Buildex
17.	Round Barbed Seam Plate	Galvalume stress plate	2-3/8"	ITW Buildex
18.	EHD Fasteners	Insulation and membrane fastener	Various	Tru-Fast.
19.	Barbed Seam Plate	Galvalume stress plate	2.4"	Tru-Fast
20.	MaxLoad Fasteners	Insulation and membrane fastener	Various	ITW Buildex
21.	Eye Hook Seam Plate	Galvalume stress plate	2.75"	ITW Buildex
22.	Super XHD Fasteners	Insulation and membrane fastener	Various	Olympic Mfg. Group
23.	Super Barbed Stress Plate	Galvalume stress plate	2.75"	Olympic Mfg. Group
24.	Piranha HP-Xtra Fastener	Insulation and membrane fastener	Various	Carlisle Inc.
25.	Piranha-Xtra Plates	Galvalume stress plate	2 3/8"	Carlisle Inc
26.	All purpose Heavy Duty Fastener	Insulation and membrane fastener	Various	Firestone Building Products
27.	All purpose Fastener	Insulation and membrane fastener	Various	Firestone Building Products
28.	Insulation Fastening Plate	Galvalume stress plate	Various	Firestone Building Products
29.	Rawl #12 or #14	Insulation and membrane fastener	Various	Powers Fastening Inc
30.	Rawl Speed-Lock Toggle Bolt	Insulation and membrane fastener	Various	Powers Fastening Inc
31.	Rawl Insulation Plate	Galvalume stress plate	3"	Powers Fastening Inc
32.	Olympic #10 Fastener	Insulation and membrane fastener	Various	Olympic Mfg. Group
33.	Olympic Stainless #12 Fastener	Insulation and membrane fastener	Various	Olympic Mfg. Group
34.	Iron-Lok or Strap Toggle Fastener	Insulation and membrane fastener	Various	Olympic Mfg. Group
35.	Olympic Heavy Duty Fastener	Insulation and membrane fastener	Various	Olympic Mfg. Group



36.	Accutrac or Hextra with Recessed, Accutrac or Gearlock Plate	Insulation and membrane fastener and plate	Various	ITW Buildex
37.	#12 ¼ in,#14 Roofgrip Drill Point, #14-10 or #15 Roofgrip with Recessed, Accutrac Flat Bottom, Gearlock Plate	Insulation and membrane fastener and plate	Various	ITW Buildex
38.	Hextra Plus Pre-assembled System,	Insulation and membrane system	Various	ITW Buildex
39.	Roofgrip Plus Pre-assembled System	Insulation and membrane system	Various	ITW Buildex
40.	OMG Hex Head #12 Fastener	Insulation and membrane fastener	Various	Olympic Mfg. Group
41.	OMG Hex Head #14 Fastener	Insulation and membrane fastener	Various	Olympic Mfg. Group
42.	OMG G-2 Stress Plate	Insulation and membrane Plate	Various	Olympic Mfg. Group
43.	OMG LGP Stress Plate	Insulation and membrane Plate	Various	Olympic Mfg. Group
44.	OMG SIP Fastener	Insulation and membrane fastener	Various	Olympic Mfg. Group
45.	Dekfast #12	Insulation and membrane fastener	Various	SFS Intec Fastening System Inc
46.	Dekfast #12 Hex	Insulation and membrane fastener	Various	SFS Intec Fastening System Inc
47.	Dekfast #14 SS	Insulation and membrane fastener	Various	SFS Intec Fastening System Inc
48.	Dekfast #15 HS	Insulation and membrane fastener	Various	SFS Intec Fastening System Inc
49.	Dekfast 3" Round Plastic Lock Plate	Insulation and membrane Plate	3"	SFS Intec Fastening System Inc
50.	Dekfast Galvalume Steel Round Plate	Insulation and membrane Plate	3"	SFS Intec Fastening System Inc
51.	Dekfast Galvalume Steel Hex	Insulation and membrane fastener	Various	SFS Intec Fastening System Inc
52.	Dekfast Isofast IFC/PH-70x70 Insulation Plate	Insulation Plate	Various	SFS Intec Fastening System Inc
53.	Dekfast K-Fast	Insulation and membrane fastener	Various	SFS Intec Fastening System Inc
54.	Dekfast Recessed Galvalume Steel Hex	Stress Plate	Various	SFS Intec Fastening System Inc
55.	Dekfast System ES #12 Plastic	Pre-assembled	Various	SFS Intec Fastening System Inc
56.	Dekfast System ES #12 Steel	Pre-assembled	Various	SFS Intec Fastening System Inc
57.	Dekfast System ES #14 Steel	Pre-assembled	Various	SFS Intec Fastening System Inc
58.	Tru-Fast PA System	Pre-assembled	Various	Tru-Fast Corp.
59.	Tru-Fast DL	Insulation and membrane fastener	Various	Tru-Fast Corp.
60.	Tru-Fast DP	Insulation and membrane fastener	Various	Tru-Fast Corp.
61.	Tru-Fast DP-H	Insulation and membrane fastener	Various	Tru-Fast Corp.
62.	Tru-Fast HD	Insulation and membrane fastener	Various	Tru-Fast Corp.



63.	Tru-Fast MP-3	Stress Plate	3"	Tru-Fast Corp.
64.	Tru-Fast MP-3 -SS	Stress Plate	3"	Tru-Fast Corp.
65.	Tru-Fast MPH-3	Stress Plate	3"	Tru-Fast Corp.
66.	Tru-Fast MPH-3-SS	Stress Plate	3"	Tru-Fast Corp.
67.	Tru-Fast Plastic	Stress Plate	3"	Tru-Fast Corp.
68.	Tru-Fast TP	Insulation and membrane fastener	Various	Tru-Fast Corp.
69.	Tru-Fast Ultra SS	Insulation and membrane fastener	Various	Tru-Fast Corp.
70.	CD-10 Spike	Insulation and membrane fastener	Various	Olympic Mfg. Group
71.	Fluted Nail	Insulation and membrane fastener	Various	Olympic Mfg. Group
72.	NTB Magnum	Fastener for cementitious and gypsum decks	Various	Olympic Mfg. Group
73.	Isofast IF2 Fasteners	Insulation fastener for steel and wood decks	Various	SFS Intec, Inc

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Report</u>	<u>Name</u>	<u>Date</u>
Factory Mutual Corp.	3025170	4470	02/07/06
	3021133	4470	02/07/06
	J.I. 1R2A0.AM	4470	04/10/90
	J.I. 0T9A3.AM	4470	10/01/90
	J.I. 1V1A8.AM	4470	04/21/92
	J.I. 0X2A9.AM	4470	06/26/93
	J.I. 3W1A1.AM	4470	03/29/93
	J.I. 1W1A9.AM	4470	09/11/93
	J.I. 1X3A6.AM	4470	10/03/93
	J.I. 1W9A2.AM	4470	06/15/93
	J.I. 1W2A0.AM	4470	08/24/93
	J.I. 1T2A6.AM	4470	02/22/93
	J.I. 3W3A4.AM	4470	03/26/93
	J.I. 0X8A9.AM	4470	06/25/93
	J.I. 1X6A5.AM	4470	10/12/93
	J.I. 2W5A6.AM	4470	06/01/93
	Underwriters Laboratories, Inc.	File R9834 (N)	UL 790



APPROVED ASSEMBLIES

Deck Type 7I: Recover, Insulated

Deck Description: cementitious wood fiber/gypsum

System Type A(1): Anchor sheet mechanically attached, insulation adhered, membrane adhered.

All General and System Limitations apply.

One or more layers of the Base Layer insulation covered by one layer of the insulation listed as Top Layer.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
-----------------------	-----------------------------------	----------------------------------

ACFoam II, Multi-Max FA, ENRGY-2, ENRGY-3, PSI-25, ISO-95+, ISO + GL, Hy-Therm AP, Pyrox

Minimum 1.4" thick	N/A	N/A
--------------------	-----	-----

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
----------------------	-----------------------------------	----------------------------------

High Density Fiberboard, FM-90 High Density, Armor Board Regular, Esgard, EnergyGuard Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber

Minimum 1/2" thick	N/A	N/A
--------------------	-----	-----

Note: All insulation shall be adhered to the anchor sheet in full moppings of approved asphalt within the EVT range and at a rate of 20-40 lbs./sq. or Cooley Bonding Adhesive at 1 gal./sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Anchor Sheet: One ply of Celotex Hydrostop, GAFGLAS #75, GAFGLAS Stratavent, Johns Manville Ventsulation or Johns Manville PermaPly 28 secured to the deck with Olympic NTB Magnum fasteners at 1 per 2 sq. ft.

Note: Anchor sheet fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements set forth in the applicable Building Code.

Membrane: C3 Fleece Back Roof Cover fully adhered to the insulation with Cooley Bonding Adhesive (C-1006) applied at the rate of 1 gal./sq., or approved mopping asphalt applied at the rate of 25 lbs./sq..

Maximum Design Pressure: -45 psf (See General Limitation #9)



NOA No.: 09-0608.05
Expiration Date: 08/03/11
Approval Date: 07/15/09
Page 8 of 19

Deck Type 7I: Recover, Insulated

Deck Description: wood/steel/concrete/lightweight concrete/cementitious wood fiber/gypsum

System Type A(2): One or more layers of insulation adhered with approved asphalt or adhesive; membrane fully adhered.

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam II, Multi-Max FA, E'NRG'Y-2, PSI-25, ISO-95+, ISO + GL, Hy-Therm AP, Pyrox Minimum 1.4" thick	N/A	N/A
High Density Fiberboard, FM-90 High Density, Armor Board Regular, Esgard, Celotex Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber Minimum ½" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
High Density Fiberboard, FM-90 High Density Minimum ½" thick	N/A	N/A

Note: Existing roof surface shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet or base insulation layer. All insulation shall be adhered to the anchor sheet or primed substrate in full moppings of approved asphalt within the EVT range and at a rate of 20-40 lbs./sq. or with ¾" to 1" wide beads of Insta-Stik Adhesive, 12" o.c. (primer not required for use of Insta-Stik). Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with an optional second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder may be installed over the deck or the base layer of insulation.

Barrier: (Optional) 1/2" or 5/8" gypsum or Dens Deck secured to the deck with the insulation.

Membrane: C3 Fleece Back Roof Cover fully adhered to the insulation with Cooley Bonding Adhesive (C-1006) applied at the rate of 1 gal./sq., or approved mopping asphalt applied at the rate of 25 lbs./sq..

Maximum Design Pressure: -45 psf (See General Limitation #9)



Deck Type 7I: Recover, Insulated

Deck Description: Concrete

System Type C(1): All layers of insulation simultaneously attached; C3PLUS membrane fully adhered.

All General and System Limitations apply.

One or more layers of the following insulations:

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam-II, ACFoam-III Minimum 2" thick	2, 7, 35, 37, 40, 41, 42, 44, 45, 47, 48, 49, 50, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 66, 67, 68, 69, 70, 71	1: 4 ft ²
ENRGY 3, PSI 25, ValuTherm Minimum 2" thick	7, 37, 26, 27, 28, 45, 47, 48, 49, 50, 52, 53, 54, 55, 56, 57	1: 4 ft ²
ISO 95+ GL Minimum 2" thick	2, 26, 27, 28, 35, 37, 40, 41, 42, 44, 70, 71 Steel Plate only for OMG	1: 4 ft ²
Hy-Therm AP Minimum 1.5" thick	2, 7, 26, 27, 28, 29, 30, 31, 35, 37, 40, 41, 42, 44, 45, 47, 48, 49, 50, 52, 53, 54, 55, 56, 57, 70, 71	1: 4 ft ²
BP High Strength Fiberboard Minimum ½" thick	26, 27, 28,	1: 2 ft ²
Fiber Top C, E Minimum 1" thick	2, 26, 27, 28, 29, 30, 31, 35, 37, 40, 41, 42, 44, 70, 71	1: 2 ft ²
High Density Fiberboard, Armor Board Regular and High Density, Esgard and Esgard High Strength, EnergyGuard High Density Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber, GAFTEMP Fiberboard, Knight-Celotex Fiberboard Premium and High Density, High Density Roof Board, High Density Roof Fiberboard Minimum 1" thick	2, 26, 27, 28, 29, 30, 31, 35, 40, 41, 42, 44, 70, 71	1: 2 ft ²

Note: All layers shall be simultaneously fastened. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: (Optional) Any UL or FM approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: (Optional) Minimum 1/4" Dens Deck secured to the deck with the insulation.

Membrane: C3 Plus Membrane fully adhered to the insulation with Cooley Bonding Adhesive (C-1006) applied at the rate of 0.83 gal./sq. on both the membrane and the substrate for a total of 1.67 gal./sq., and a heat welded seam minimum 1½" wide at the laps, or Cooley PVC Bonding Adhesive applied at the rate of 1 gal/sq on both the membrane and the substrate for a total of 2 gal/sq, or Cooley WB Bonding Adhesive applied at the rate of 0.67 gal/sq to the substrate, or Cooley Low VOC Adhesive applied at the rate of 0.83 gal/sq on both the membrane and the substrate for a total of 1.67 gal/sq.

Maximum Design

Pressure: -45 psf; (See General Limitation #9.)



NOA No.: 09-0608.05
Expiration Date: 08/03/11
Approval Date: 07/15/09
Page 10 of 19

Deck Type 7I: Recover, Insulated
Deck Description: Steel, Wood
System Type C(2): All layers of insulation simultaneously attached; C3 Plus membrane fully adhered.

All General and System Limitations apply.

One or more layers of the following insulations:

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Fiber Top E Minimum 0.75" thick	1, 2, 4, 26, 27, 28, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69	1: 2.6 ft ²
Fiber Top C, E Minimum 1" thick	1, 2, 4, 26, 27, 28, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44	1: 2 ft ²
High Density Fiberboard, Armor Board Regular and High Density, Esgard and Esgard High Strength, EnergyGuard High Density Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber, GAFTEMP Fiberboard, Knight-Celotex Fiberboard Premium and High Density, High Density Roof Board, Fiber Top C Minimum 1" thick	1, 2, 4, 26, 27, 28, 32, 33, 34, 35, 40, 41, 42, 43, 44	1: 2 ft ²

Note: All layers shall be simultaneously fastened. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: (Optional) Any UL or FM approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: (Optional) Minimum 1/4" Dens Deck secured to the deck with the insulation.

Membrane: C3 Plus Membrane fully adhered to the insulation with Cooley Bonding Adhesive (C-1006) applied at the rate of 0.83 gal./sq. on both the membrane and the substrate for a total of 1.67 gal./sq., and a heat welded seam minimum 1 1/2" wide at the laps, or Cooley PVC Bonding Adhesive applied at the rate of 1 gal/sq on both the membrane and the substrate for a total of 2 gal/sq, or Cooley WB Bonding Adhesive applied at the rate of 0.67 gal/sq to the substrate, or Cooley Low VOC Adhesive applied at the rate of 0.83 gal/sq on both the membrane and the substrate for a total of 1.67 gal/sq

Maximum Design Pressure: -45 psf; (See General Limitation #9.)



Deck Type 7I: Recover, Insulated

Deck Description: wood/steel/concrete/cementitious wood fiber/gypsum

System Type C(3): All layers of insulation simultaneously fastened; membrane fully adhered.

All General and System Limitations apply.

One or more layers of the Base Layer insulation covered by one layer of the insulation listed as Top Layer.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam II, Multi-Max FA, E'NRG'Y-2, PSI-25, ISO-95+, ISO + GL, Hy-Therm AP, Pyrox Minimum 1.4" thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam II, Multi-Max FA Minimum 1.5" thick	1, 5, 70, 72, 73	1:2 ft ²
ISO 95 +, ISO 95 + GL Minimum 1.4" thick	1, 5, 70, 72, 73	1:2 ft ²
E'NRG'Y-2, PSI-25, Hy-Therm AP, Pyrox Minimum 1.4" thick	1, 5, 14, 15, 70, 72, 73	1:2 ft ²
High Density Fiberboard, FM-90 High Density, Armor Board Regular, Esgard, Celotex Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber Minimum ½" thick	1, 5, 14, 15, 70, 72, 73	1:2 ft ²

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder may be installed over the deck or the base layer of insulation.

Barrier: (Optional) 1/2" or 5/8" gypsum or Dens Deck secured to the deck with the insulation.

Membrane: C3 Fleece Back membrane fully adhered to the insulation with Cooley Bonding Adhesive (C-1006) applied at the rate of 1 gal./sq., or approved mopping asphalt applied at the rate of 25 lbs./sq..

Maximum Design Pressure: -45 psf. (See General Limitation #7)



Deck Type 7I: Recover, Insulated

Deck Description: Steel, Wood, Concrete

System Type D(1): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply.

Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Conperl, EnergyGuard Perlite, FescoBoard, Armor Board High Density, BP High Strength, FM-90 Traffic Top/High Density, ERS Redi-Deck, Riber Top C, E, S, EnergyGuard High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek, Pyrox, Hy-Therm AP, Whiteline, ENRGY-2, ENRGY-3, PSI-25, Mutli-Max, Thermarroof Plus, AC Foam II, Ultra/M-11ISO/glas, ISO 95+, ISO 95+GL, Ultragard, Fesco Foam Minimum 1" thick	N/A	N/A
High Density Fiberboard, FM-90 High Density, Armor Board Regular, Esgard, EnergyGuard Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber Minimum 1/2" thick	N/A	N/A

Note: Total Insulation Layer shall be 1" thick Maximum. All layers of insulation and base sheet shall be simultaneously attached. See membrane below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Vapor Retarder: (Optional) Any UL or FM approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: (Optional) Minimum 1/4" Dens Deck secured to the deck with the insulation.

Membrane: C3 Plus Membrane attached through the preliminary attached insulation as specified below.

(Steel and Wood)

Fastening #1: Membrane is mechanically attached using Olympic XHD Fastening System; Tru-Fast 2.4" Barbed Seam Plate and Tru-Fast EHD fasteners; ITW Buildex 2-3/8" Round Barbed Seam Plates and #15 Roofgrip fasteners; Dekfast 2-1/2" HS Membrane Plates and Dekfast #15 HS fasteners spaced 6" o.c. through 5" wide laps spaced in rows 73" apart. The 5" wide laps are then sealed with a min. 1-1/2" wide heat seal.

(Concrete)

Fastening #2: Membrane is mechanically attached using Olympic HD or CD-10 Fasteners and Olympic XHD Seam Plate; ITW Buildex 2-3/8" Round Barbed Seam Plates and #15 Roofgrip fasteners; Dekfast 2-1/2" HS Membrane Plates and Dekfast #15 HS fasteners spaced 6" o.c. through 5" wide laps spaced in rows 73" apart. The 5" wide laps are then sealed with a min. 1-1/2" wide heat seal.

Maximum Design

Pressure: -60 psf; (See General Limitation #7.)



Deck Type 7I: Recover, Insulated
Deck Description: Steel, Wood, Concrete
System Type D(2): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply.

Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Conperl, EnergyGuard Perlite, FescoBoard, Armor Board High Density, BP High Strength, FM-90 Traffic Top/High Density, ERS Redi-Deck, Riber Top C, E, S, EnergyGuard High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek, Pyrox, Hy-Therm AP, Whiteline, ENRGY-2, ENRGY-3, PSI-25, Mutli-Max, Thermarroof Plus, ACfoam II, Ultra/M-11ISO/glas, ISO 95+, ISO 95+GL, Ultragard, Fesco Foam Minimum 1" thick	N/A	N/A
High Density Fiberboard, FM-90 High Density, Armor Board Regular, Esgard, EnergyGuard Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber Minimum ½" thick	N/A	N/A

Note: Total Insulation Layer shall be 1" thick Maximum. All layers of insulation and base sheet shall be simultaneously attached. See membrane below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Vapor Retarder: (Optional) Any UL or FM approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: (Optional) Minimum ¼" Dens Deck secured to the deck with the insulation.

Membrane: C3 Plus Membrane attached through the preliminary attached insulation as specified below.

(Steel and Wood)

Fastening #1: Membrane is mechanically attached using Olympic XHD Fastening System; Tru-Fast 2.4" Barbed Seam Plate with Tru-Fast EHD fasteners; ITW Buildex 2-3/8" Round Barbed Seam Plates with #15 Roofgrip fasteners; Dekfast 2-1/2" HS Membrane Plates with Dekfast #15 HS fasteners spaced 12" o.c. through 5" wide laps spaced in rows 73" apart. The 5" wide laps are then sealed with a min. 1-1/2" wide heat seal.

(Concrete)

Fastening #2: Membrane is mechanically attached using Olympic HD or CD-10 Fasteners and Olympic XHD Seam Plate; ITW Buildex 2-3/8" Round Barbed Seam Plates and #15 Roofgrip fasteners; Dekfast 2-1/2" HS Membrane Plates and Dekfast #15 HS fasteners spaced 12" o.c. through 5" wide laps spaced in rows 73" apart. The 5" wide laps are then sealed with a min. 1-1/2" wide heat seal.

(Steel)

Fastening #3: Membrane is mechanically attached using Dekfast Isofast IF 2¾" Stress Plates with Dekfast #15 HS or Dekfast #15 Belted Fasteners spaced 6" o.c. through 6" wide laps spaced in rows 66" apart. The 6" wide laps are then sealed with a min. 1½" wide heat seal.

Maximum Design Pressure: -45 psf; (See General Limitation #7.)



Deck Type 7I: Recover, Insulated

Deck Description: wood/steel/concrete

System Type D(3): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply.

One or more layers of the Base Layer insulation covered by one or more layers of the insulation listed as Top Layer.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
------------------------------	---	--

EPS over gypsum barrier.
Minimum 1" thick

N/A

N/A

Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
---	---	--

Celotherm, Conperl, GAFTEMP Permalite, FescoBoard, Armor Board High Density, BP High Strength, FM-90 Traffic Top/High Density, ERS Redi-Deck, Riber Top C, E, S, GAFTEMP High Density, Roof Insulation Board, High Density Fiberboard, Fiber Base HD1, HD6, Structodek, Hy-Tec, Pyrox, Hy-Therm AP, Whiteline, Hy-Therm SP, E'NRG'Y-2, PSI-25, Mutli-Max, Thermanroof Plus, ACfoam II, Ultra/M-11ISO/glas, ISO 95+, ISO 95+GL, Ultragard, Fesco Foam
Minimum 1" thick

N/A

N/A

Firesield, High Density Fiberboard, Fiber Top C, E or S, Armor Board Regular, Esgard, Knight-Celotex Premium Fiberboard, GAFTEMP Fiberboard, Huebert Fiberboard, Kop-R Wood Fiber
Minimum 1/2" thick

N/A

N/A

Note: All layers of insulation and base sheet shall be simultaneously attached. See membrane below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder may be installed over the deck or the base layer of insulation.

Barrier: (Optional) 1/2" or 5/8" gypsum or Dens Deck secured to the deck with the insulation.

Membrane: C3 Membrane or C3 Fleece Backed Membrane attached through the preliminary attached insulation as specified below.

Fastening #1: Roof cover is rolled over the insulation and its 2" laps are sealed. Membrane is mechanically attached using SFS Isofast IF/IG-82x40 plates and IF or IG screws (wood or steel only), Olympic 2" round steel, ASAP or Solweld plates with Olympic Standard (wood or steel only), Heavy Duty Screws or CD-10 (concrete only), Dekfast or Solweld plates with Dekfast #14 or #15 screws, or Solweld plates with HD Insulfixx spaced 6" o.c. in rows 8 ft. apart or 12" o.c. in rows 4 ft. apart. Fastener rows are stripped in with 6" wide strips of membrane or 6" diameter membrane caps, heat or solvent welded.



Fastening #2: Membrane is mechanically attached using Olympic 2" round steel, ASAP, or Solweld plates with Olympic Standard (wood or steel only), Heavy Duty Screws or CD-10 (concrete only), Dekfast or Solweld plates with Dekfast #14 or #15 screws, or Solweld plates with HD Insulfixx spaced 18" o.c. through 3" wide laps spaced 48" apart.

Fastening #3: Roof cover is rolled over the insulation and its 2" laps are sealed. Cooley Plate Adhesive is liberally applied to the bottom of the Solweld plates. Membrane is mechanically attached using the adhesive coated Solweld plates with Olympic Standard (wood or steel only), Heavy Duty Screws or CD-10 (concrete only), Dekfast #14 or #15 screws, or HD Insulfixx spaced 18" o.c. in rows spaced 48" apart. 6" diameter membrane caps is coated with Cooley Plate Adhesive and placed over the fastener/plate head.

Fastening #4: 78" wide membrane is mechanically attached using Olympic 2" round steel or ASAP plates with Olympic Standard (wood or steel only), Heavy Duty Screws, or CD-10 (concrete), Dekfast plates with Dekfast Omega, #14 or #15 screws or HD Insulfixx S spaced 18" o.c. through 6" wide laps spaced 72" apart.

Maximum Design Pressure: -45 psf (See General Limitation # 7)



Deck Type 7: Recover, Non-Insulated

Deck Description: wood/steel/concrete

System Type E(1): Membrane mechanically attached to deck.

All General and System Limitations apply.

Barrier: (Optional) 1/2" or 5/8" gypsum or Dens Deck secured to the deck with 4 approved fasteners per board.

Membrane: C3 Membrane or C3 Fleece Backed Membrane attached as specified below.

Fastening #1: Roof cover is rolled over the insulation and its 2" laps are sealed. Membrane is mechanically attached using SFS Isofast IF/IG-82x40 plates and IF or IG screws (wood or steel only), Olympic 2" round steel, ASAP or Solweld plates with Olympic Standard (wood or steel only), Heavy Duty Screws or CD-10 (concrete only), Dekfast or Solweld plates with Dekfast #14 or #15 screws, or Solweld plates with HD Insulfixx spaced 6" o.c. in rows 8 ft. apart or 12" o.c. in rows 4 ft. apart. Fastener rows are stripped in with 6" wide strips of membrane or 6" diameter membrane caps, heat or solvent welded.

Fastening #2: Membrane is mechanically attached using Olympic 2" round steel, ASAP, or Solweld plates with Olympic Standard (wood or steel only), Heavy Duty Screws or CD-10 (concrete only), Dekfast or Solweld plates with Dekfast #14 or #15 screws, or Solweld plates with HD Insulfixx spaced 18" o.c. through 3" wide laps spaced 48" apart.

Fastening #3: Roof cover is rolled over the insulation and its 2" laps are sealed. Cooley Plate Adhesive is liberally applied to the bottom of the Solweld plates. Membrane is mechanically attached using the adhesive coated Solweld plates with Olympic Standard (wood or steel only), Heavy Duty Screws or CD-10 (concrete only), Dekfast #14 or #15 screws, or HD Insulfixx spaced 18" o.c. in rows spaced 48" apart. 6" diameter membrane caps is coated with Cooley Plate Adhesive and placed over the fastener/plate head.

Fastening #4: 78" wide membrane is mechanically attached using Olympic 2" round steel or ASAP plates with Olympic Standard (wood or steel only), Heavy Duty Screws, or CD-10 (concrete), Dekfast plates with Dekfast Omega, #14 or #15 screws or HD Insulfixx S spaced 18" o.c. through 6" wide laps spaced 72" apart.

Maximum Design Pressure: -45 psf (See General Limitation #7)



Deck Type 7: Recover, Non-Insulated

Deck Description: cementitious wood fiber/gypsum

System Type E(2): Anchor sheet mechanically attached, membrane adhered.

All General and System Limitations apply.

Anchor Sheet: One ply of Celotex Hydrostop, GAFGLAS #75, GAFGLAS Stratavent, Johns Manville Ventsulation or Johns Manville PermaPly 28 secured to the deck with Olympic NTB Magnum fasteners at 1 per 2 sq. ft.

Note: Anchor sheet fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements set forth in the applicable Building Code.

Membrane: C3 Fleece Back Roof Cover fully adhered to the anchor sheet with Cooley Bonding Adhesive (C-1006) applied at the rate of 1 gal./sq., or approved mopping asphalt applied at the rate of 25 lbs./sq..

Maximum Design Pressure: -45 psf (See General Limitation #9)



RECOVER SYSTEM LIMITATIONS:

- 1 Existing roof surfaces used as a bonding substrate shall be tested for uplift resistance, in compliance with Testing Application Standard TAS 124 to the calculated design pressures of the field, perimeter and corner areas, determined in compliance with the Florida Building Code requirements.
- 2 All System Limitations and General Limitations shall apply. See specific deck type Notice of Acceptance for deck type System Limitations.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.
Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 09-0608.05
Expiration Date: 08/03/11
Approval Date: 07/15/09
Page 19 of 19