



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Siplast
1111 Highway 67 South
Arkadelphia, AR 71923**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Siplast Modified Bitumen Roofing Systems Over Concrete Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 08-0731.02 and consists of pages 1 through 30.
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No: 09-0901.13
Expiration Date: 04/14/13
Approval Date: 01/20/10
Page 1 of 30**

ROOFING ASSEMBLY NOTICE OF ACCEPTANCE

Category: Roofing
Sub-Category: Modified Bitumen
Material: SBS/SBS Foil
Deck Type: Concrete
Maximum Design Pressure -402.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Parabase	3' x 108'	ASTM D 4601	Asphalt coated fiberglass base sheet for mechanically fastened applications.
Parabase FS	3' x 108'	ASTM D 4601	Asphalt coated fiberglass base sheet with a polyolefin back surfacing for mechanically fastened applications.
Parabase Plus	3.28' x 102.3'; 28 lbs./sq.	ASTM D 5147	Elastomeric asphalt coated base sheet.
Paraglas	3' x 180'; 12 lbs./sq.	ASTM D 2178 Type IV	Asphalt coated fiberglass mat used as a base or ply sheet.
Paravent	3' x 108'	ASTM D 4601	Asphalt coated venting fiberglass base sheet with 1.5 inch perforations.
Paravent FS	3' x 108'	ASTM D 4601	Asphalt coated venting fiberglass base sheet with 1.5 inch perforations and a polyolefin back surfacing..
Paradiene 20	3.28' x 50'; 90 lbs./ sq.	ASTM D 6163	Asphalt elastomer sheet with random fiberglass mat reinforcement used as the base ply of a Paradiene 20/30 system.
Paradiene 20 HT	3.28' x 50'; 90 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply of a Paradiene 20/30 system.
Paradiene 20 EG	3.28' x 33.5'; 90 lbs./sq.	ASTM D 6163	Heavy duty asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply in Paradiene systems.
Paradiene 20 HV	3.28' x 33.5'; 90 lbs./sq.	ASTM D 6163	Heavy duty asphalt elastomer sheet with random fiberglass mat reinforcement used as a base ply of a Paradiene 20/30 system.
Paradiene 20 PR	3.28' x 50'; 55 lbs./sq.	ASTM D 6162	Asphalt elastomer sheet with polyester fiberglass scrim composite reinforcement used as the top ply of a Paradiene 20/20 PR system having a gravel surfacing. Has additional puncture resistance.
Paradiene 20 TG	3.28' x 33.5'; 70 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with random fiberglass reinforcement used as the base ply of a Paradiene 20/30 TG Series system.



NOA No: 09-0901.13
 Expiration Date: 04/14/13
 Approval Date: 01/20/10
 Page 2 of 30

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Paradiene 20 TG F	3.28' x 33.5'; 70 lbs./sq.	ASTM D 4601	Asphalt elastomer sheet with random fiberglass reinforcement and a silica parting agent on the top surface, for use as the base ply of a Paradiene 20/30 TG Series system.
Paradiene 20 HT TG	3.28' x 33.5'; 70 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply of a Paradiene 20/30 system.
Paradiene 20 EG TG	3.28' x 33.5'; 100 lbs./sq.	ASTM D 5147	Heavy duty asphalt elastomer sheet with fiberglass scrim reinforced for use as a base ply in Paradiene 20TG/30TG systems.
Paradiene 20 HV TG	3.28' x 33.5'; 100 lbs./sq.	ASTM D 6163	Heavy duty asphalt elastomer sheet with random fiberglass mat reinforcement used as a base ply of a Paradiene 20TG/30TG system.
Paradiene 20 PR TG	3.28' x 33.5'; 96 lbs./sq.	ASTM D 6164	High performance SBS modified bitumen finish ply designed for use in gravel surfaced. Used as a surface ply of a Paradiene 20/20TG system.
Paradiene 20 TS	3.28' x 33.5'; 76 lbs./sq.	ASTM D 6163	High performance, semi adhered SBS modified bitumen with random fiberglass mat reinforcement used as a base ply of Paradiene 20/30 systems.
Terabase	3.28' x 50'; 90 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with random fiberglass mat reinforcement used as the base ply for Teranap systems.
Terabase TG	3.28' x 33.5'; 70 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with random fiberglass reinforcement used as the base ply for Teranap systems.
Teranap	3.28' x 26'; 97 lbs./sq.	ASTM D 5147	A non-woven polyester mat impregnated and coated with high quality SBS modified bitumen. The surface of the sheet is protected by a polyester film or by sand.
Paradiene 30 Paradiene 30 CR	3.28' x 33.5'; 85 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with mineral surfacing and random glass mat reinforcement, for use as the top ply of a Paradiene 20/30 system.
Paradiene 30FR Paradiene 30 FR CR	3.28' x 33.5'; 85 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with mineral surfacing and random glass mat reinforcement, for use as the top ply of a Paradiene 20/30 system.
Paradiene 30 HT	3.28' x 33.5'; 85 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene 20/30 system.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Paradiene 30 HTFR	3.28' x 33.5'; 87 lbs./sq.	ASTM D 6163	Fire-rated asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene 20/30 FR system.
Paradiene 30 MW	3.28' x 33.5'; 87 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with mineral surfacing and ultra high tensile fiberglass reinforcement for use as the top ply of a Paradiene 20/30 FR system.
Paradiene 30 MW FR	3.28' x 33.5'; 87 lbs./sq.	ASTM D 6163	Fire rated asphalt elastomer sheet with mineral surfacing and ultra high tensile fiberglass reinforcement for use as the top ply of a Paradiene 20/30 FR system.
Paradiene 30 TG Paradiene 30 CR TG	3.28' x 25.25'; 80 lbs./sq.	ASTM D 5147	Fire rated asphalt elastomer sheet with mineral surfacing and random fiberglass mat reinforcement for use as the top ply sheet of a Paradiene 20/30 TG Series system.
Paradiene 30 FRTG Paradiene 30 CR FR TG	3.28' x 25.25'; 80 lbs./sq.	ASTM D 6163	Fire rated asphalt elastomer sheet with mineral surfacing and random fiberglass mat reinforcement for use as the top ply sheet of a Paradiene 20/30 TG Series system.
Paradiene 30 HTTG	3.28' x 25.25'; 80 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene 20/30 TG Series system requiring high tensile strength.
Paradiene 30 HTFRTG	3.28' x 25.25'; 80 lbs./sq.	ASTM D 6163	Fire rated asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene TG Series system.
Paradiene 40 FR	3.28' x 26'; 115 lbs./sq.	ASTM D 5147	Fire rated asphalt elastomer sheet with mineral surfacing, glass mat/glass scrim reinforced.
Parafor 50 LT	3.28' x 17.5'; 114 lbs./sq.	ASTM D 6162	Heavy duty asphalt elastomer sheet with mineral surfacing, polyester mat/fiberglass scrim reinforced.
Paralosa TS	3.28' x 26.25'; 141 lbs./sq.	ASTM D 6162	Heavy duty asphalt elastomer sheet with mineral surfacing, polyester mat/fiberglass scrim reinforced. For use as single ply membrane over concrete decks.
IREX 30	3.28' x 34'; 74 lbs./sq.	ASTM D 5147	High-melt asphalt sheet with random fiberglass mat reinforcement for use as the base ply sheet for a Veral system.
IREX 40	3.28' x 34'; 89 lbs./sq.	ASTM D 5147	High-melt asphalt sheet with random fiberglass mat reinforcement for use as the base ply sheet for a Veral system.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
IREX HT	3.28' x 34'; 89 lbs./sq.	ASTM D 5147	High-melt asphalt sheet with fiberglass scrim reinforcement for use as a base ply sheet for the Veral system.
IREX PR	3.28' x 34'; 89 lbs./sq.	ASTM D 5147	High-melt asphalt sheet with polyester mat / fiberglass scrim reinforcement for use as a mechanically fastened base sheet with the Veral system.
Veral Aluminum	3.28' x 33.5'; 90 lbs./sq.	ASTM D 6298	Aluminum clad asphalt elastomer sheet with woven fiberglass reinforcement for use as the top ply sheet of a Veral system.
Veral Copper	3.28' x 33.5'; 105 lbs./sq.	ASTM D 6298	Copper clad asphalt elastomer sheet with fiberglass scrim reinforcement for use as the top ply of a Veral system.
Veral Stainless Steel	3.28' x 33.5'; 105 lbs./sq.	ASTM D 6298	Stainless steel clad asphalt elastomer sheet with fiberglass scrim reinforcement for use as the top ply sheet of a Veral system.
Veral Spectra Series	3.28' x 33.5'; 90 lbs./sq.	ASTM D 6298	Aluminum clad asphalt elastomer sheet with fiberglass scrim reinforcement and factory finished with a Kynar PVDF coating.
PA 100 Mopping Asphalt		ASTM D 312 Type IV	Mopping Asphalt
PA 311/311 M/311LS Adhesive	5 or 55 gal.	ASTM D 4479	Blend of adhesive asphalts and quick-drying solvents.
PA 828 Flashing Cement	5 gal.	ASTM D 4586	Flashing Cement
PA 1021 Plastic Cement	5 gal.	ASTM D 4586	Asphalt cutback reinforced general purpose cement with non-asbestos fibers.
PA 1125 Asphalt Primer	5 or 55 gal.	ASTM D 41	Asphalt primer.
PC - 227	5 or 55 gal	ASTM D 6083	Elastomeric roof coating.
Para-Stik Insulation Adhesive	30 lb pressurized cylinders	N/A	A single component moisture curing Urethane foam adhesive



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
Paratherm, Paratherm W, Paratherm H	Isocyanurate Insulation	Siplast
Siplast Wood Fiberboard	Wood fiber insulation	Siplast
ACFoam II	Polyisocyanurate Insulation	Atlas Roofing Corp.
Fiberglas	Fiber glass roof insulation.	Generic
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic
High Density Wood Fiberboard	High Density Wood Fiber insulation board	Georgia Pacific
Perlite Insulation Board	Perlite Insulation	Generic
Dens Deck, Dens Deck Prime	Water resistant gypsum	G-P Gypsum Corp.
H-Shield	Polyisocyanurate Foam Insulation.	Hunter Panels LLC
ENRGY 3	Polyisocyanurate Insulation.	Johns Manville
Fiber Glass Roof Insulation	Fiberglas roof insulation.	Johns Manville
ISORoc	Polyisocyanurate foam insulation.	Johns Manville
DuraBoard	Expanded Mineral Fiber	Johns Manville
FescoBoard	Perlite Insulation	Johns Manville
Multi-Max, FA	Polyisocyanurate foam insulation.	RMax Inc.
SecuRock	Water resistant recycled cellulose and synthetic gypsum	USG

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	N/A	N/A	N/A	N/A



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	FMRC 4470 - TAS 114	J.I. 2Y1A1.AM	04/15/96
	FMRC 4470 - TAS 114	J.I. 3Z3A7.AM	04/12/96
	FMRC 4470	3008071	01/18/01
	FMRC 4470	3008210	04/10/01
	FMRC 4470	3015680	11/24/03
	FMRC 4470	3021507	11/04/05
	FMRC 4470	3023079	05/12/06
	FM 4470	3026749	07/27/06
	FM 4470	3031655	05/27/08
	FM 4470	3033854	01/16/09
Atlantic & Caribbean Roof Consulting, LLC	TAS 114-95 Appendix D	04-002	10/05/04
	TAS 114-95 Appendix D	04-003	10/05/04
	TAS 114-95 Appendix D	06-025	06/28/06
	TAS 114-95 Appendix D	07-035	05/29/07
Underwriters Laboratories, Inc.	UL 790 - PA 114	R10630	01/01/96
Exterior Research & Design, LLC.	TAS 114	#4701.02.96-1	02/28/96
	TAS 114	#4701.09.96-1	08/22/96
	TAS 117	C8500SC.11.07	11/30/07



APPROVED ASSEMBLIES

Membrane Type: SBS

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(1): All layers of insulation adhered with approved asphalt.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
One or more layers of any of the following insulations:		
ENRGY-3, ACFoam-I, II, Paratherm W, H-Shield Minimum 1" thick	N/A	N/A
ISORoc Minimum 1.3" thick	N/A	N/A
Fiberglas Minimum 1" thick	N/A	N/A
Perlite Minimum ¾" thick	N/A	N/A
High Density Wood Fiberboard Minimum ½" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One or more plies of Paraglas adhered to the insulation with approved mopping asphalt at an application rate of 20-40 lbs/sq.

Ply Sheet: Paradiene 20 TG, 20 TG F, 20 HVTG, 20 HTTPG, 20 EGTG or Terabase TG adhered by torch or Paradiene 20, 20 HT, 20 HV, 20 EG or Terabase adhered with approved mopping asphalt at an application rate of 20-40 lbs/sq. or with PA 311/311M adhesive.

Membrane: Paradiene 20 PR, 30 FR, 30 CRFR, 30 MW FR or 30 HTFR adhered in approved mopping asphalt or PA 311/311M adhesive, or Paradiene 20, PRTG, Teranap, Paradiene 30 FRTG, 30 CRFRTG, 30 HTFRTG or Parafor 50 LT adhered by torch.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure: -52 psf (See General Limitation #9)



Membrane Type: SBS Foil
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(2): All layers of insulation adhered to deck with approved asphalt.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
One or more layers of any of the following insulations:		
ENRGY-3, ACFoam-II, Paratherm W, H-Shield Minimum 1" thick	N/A	N/A
ISORoc Minimum 1.3" thick	N/A	N/A
Fiberglas Minimum 1" thick	N/A	N/A
Perlite Minimum ¾" thick	N/A	N/A
High Density Wood Fiberboard Minimum ½" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One or more plies of Paraglas adhered to the insulation with approved mopping asphalt at an application rate of 20-40 lbs/100 ft².

Ply Sheet: IREX 30, IREX 40, IREX HT, Paradiene 20, 20 HT, 20 HV or 20 EG adhered in approved mopping asphalt at an application rate of 20-40 lbs/sq. or IREX 40, IREX HT, Paradiene 20 TG, 20 TG F, 20 HVTG, 20 HTTG or 20 EGTG applied by torch.

Membrane: Veral adhered in approved mopping asphalt or by torch.

Surfacing: None

Maximum Design Pressure: -45 psf (See General Limitation #9)



Membrane Type: SBS

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(3): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
One or more layers of any of the following insulations:		
Paratherm, ENRGY-3, ACFoam-II, Paratherm W, H-Shield Minimum 1.4" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or Insta-Stik /Para-Stik adhesive applied in continuous ¾" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: One ply of Paravent or Paravent FS loose laid and lapped a minimum of 1".

Ply Sheet: Paradiene 20 TG, 20 TG F, 20 HVTG, 20 HTTG or 20 EGTG or Terabase TG adhered by torch or Paradiene 20, 20 HT, 20 HV, 20 EG or Terabase adhered with approved mopping asphalt at an application rate of 20-40 lbs/sq. or with PA 311/311M adhesive.

Membrane: Paradiene 20 PR, 30 FR,30CRFR, 30 MW FR or 30 HTFR adhered in approved mopping asphalt or PA 311/311M adhesive, or Paradiene 20, PRTG, Teranap, Paradiene 30 FRTG,30CRFRTG or 30 HTFRTG adhered by torch.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure: -90 psf (See General Limitation #9)



Membrane Type: SBS Foil

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(4): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
One or more layers of any of the following insulations:		
Paratherm, ENRGY-3, ACFoam II, Paratherm W, H-Shield Minimum 1.4" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or Insta-Stik/Para-Stik adhesive applied in continuous 3/4" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: One ply of Paravent or Paravent FS loose laid and lapped a minimum of 1".

Ply Sheet: IREX 30, IREX 40, IREX HT, Paradiene 20, 20 HT, 20 HV or 20 EG adhered in approved mopping asphalt at an application rate of 20-40 lbs/sq.

Membrane: Veral adhered in approved mopping asphalt or by torch.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure: -90 psf (See General Limitation #9)



Membrane Type: SBS

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(5): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

Base Insulation Layer (Optional)	Insulation Fasteners Table 3	Fastener Density/ft²
One or more layers of any of the following insulations:		
Paratherm H, MultiMax, FA, H-Shield Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
Dens Deck Minimum ¼" thick	N/A	N/A
DuraBoard Minimum ¾" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or Insta-Stik/Para-Stik adhesive applied in continuous ¾" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One or more plies of Paraglas adhered to the insulation with approved mopping asphalt at an application rate of 20-25 lbs./sq. See General Limitation #4.

Ply Sheet: Paradiene 20 TG, 20 TG F, 20 HVTG, 20 HTTG or 20 EGTG or Terabase TG adhered by torch or Paradiene 20, 20 HT, 20 HV, 20 EG or Terabase adhered with approved mopping asphalt at an application rate of 20-40 lbs/sq. or with PA 311/311M adhesive.

Membrane: Paradiene 20 PR, 30 FR, 30CRFR, 30 MW FR or 30 HTFR adhered in approved mopping asphalt or PA 311/311M adhesive, or Paradiene 20, PRTG, Teranap, Paradiene 30 FRTG, 30CRFRTG or 30 HTFRTG adhered by torch.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure:
-157.5 psf (using Dens Deck) (See General Limitation #9)
-112.5 psf (using DuraBoard) (See General Limitation #9)



Membrane Type: SBS Foil

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(6): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

Base Insulation Layer (Optional)

**Insulation Fasteners
Table 3**

**Fastener
Density/ft²**

One or more layers of any of the following insulations:

**MultiMax, FA, H-Shield, Paratherm H
Minimum 1.5" thick**

N/A

N/A

Top Insulation Layer

**Insulation Fasteners
Table 3**

**Fastener
Density/ft²**

**Dens Deck
Minimum ¼" thick**

N/A

N/A

**DuraBoard
Minimum ¾" thick**

N/A

N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or Insta-Stik/Para-Stik adhesive applied in continuous ¾" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One or more plies of Paraglas adhered to the insulation with approved mopping asphalt at an application rate of 20-25 lbs./sq. See General Limitation #4.

Ply Sheet: IREX 30, IREX 40, IREX HT, Paradiene 20, 20 HT, 20 HV or 20 EG adhered in approved mopping asphalt at an application rate of 20-40 lbs./sq.

Membrane: Veral adhered in approved mopping asphalt or by torch.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design

Pressure: -157.5 psf (using Dens Deck) (See General Limitation #9)

-112.5 psf (using DuraBoard) (See General Limitation #9)



Membrane Type: SBS
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(7): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
ENRGY-3, H-Shield Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
Perlite Minimum ¾" thick	N/A	N/A
High Density Wood Fiberboard Minimum ½" thick	N/A	N/A
Dens Deck Minimum ¼" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One or more plies Paraglas adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs/sq.

Ply Sheet: Paradiene 20, 20 HT, 20 HV, 20 EG or Terabase TG adhered in full mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs/sq or with PA 311/311M adhesive or Paradiene 20 TG, 20 TG S, 20 HVTG, 20 HTTPG or 20 EGTG, adhered by torch.

Membrane: Paradiene 20 PR, 30 FR, 30CRFR, 30 MW FR or 30 HTFR adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs/sq or PA 311/311M adhesive or Paradiene 20, PRTG, Teranap, Paradiene 30 FRTG, 30CRFRTG, 30 HTFRTG or Parafor 50 LT adhered by torch.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design

Pressure: -240 psf (using Perlite) (See General Limitation #9)
-370 psf (using Dens Deck) (See General Limitation #9)
-375 psf (using High Density Wood Fiberboard) (See General Limitation #9)



Membrane Type: SBS Foil

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(8): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
ENRGY-3, H-Shield Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
Perlite Minimum ¾" thick	N/A	N/A
High Density Wood Fiberboard Minimum ½" thick	N/A	N/A
Dens Deck Minimum ¼" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One or more plies Paraglas adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs/sq.

Ply Sheet: Paradiene 20, 20 HT, 20 HV or 20 EG adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs/sq or with PA 311/311M adhesive or Paradiene 20 TG, 20 TS F, 20 HVTG, 20 HTTPG or 20 EGTG, adhered by torch.

Membrane: Veral adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs/sq. or adhered by torch.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design

Pressure:
-240 psf (using Perlite) (See General Limitation #9)
-370 psf (using Dens Deck) (See General Limitation #9)
-375 psf (using High Density Wood Fiberboard) (See General Limitation #9)



Membrane Type: SBS Foil

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(9): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
ACFoam II, Paratherm W, H-Shield Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
Dens Deck Minimum ¼" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Ply Sheet: Paradiene 20, 20 HT, 20 HV or 20 EG adhered with PA 311/311M.

Membrane: Paradiene , 30 FR,30 CRFR, or 30 HTFR adhered in PA 311/311M

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure: -180 psf (See General Limitation #9)



Membrane Type: SBS Foil

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(10): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer

**Insulation Fasteners
Table 3**

**Fastener
Density/ft²**

**ACFoam II, Paratherm W, H-Shield
Minimum 1.5" thick**

N/A

N/A

Top Insulation Layer

**Insulation Fasteners
Table 3**

**Fastener
Density/ft²**

**Georgia Pacific High Density Roof Fiberboard
Minimum 1/2" thick**

N/A

N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Ply Sheet: Paradiene 20, 20 HT, 20 HV or 20 EG adhered with PA 311/311M.

Membrane: Paradiene, 30 FR, 30 CRFR, or 30 HTFR adhered in PA 311/311M

Note: Refer to manufacturer's specifications for specific application requirements.

**Maximum Design
Pressure:** -75 psf (See General Limitation #9)



**NOA No: 09-0901.13
Expiration Date: 04/14/13
Approval Date: 01/20/10
Page 17 of 30**

Membrane Type: SBS Foil

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(11): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
ACFoam II, Paratherm W, H-Shield Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
Johns Manville FescoBoard Minimum ¾" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Ply Sheet: Paradiene 20, 20 HT, 20 HV or 20 EG adhered with PA 311/311M.

Membrane: Paradiene , 30 FR,30 CRFR, or 30 HTFR adhered in PA 311/311M

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure: -120 psf (See General Limitation #9)



Membrane Type: SBS Foil

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(12): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer

ACFoam II, Paratherm W, H-Shield

Minimum 1.5" thick

**Insulation Fasteners
Table 3**

**Fastener
Density/ft²**

N/A

N/A

Top Insulation Layer

**Insulation Fasteners
Table 3**

**Fastener
Density/ft²**

Johns Manville Duraboard

Minimum ¾" thick

N/A

N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Ply Sheet: Paradiene 20, 20 HT, 20 HV or 20 EG adhered with PA 311/311M.

Membrane: Paradiene , 30 FR,30 CRFR, or 30 HTFR adhered in PA 311/311M

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design

Pressure: -82.5 psf (See General Limitation #9)



Membrane Type: SBS/SBS Foil

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(13): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
One or more layers of any of the following insulations:		
ACFoam II, Paratherm W, H-Shield Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners Table 3	Fastener Density/ft²
SecuRock Roof Guard Panels Minimum 1/4" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered with Insta-Stik/Para-Stik adhesive applied in continuous 3/4" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: Paradiene 20, 20 HT, 20 HV or 20 EG adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs/sq or with PA 311/311M/311LS cold adhesive applied at a rate of 1.5-2.5 gal/square or Paradiene 20 TG, 20 HTTG or 20 EGTG, adhered by torch.

Ply Sheet: None.

Membrane: Paradiene 30, 30 FR, 30 CRFR, or 30 HTFR adhered in approved mopping asphalt or PA 311/311M/311 LS adhesive, or Paradiene 30 FRTG, 30 CRFRTG, 30 HTFRTG, Parafor 30 Parafor 50 LT, Veral Aluminum, Veral Copper, Veral Stainless, or Veral Spectra adhered by torch.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure: -285 psf (See General Limitation #9)



Membrane Type: SBS/SBS Foil
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(14): Vapor barrier and insulation adhered with approved asphalt or adhesive.

All General and System Limitations apply.

Vapor Barrier: Paradiene 20 TG, Paradiene 20 HT TG or Paradiene 20 EG TG torch adhered or Paradiene 20, Paradiene 20 HT, Paradiene 20 EG or Paradiene 20 HV adhered to the deck with hot asphalt.

Insulation Base Layer (Optional):	Insulation Fasteners Table 3	Fastener Density/ft²
Multi-Max 3, Multi-Max FA-3, H-Shield, or Paratherm H Minimum: 1.5" thick	N/A	N/A
Insulation Top Layer:	Insulation Fasteners Table 3	Fastener Density/ft²
Dens Deck Minimum ¼" thick	N/A	N/A
DuraBoard Minimum ¾" thick	N/A	N/A

Note: All insulation shall be adhered with Para-Stik Roofing Adhesive or OlyBond 500 Adhesive Fastener applied in continuous ¾ to 1 in. ribbons spaced 12 in. o.c. or OlyBond Adhesive Fastener applied at a rate of 1.0 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: Paradiene 20 TG, Paradiene 20 HT TG or Paradiene 20 EG TG torch adhered or Paradiene 20, Paradiene 20 HT, Paradiene 20 EG, Paradiene 20 HV, Irex 30, Irex 40 or Irex HT hot asphalt applied or adhered with Siplast PA-311 Cold Adhesive or PA-311 M Cold adhesive.

Membrane: Paradiene 30, Paradiene 30 FR, Paradiene 30 HT, Paradiene 30 HT FR, Paradiene 30 TG, Paradiene 30 FR TG, Paradiene 30 HT TG, Paradiene 30 HT FR TG, Paradiene 40 FR, Veral Aluminum, Veral Copper, Veral Stainless Steel, Veral Spectra, or Parafor 50 LT adhered to the base sheet with hot asphalt; Siplast PA-311 Cold Adhesive or PA-311 M Cold Adhesive at a rate of 1.5-2 gal/sq; or torch adhered (if torch grade membrane is used).

Maximum Design Pressure:
 -82.5 psf with PA-311 M Cold Adhesive over DuraBoard
 (See General Limitation #9)
 -112.5 psf with hot asphalt or PA-311 Cold Adhesive over DuraBoard
 (See General Limitation #9)
 -157.5 psf over Dens Deck
 (See General Limitation #9)



Membrane Type: SBS/SBS Foil
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(15): Vapor barrier torch adhered onto deck and insulation adhered with approved asphalt onto vapor barrier.

All General and System Limitations apply.

Vapor Barrier: Paradiene 20 TG, Paradiene 20 HT TG or Irex 40 vapor retarder is torch adhered to deck primed with PA-1125 at a rate of 1 gal/square (0.4 liter/m²).

Insulation Base Layer:	Insulation Fasteners Table 3	Fastener Density/ft²
Paratherm H, Paratherm W, ACFoam II, or H-Shield (Tapered or Flat) Minimum 1" thick	N/A	N/A
Insulation Top Layer:	Insulation Fasteners Table 3	Fastener Density/ft²
Dens Deck Minimum ¼" thick	N/A	N/A
Siplast Wood Fiberboard, High Density Wood Fiberboard Minimum ½" thick		

Note: All insulation shall be adhered in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: Paradiene 20 TG, Paradiene 20 HT TG, 20 TGF, or Paradiene 20 EG TG torch adhered onto Dens Deck cover board.
Option 1

Membrane: Paradiene 30 TG, 30 FR TG, 30 CR FR TG, 30 HT TG, 30 HT FR TG torch adhered onto the base sheet (option 1) above.
Option 1

Base Sheet: Paradiene 20, 20 HT, 20 EG, or 20 HV, hot asphalt applied at a minimum rate of 20 lb/sq (0.1 kg/m²) onto Wood Fiberboard cover board.
Option 2

Membrane: Paradiene 30, 30 FR, 30 CR FR, 30 HT, 30 HT FR, or Parafor 50 LT surfacing membrane is hot asphalt applied at a minimum rate of 20 lb/sq (0.1 kg/m²) onto the base sheet (option 2) above.
Option 2

Maximum Design Pressure: -202.5psf (see general limitation 9)



Membrane Type: SBS/SBS Foil
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 3000 psi structural concrete
System Type A(16): Vapor barrier torch adhered to deck and insulation adhered with approved adhesive onto vapor barrier.

All General and System Limitations apply.

Vapor Barrier: Irex 40 torch adhered to deck primed with PA-1125 at a rate of 1½ -2 gal/square.

Insulation Base Layer:	Insulation Fasteners Table 3	Fastener Density/ft²
ACFoam II or Paratherm W Minimum: 1.5" thick	N/A	N/A
Insulation Top Layer:	Insulation Fasteners Table 3	Fastener Density/ft²
Dens Deck Minimum ¼" thick	N/A	N/A

Note: All insulation shall be adhered with Para-Stik Roofing Adhesive applied in continuous ¾ to 1 in. ribbons spaced 12 in. o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: Paradiene 20 TG torched adhered onto Den Deck primed with PA-1125 at a rate of 2-2½ gal/square.
Membrane: Paradiene 30 FR TG torch adhered onto the base sheet.
Maximum Design Pressure: -142.5psf (See General Limitation #9)



Membrane Type: SBS
Deck Type 3: Concrete Decks, Non-insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(1): Optional vented base sheet, loose laid, followed by asphalt or torch applied ply sheet.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Base Sheet: (Optional) One ply of Paravent or Paravent FS loose laid and lapped a minimum of 1".

Ply Sheet: Paradiene 20 TG, 20 TG F, 20 HVTG, 20 HTTG or 20 EGTG or Terabase TG adhered by torch or Paradiene 20, 20 HT, 20 HV, 20 EG or Terabase adhered with approved mopping asphalt at an application rate of 20-40 lbs/sq. or with PA 311/311M adhesive.

Membrane: Paradiene 20 PR, 30 FR, 30 CRFR, 30 MW FR or 30 HTFR adhered in approved mopping asphalt or PA 311/311M adhesive, or Paradiene 20, PRTG, Teranap, Paradiene 30 FRTG, 30 CRFRTG, 30 HTFRTG or Parafor 50 adhered by torch.

Note: Refer to manufacturer's specifications for specific application requirements.

Surfacing: None

Maximum Design Pressure: -120 psf (See General Limitation #9)

Membrane Type: SBS Foil
Deck Type 3: Concrete Decks, Non-insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(2): Optional vented base sheet, loose laid, followed by asphalt or torch applied ply sheet.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Base Sheet: (Optional) Paravent or Paravent FS loose laid and lapped a minimum of 1"

Ply Sheet: IREX 30, IREX 40, IREX HT, Paradiene 20, 20 HT, 20 HV or 20 EG adhered in approved mopping asphalt at an application rate of 20-40 lbs/sq. or IREX 40, IREX HT, Paradiene 20 TG, 20 TG F, 20 HVTG, 20 HTTG or 20 EGTG applied by torch.

Membrane: Veral adhered in approved mopping asphalt or by torch

Note: Refer to manufacturer's specifications for specific application requirements.

Surfacing: None

Maximum Design Pressure: -120 psf (See General Limitation #9)



Membrane Type: SBS
Deck Type 3: Concrete Decks, Non-insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(3): Membrane adhered with asphalt or torch applied.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Base Sheet: (Optional) One or more plies Paraglas adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-25 lbs/sq.

Ply Sheet: Paradiene 20, 20 HT, 20 HV, 20 EG or Terabase adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-25 lbs/sq or with PA 311/311M adhesive or Paradiene 20 TG, 20 TG F, 20 HVTG, 20 HTTG, 20 EGTG or Terabase TG adhered by torch.

Membrane: Paradiene 20 PR, 30 FR, 30 CRFR, 30 MW FR or 30 HTFR adhered in approved mopping asphalt or PA 311/311M adhesive, or Paradiene 20, PRTG, Teranap, Paradiene 30 FRTG, 30 CRFRTG, 30 HTFRTG or Parafor 50 LT adhered by torch.

Note: **Refer to manufacturer's specifications for specific application requirements.**

Surfacing: None

Maximum Design Pressure: -230 psf (See General Limitation #9)

Membrane Type: SBS Foil
Deck Type 3: Concrete Decks, Non-insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(4): Membrane adhered with asphalt or torch applied.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Base Sheet: (Optional) One or more plies Paraglas adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-25 lbs/sq.

Ply Sheet: Paradiene 20, 20 HT, 20 HV or 20 EG adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs/sq or with PA 311/311M adhesive or Paradiene 20 TG, 20 TG F, 20 HVTG, 20 HTTG or 20 EGTG, adhered by torch.

Membrane: Veral adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-25 lbs/sq. or adhered by torch.

Note: **Refer to manufacturer's specifications for specific application requirements.**

Surfacing: None

Maximum Design Pressure: -230 psf (See General Limitation #9)



Membrane Type: SBS
Deck Type 3: Concrete Decks, Non-insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(5): Membrane adhered with asphalt or torch applied.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Base Sheet: None.
Ply Sheet: Paradiene 20 TG, 20 TG F, 20 HVTG, 20 HTTP, 20 EGTG or Terabase TG adhered by torch
Membrane: Paradiene 20 PR, 30 FR, 30 CRFR, 30 MW FR or 30 HTFR adhered in approved mopping asphalt or PA 311/311M adhesive, or Paradiene 20, PRTG, Teranap, Paradiene 30 FRTG, 30 CRFRTG, 30 HTFRTG or Parafor 50 LT adhered by torch.
Note: Refer to manufacturer's specifications for specific application requirements.
Surfacing: None
Maximum Design Pressure: -402.5 psf (See General Limitation #9)

Membrane Type: SBS Foil
Deck Type 3: Concrete Decks, Non-insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(6): Membrane adhered with asphalt or torch applied.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Base Sheet: None.
Ply Sheet: IREX 40 or IREX HT adhered by torch.
Membrane: Veral adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-25 lbs/sq or adhered by torch.
Note: Refer to manufacturer's specifications for specific application requirements.
Surfacing: None
Maximum Design Pressure: -402.5 psf (See General Limitation #9)



Membrane Type: SBS

Deck Type 3: Concrete Decks, Non-insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type F(7): Membrane adhered by torch.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Ply Sheet: Paradiene 20 TS adhered by torch.

Membrane: Paradiene 30 FRTG, 30 CRFRTG, 30 HTFRTG, or Parafor 50 LT adhered by torch.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure: -120 psf (See General Limitation #9)

Membrane Type: SBS

Deck Type 3: Concrete Decks, Non-insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type F(8): Membrane adhered by torch.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Membrane: Paralosa TS adhered by torch.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure: -120 psf (See General Limitation #9)



Membrane Type: SBS
Deck Type 3: Concrete Decks, Non-insulated
Deck Description: 3000 psi structural concrete or concrete plank
System Type F(9): Membrane adhered by torch.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Membrane: Terabase "TG" adhered by torch followed by Teranap "1M" adhered by torch then pour 2" Structural Concrete over membranes.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure: -315 psf (See General Limitation #9)

Membrane Type: SBS
Deck Type 3: Concrete Decks, Non-insulated
Deck Description: 3000 psi structural concrete or concrete plank
System Type F(10): Membrane adhered by torch.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Membrane: Terabase "TG" adhered by torch followed by Teranap "1M" adhered by torch then pour 1.5" Mortar mix over Siplast membranes and install and set 2" x 24" square Hanover Concrete Pavers in mortar mix.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure: -115 psf (See General Limitation #9)



Membrane Type: SBS

Deck Type 3: Concrete Decks, Non-insulated

Deck Description: 3000 psi structural concrete or concrete plank

System Type F(11): Membrane adhered by torch.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Membrane: Terabase "TG" adhered by torch followed by Teranap "1M" adhered by torch then 2" x 24" square Hanover concrete pavers set over Hanover pedestals and clipped at 4 corners. Pedestals fully adhered to top ply with Siplast PS 304 elastomeric sealant.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure: -170 psf (See General Limitation #9)

Membrane Type: SBS

Deck Type 3: Concrete Decks, Non-insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type F(12): Membrane adhered with asphalt or torch applied.

All General and System limitations apply.

Note: Concrete deck shall be primed with Paradiene PA-1125 applied at a rate of 1 gal/square and allowed to dry prior to application of base sheet.

Base Sheet: Paradiene 20 TS or Paradiene 20 TG base membrane torch adhered to primed concrete

Membrane: Paradiene 30 FR TG, 30 CR FR TG or 30 CR FR HT TG cap sheet torch adhered to the base sheet or Paradiene 30 FR, 30 HT FR, 30 CR FR HT or 30 CR FR adhered to the base sheet in hot asphalt at 20-25 lbs/square

Maximum Design Pressure:
-352.5 psf with Paradiene 20 TS base membrane (See General Limitation #9)
-367.5 psf with Paradiene 20 TG base membrane (See General Limitation #9)



CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.
2. Veral may be applied in approved mopping asphalt at slopes ranging from ½":12" to 2½":12". Veral may be torched at any slope above ½":12".

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No: 09-0901.13
Expiration Date: 04/14/13
Approval Date: 01/20/10
Page 30 of 30