



BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

Carlisle Residential
1285 Ritner Highway
Carlisle, PA 17013

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The BCCO (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BCCO reserves the right to revoke this acceptance, if it is determined by BCCO that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Carlisle Residential EN Base and EN Vent Insulation

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This renews NOA #08-0506.04 and consists of pages 1 through 3.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 09-0915.16
Expiration Date: 01/14/15
Approval Date: 01/13/10
Page 1 of 3

PRODUCT CONTROL NOTICE OF ACCEPTANCE

Category: Roofing
Sub-Category: Insulation
Type: Insulation
Sub-Type: Polyisocyanurate, Perlite and Fiberglass

TYPICAL PHYSICAL PROPERTIES:

<u>Property</u>	<u>Test</u>	<u>Typical Results</u>
Density	ASTM D 1622	2.0 lbs./ft ³
Compressive Strength	ASTM D 1621	20 psi
Water Absorption	ASTM C 209	24 PSI
Moisture Vapor Transmission	ASTM E 96	Less than 1% by volume
Service Temperature		Less than one (1) perm
Surface Burning Characteristics (4" Foam Core Max.)	ASTM E 84	-100° F +250° F Max Flamespread: 50 Smoke Developed: 450

Note: The physical properties listed above are presented as typical average values as determined by accepted ASTM test methods and are subject to normal manufacturing variation. Numerical ratings as determined by ASTM Test Method E 84 are not intended to reflect hazards presented by this or any other material under actual fire conditions.

MANUFACTURING LOCATION:

- Lake City, FL.

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Exterior Research & Design, L.L.C.	Physical Properties	03190.05.04-1	5/24/2004
Factory Mutual Approvals	Class 4450	3009425	6/13/2003
		3019743	6/15/2004
		3021539	4/27/2005
Factory Mutual Approvals	ASTM-E84	3018331	8/30/2004
Factory Mutual Approvals	ASTM-D1929	3021560	8/31/2004
Factory Mutual Approvals	Fire Classification	3016355	9/15/2004
Underwriters Laboratories	Fire Classification	R 18846	4/15/2003
Underwriters Laboratories	Fire Classification	R 18846	4/16/2003



NOA No.: 09-0915.16
 Expiration Date: 01/14/15
 Approval Date: 01/13/10
 Page 2 of 3

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

Trade name: EN Base and EN Vent
Special Application: Polyisocyanurate insulation laminated to plywood. EN Base and EN Vent insulation shall have APA rated plywood topside in compliance with the provisions of Chapter 23 of the FBC.

COMMENTS AND LIMITATIONS:

1. Roof assemblies are approved under specific roof cover's Product Control Notice of Acceptance.
2. Carlisle Residential products may be used with any approved roof covering listing a specific Carlisle Residential product as a component part of a roof assembly Notice of Acceptance. If a Carlisle Residential product is not listed, a request may be made to the authority having jurisdiction or the Miami Dade Building Code Compliance Office for approval provided that appropriate documentation is provided.
3. Fire classification is not a part of this Notice of Acceptance
4. All approved products listed herein shall be labeled and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE



NOA No.: 09-0915.16
Expiration Date: 01/14/15
Approval Date: 01/13/10
Page 3 of 3