MIAMI-DADE COUNTY

BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

Mid-States Asphalt and Cant Strip, Inc.
1637 51st Ave
Tuscaloosa, AL. 35401

SCOPE:
This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: MSA Underlayments

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 4.
The submitted documentation was reviewed by Alex Tigera.

MIAMI-DADE COUNTY APPROVED

ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: SBS

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

Product	Dimensions	Test Specification	Product Description
Quik-Stick Ice & Water Sand Surfaced	3' x 33.4' rolls 3' x 66.8' rolls	ASTM D 1970	Self-adhering, non-woven fiberglass mat reinforced membrane with a sand surface for use as an underlayment in sloped roof assemblies.
Quik-Stick Ice & Water	3' x 33.4' rolls 3' x 66.8' rolls	ASTM D 1970	Self-adhering, non-woven fiberglass mat reinforced membrane for use as an underlayment in sloped roof assemblies.
Quik-Stick HT	3' x 33.4' rolls 3' x 66.8' rolls	ASTM D 1970	Self-adhering, non-woven fiberglass mat reinforced membrane for use as an underlayment in high temperature sloped roof assemblies.

MANUFACTURING PLANTS:

1. Tuscaloosa, AL

EVIDENCE SUBMITTED:

Test Agency	Test Identifier	Test Name/Report	Date
PRI Construction Materials Technologies	BWR-514-02-01 (rev)	ASTM D 1970	09/04/09
PRI Construction Materials Technologies	VRMI-011-02-01	ASTM D 1970	03/30/09
PRI Construction Materials Technologies	BWR-511-02-01	ASTM D 1970	09/29/09
PRI Construction Materials Technologies	BWR-511-02-01	ASTM D 4798	09/29/09

APPROVED ASSEMBLIES:

Deck Type 1: Wood, non-insulated

Deck Description: $^{19}/_{32}$" or greater plywood or wood plank

System E(1): Anchor sheet mechanically fastened deck, membrane adhered.

Base Sheet: One or more plies of ASTM D 226 Type II or ASTM D 2626 with a minimum 4" side lap and a 6" end lap mechanically fastened to deck with approved nails and tin caps 6" o.c. at the laps and two staggered rows 12" o.c. the field of the roll.

* In the Non-HVHZ area a Base Sheet is optional.

Membrane: One or more plies of Quik-Stick Ice & Water Sand Surfaced, Quik-Stick Ice & Water, or Quik-Stick HT underlayment with a minimum 4" side lap and 6" end lap.

Surfacing: Approved Roof Assemblies. See Limitation #3.

LIMITATIONS:

1. Fire classification is not part of this acceptance.
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code. Quik-Stick Ice & Water Sand Surfaced, Quik-Stick Ice & Water, or Quik-Stick HT underlayments shall be installed in strict compliance with applicable Building Code.
3. Quik-Stick Ice & Water Sand Surfaced, Quik-Stick Ice & Water, or Quik-Stick HT underlayments may be used in asphaltic shingles, wood shakes and shingles and quarry slate roof assemblies. Quik-Stick Ice & Water Sand Surfaced, Quik-Stick Ice & Water, or Quik-Stick HT underlayment shall not be used as roof tile underlayment.
4. Quik-Stick Ice & Water Sand Surfaced, Quik-Stick Ice & Water, or Quik-Stick HT underlayment shall not be applied over an existing roof membrane as a recover, but may be applied over a roofing Base/Anchor sheet underlayment.
5. Quik-Stick Ice & Water Sand Surfaced and Quik-Stick Ice & Water underlayment shall not be left exposed as a temporary roof for longer than 14 days of application.
6. Quik-Stick HT underlayment shall not be left exposed as a temporary roof for longer than 90 days of application.
7. Refer to Prepared Roofing system Product Control Notice of Acceptance for listed approval of this product with specific prepared roofing products.
8. Quik-Stick Ice & Water Sand Surfaced, Quik-Stick Ice & Water, or Quik-Stick HT underlayments may be used with any approved roof covering Notice of Acceptance listing Quik-Stick Ice & Water Sand Surfaced, Quik-Stick Ice & Water, or Quik-Stick HT underlayments as a component part of an assembly in the Notice of Acceptance. If Quik-Stick Ice & Water Sand Surfaced, Quik-Stick Ice & Water, or Quik-Stick HT underlayments are not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
9. Quik-Stick Ice & Water Sand Surfaced, Quik-Stick Ice & Water, or Quik-Stick HT underlayments shall be applied to a smooth, clean and dry surface with deck free of irregularities. All nails in the deck shall be carefully checked for protruding heads. Re-fasten any loose decking panels. Sweep the deck thoroughly to remove any dust and debris prior to application.
10. When applying the membrane in the valley, start at the low point and work to the high point, rolling the membrane from the center outward in both directions. For ridge applications, center the membrane and roll from the center outward in both directions.
11. Roll or broom the entire membrane surface so as to have 100% contact with the surface, giving special attention to overlap areas.
12. Flash vent pipes, stacks, chimneys and penetrations in compliance with Roof Assembly current Product Control Notice of Acceptance and applicable Building Code.
13. All protrusions or drains shall be initially taped with a 6" piece of underlayment. The flashing tape shall be pressed in place and formed around the protrusion to ensure a tight fit. A second layer of Quik-Stick Ice & Water Sand Surfaced, Quik-Stick Ice & Water, or Quik-Stick HT underlayments shall be applied over the underlayment.
14. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.
15. All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.

MIAMI-DADE COUNTY APPROVED

END OF THIS ACCEPTANCE