



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

**Siplast  
1111 Highway 67 South  
Arkadelphia, AR 71923**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by the BCCO and accepted by the Building Code and Product Review Committee to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Siplast Self-Adhered Modified Bitumen Roofing Systems Over Concrete Decks**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 12.

The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No: 09-1216.01  
Expiration Date: 04/14/13  
Approval Date: 01/20/10  
Page 1 of 12**

## ROOFING ASSEMBLY NOTICE OF ACCEPTANCE

Category: Roofing  
Sub-Category: Modified Bitumen  
Material: SBS/SBS Foil  
Deck Type: Concrete  
Maximum Design Pressure -405 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Parabase	3' x 108'	ASTM D 4601	Asphalt coated fiberglass base sheet for mechanically fastened applications.
Parabase FS	3' x 108'	ASTM D 4601	Asphalt coated fiberglass base sheet with a polyolefin back surfacing for mechanically fastened applications.
Parabase Plus	3.28' x 102.3' 28 lbs./sq.	ASTM D 5147	Elastomeric asphalt coated base sheet.
Paraglas	3' x 180' 12 lbs./sq.	ASTM D 2178 Type IV	Asphalt coated fiberglass mat used as a base or ply sheet.
Paravent	3' x 108'	ASTM D 4601	Asphalt coated venting fiberglass base sheet with 1.5 inch perforations.
Paravent FS	3' x 108'	ASTM D 4601	Asphalt coated venting fiberglass base sheet with 1.5 inch perforations and a polyolefin back surfacing..
Paradiene 20	3.28' x 50' 90 lbs./ sq.	ASTM D 6163	Asphalt elastomer sheet with random fiberglass mat reinforcement used as the base ply of a Paradiene 20/30 system.
Paradiene 20 HT	3.28' x 50' 90 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply of a Paradiene 20/30 system.
Paradiene 20 EG	3.28' x 33.5' 90 lbs./sq.	ASTM D 6163	Heavy duty asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply in Paradiene systems.
Paradiene 20 HV	3.28' x 33.5' 90 lbs./sq.	ASTM D 6163	Heavy duty asphalt elastomer sheet with random fiberglass mat reinforcement used as a base ply of a Paradiene 20/30 system.
Paradiene 20 PR	3.28' x 50' 55 lbs./sq.	ASTM D 6162	Asphalt elastomer sheet with polyester fiberglass scrim composite reinforcement used as the top ply of a Paradiene 20/20 PR system having a gravel surfacing. Has additional puncture resistance.
Paradiene 20 TG	3.28' x 33.5' 70 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with random fiberglass reinforcement used as the base ply of a Paradiene 20/30 TG Series system.



NOA No: 09-1216.01  
 Expiration Date: 04/14/13  
 Approval Date: 01/20/10  
 Page 2 of 12

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Paradiene 20 TG F	3.28' x 33.5'; 70 lbs./sq.	ASTM D 4601	Asphalt elastomer sheet with random fiberglass reinforcement and a silica parting agent on the top surface, for use as the base ply of a Paradiene 20/30 TG Series system.
Paradiene 20 HT TG	3.28' x 33.5'; 70 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply of a Paradiene 20/30 system.
Paradiene 20 EG TG	3.28' x 33.5'; 100 lbs./sq.	ASTM D 5147	Heavy duty asphalt elastomer sheet with fiberglass scrim reinforced for use as a base ply in Paradiene 20TG/30TG systems.
Paradiene 20 HV TG	3.28' x 33.5'; 100 lbs./sq.	ASTM D 6163	Heavy duty asphalt elastomer sheet with random fiberglass mat reinforcement used as a base ply of a Paradiene 20TG/30TG system.
Paradiene 20 PR TG	3.28' x 33.5'; 96 lbs./sq.	ASTM D 6164	High performance SBS modified bitumen finish ply designed for use in gravel surfaced. Used as a surface ply of a Paradiene 20/20TG system.
Paradiene 20 TS	3.28' x 33.5'; 76 lbs./sq.	ASTM D 6163	High performance, semi adhered SBS modified bitumen with random fiberglass mat reinforcement used as a base ply of Paradiene 20/30 systems.
Paradiene 20 TS SA	3.28' x 33.5'; 76 lbs./sq.	ASTM D 6163	High performance, semi adhered, self adhesive, SBS modified bitumen with random fiberglass mat reinforcement used as a base ply of Paradiene 20/30 systems.
Paradiene 20 HT TS SA	3.28' x 33.5'; 73 lbs./sq.	ASTM D 6163	High performance, semi adhered, self adhered, SBS modified bitumen with random fiberglass mat/fiberglass scrim reinforcement used as a base ply of Paradiene 20/30 systems.
Paradiene 20 SA	3.28' x 33.5'; 72 lbs./sq.	ASTM D 6163	High performance, self adhesive, SBS modified bitumen with random fiberglass mat reinforcement used as a utility sheet.
Paradiene 20 EG SA	3.28' x 33.5'; 90 lbs./sq.	ASTM D 6163	High duty, self-adhesive, asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply in Paradiene systems.
Paradiene 20 HT SA	3.28' x 50'; 90 lbs./sq.	ASTM D 6163	High performance, self adhesive, asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply of a Paradiene 20/30 systems.
Terabase	3.28' x 50'; 90 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with random fiberglass mat reinforcement used as the base ply for Teranap systems.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Terabase TG	3.28' x 33.5'; 70 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with random fiberglass reinforcement used as the base ply for Teranap systems.
Teranap	3.28' x 26'; 97 lbs./sq.	ASTM D 5147	A non-woven polyester mat impregnated and coated with high quality SBS modified bitumen. The surface of the sheet is protected by a polyester film or by sand.
Paradiene 30 Paradiene 30 CR	3.28' x 33.5'; 85 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with mineral surfacing and random glass mat reinforcement, for use as the top ply of a Paradiene 20/30 system.
Paradiene 30FR Paradiene 30 FR CR	3.28' x 33.5'; 85 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with mineral surfacing and random glass mat reinforcement, for use as the top ply of a Paradiene 20/30 system.
Paradiene 30 HT	3.28' x 33.5'; 85 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene 20/30 system.
Paradiene 30 HTFR	3.28' x 33.5'; 87 lbs./sq.	ASTM D 6163	Fire-rated asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene 20/30 FR system.
Paradiene 30 MW	3.28' x 33.5'; 87 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with mineral surfacing and ultra high tensile fiberglass reinforcement for use as the top ply of a Paradiene 20/30 FR system.
Paradiene 30 MW FR	3.28' x 33.5'; 87 lbs./sq.	ASTM D 6163	Fire rated asphalt elastomer sheet with mineral surfacing and ultra high tensile fiberglass reinforcement for use as the top ply of a Paradiene 20/30 FR system.
Paradiene 30 TG Paradiene 30 CR TG	3.28' x 25.25'; 80 lbs./sq.	ASTM D 5147	Fire rated asphalt elastomer sheet with mineral surfacing and random fiberglass mat reinforcement for use as the top ply sheet of a Paradiene 20/30 TG Series system.
Paradiene 30 FRTG Paradiene 30 CR FR TG	3.28' x 25.25'; 80 lbs./sq.	ASTM D 6163	Fire rated asphalt elastomer sheet with mineral surfacing and random fiberglass mat reinforcement for use as the top ply sheet of a Paradiene 20/30 TG Series system.
Paradiene 30 HTTG	3.28' x 25.25'; 80 lbs./sq.	ASTM D 6163	Asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene 20/30 TG Series system requiring high tensile strength.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Paradiene 30 HTFRTG	3.28' x 25.25'; 80 lbs./sq.	ASTM D 6163	Fire rated asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene TG Series system.
Paradiene 40 FR	3.28' x 26'; 115 lbs./sq.	ASTM D 5147	Fire rated asphalt elastomer sheet with mineral surfacing, glass mat/glass scrim reinforced.
Parafor 50 LT	3.28' x 17.5'; 114 lbs./sq.	ASTM D 6162	Heavy duty asphalt elastomer sheet with mineral surfacing, polyester mat/fiberglass scrim reinforced.
Paralosa TS	3.28' x 26.25'; 141 lbs./sq.	ASTM D 6162	Heavy duty asphalt elastomer sheet with mineral surfacing, polyester mat/fiberglass scrim reinforced. For use as single ply membrane over concrete decks.
IREX 30	3.28' x 34'; 74 lbs./sq.	ASTM D 5147	High-melt asphalt sheet with random fiberglass mat reinforcement for use as the base ply sheet for a Veral system.
IREX 40	3.28' x 34'; 89 lbs./sq.	ASTM D 5147	High-melt asphalt sheet with random fiberglass mat reinforcement for use as the base ply sheet for a Veral system.
IREX HT	3.28' x 34'; 89 lbs./sq.	ASTM D 5147	High-melt asphalt sheet with fiberglass scrim reinforcement for use as a base ply sheet for the Veral system.
IREX PR	3.28' x 34'; 89 lbs./sq.	ASTM D 5147	High-melt asphalt sheet with polyester mat / fiberglass scrim reinforcement for use as a mechanically fastened base sheet with the Veral system.
Veral Aluminum	3.28' x 33.5'; 90 lbs./sq.	ASTM D 6298	Aluminum clad asphalt elastomer sheet with woven fiberglass reinforcement for use as the top ply sheet of a Veral system.
Veral Copper	3.28' x 33.5'; 105 lbs./sq.	ASTM D 6298	Copper clad asphalt elastomer sheet with fiberglass scrim reinforcement for use as the top ply of a Veral system.
Veral Stainless Steel	3.28' x 33.5'; 105 lbs./sq.	ASTM D 6298	Stainless steel clad asphalt elastomer sheet with fiberglass scrim reinforcement for use as the top ply sheet of a Veral system.
Veral Spectra Series	3.28' x 33.5'; 90 lbs./sq.	ASTM D 6298	Aluminum clad asphalt elastomer sheet with fiberglass scrim reinforcement and factory finished with a Kynar PVDF coating.
PA 100 Mopping Asphalt		ASTM D 312 Type IV	Mopping Asphalt
PA 311/311 M/311LS Adhesive	5 or 55 gal.	ASTM D 4479	Blend of adhesive asphalts and quick-drying solvents.
PA 828 Flashing Cement	5 gal.	ASTM D 4586	Flashing Cement



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
PA 1021 Plastic Cement	5 gal.	ASTM D 4586	Asphalt cutback reinforced general purpose cement with non-asbestos fibers.
PA 1125 Asphalt Primer	5 or 55 gal.	ASTM D 41	Asphalt primer.
PC – 227	5 or 55 gal	ASTM D 6083	Elastomeric roof coating.
Para-Stik Insulation Adhesive	30 lb pressurized cylinders	N/A	A single component moisture curing Urethane foam adhesive

**APPROVED INSULATIONS:**

**TABLE 2**

<b>Product Name</b>	<b>Product Description</b>	<b>Manufacturer (With Current NOA)</b>
Paratherm, Paratherm W, Paratherm H	Isocyanurate Insulation	Siplast
Siplast Wood Fiberboard	Wood fiber insulation	Siplast
ACFoam I, ACFoam II, ACFoam III	Polyisocyanurate Insulation	Atlas Roofing Corp.
Fiberglas	Fiber glass roof insulation.	Generic
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic
High Density Wood Fiberboard	High Density Wood Fiber insulation board	Georgia Pacific
Perlite Insulation Board	Perlite Insulation	Generic
Dens Deck, Dens Deck Prime, Dens Deck DuraGuard	Water resistant gypsum	G-P Gypsum Corp.
H-Shield	Polyisocyanurate Foam Insulation.	Hunter Panels LLC
ENRGY 3	Polyisocyanurate Insulation.	Johns Manville
Fiber Glass Roof Insulation	Fiberglas roof insulation.	Johns Manville
ISORoc	Polyisocyanurate foam insulation.	Johns Manville
DuraBoard	Expanded Mineral Fiber	Johns Manville
FescoBoard	Perlite Insulation	Johns Manville
Multi-Max, FA	Polyisocyanurate foam insulation.	RMax Inc.
Strataguard	Gypsum Wallboard	Owens Corning
Securock	Water resistant recycled cellulose and synthetic gypsum	USG

**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	N/A	N/A	N/A	N/A



**EVIDENCE SUBMITTED:**

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	FMRC 4470 - TAS 114	J.I. 2Y1A1.AM	04/15/96
	FMRC 4470 - TAS 114	J.I. 3Z3A7.AM	04/12/96
	FMRC 4470	3008071	01/18/01
	FMRC 4470	3008210	04/10/01
	FMRC 4470	3015680	11/24/03
	FMRC 4470	3021507	11/04/05
	FMRC 4470	3023079	05/12/06
	FM 4470	3026749	07/27/06
	FM 4470	3031655	05/27/08
	Atlantic & Caribbean Roof Consulting, LLC	TAS 114-95 Appendix D	04-002
TAS 114-95 Appendix D		04-003	10/05/04
TAS 114-95 Appendix D		06-025	06/28/06
Underwriters Laboratories, Inc.	UL 790 - PA 114	R10630	01/01/96
Exterior Research & Design, LLC.	TAS 114	#4701.02.96-1	02/28/96
	TAS 114	#4701.09.96-1	08/22/96
	TAS 117	C8500SC.11.07	11/30/07



**APPROVED ASSEMBLIES**

- Membrane Type:** SBS/SBS Foil
- Deck Type 3I:** Concrete Decks, Insulated
- Deck Description:** 2500 psi structural concrete or concrete plank
- System Type A(1):** All layers of insulation adhered to deck with approved asphalt or adhesive.

**All General and System limitations apply.**

One or more layers of any of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Paratherm H, ENRGY-3, ACFoam-I, ACFoam-II, Paratherm W, H-Shield Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Dens Deck Prime, Strataguard Minimum ¼" thick</b>	N/A	N/A

**Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup> or Insta-Stik/Para-Stik adhesive applied in continuous ¾" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.**

- Base Sheet:** Paradiene 20 TS SA self-adhered sheet applied onto insulation layer.
- Ply Sheet:** None.
- Membrane:** Paradiene 30 FRTG, 30 CRFRTG, 30 HTFRTG, Parafor 50 LT or Veral adhered by torch onto the base sheet.

**Note: Refer to manufacturer's specifications for specific application requirements.**

- Maximum Design Pressure:**
  - 90 psf (using Dens Deck) (See General Limitation #9)
  - 120 psf (using Strataguard) (See General Limitation #9)



**Membrane Type:** SBS/SBS Foil

**Deck Type 3I:** Concrete Decks, Insulated

**Deck Description:** 2500 psi structural concrete or concrete plank

**System Type A(2):** All layers of insulation adhered to deck with approved asphalt or adhesive.

**All General and System limitations apply.**

One or more layers of any of the following insulations:

<b>Insulation Layer</b>	<b>Insulation Fasteners</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Paratherm H, H-Shield, Paratherm W Minimum 1.5" thick</b>	N/A	N/A
<b>AC Foam III Minimum 2" thick</b>	N/A	N/A

**Note:** Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup> or Insta-Stik/Para-Stik adhesive applied in continuous ¾" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

**Base Sheet:** Paradiene 20 TS SA self-adhered sheet applied onto insulation layer.

**Ply Sheet:** None.

**Membrane:** Paradiene 30 FRTG, 30 CRFRTG, 30 HTFRTG, Parafor 50 LT or Veral adhered by torch onto the base sheet.

**Note:** Refer to manufacturer's specifications for specific application requirements.

**Maximum Design**

**Pressure:** -127.5 psf (using H-Shield) (See General Limitation #9)  
-135 psf (using AC Foam III) (See General Limitation #9)





Membrane Type: SBS/SBS Foli

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(3): All layers of insulation adhered to deck with approved asphalt or adhesive.

All General and System limitations apply.

One or more layers of any of the following insulations:

Insulation Fasteners	Fastener Density/ft <sup>2</sup>	Minimum 1.5" thick
Insulation Fasteners	N/A	N/A
Top Insulation Layer	Fastener Density/ft <sup>2</sup>	Minimum 1/4" thick
Securock, Dens Deck Duraguard	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered with Insta-Stik/Para-Stik adhesive applied in continuous 3/4" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: Paradiene 20 TS SA base membrane is self-adhered to the insulation layer.

Ply Sheet: None.

Membrane: Paradiene 30, 30 FR, 30 CFR, 30 HTR, Parafor 30, or Parafor 50 LT adhered in PA 311/311M/311 LS adhesive applied at a rate of 1.5-2.5 gal/square onto the base sheet.

Note: Refer to manufacturer's specifications for specific application requirements.

Maximum Design Pressure:

-112.5 psf (using SecurRock) (See General Limitation #9)  
 -187.5 psf (using Dens Deck) (See General Limitation #9)

**Membrane Type:** SBS/SBS Foil

**Deck Type 3I:** Concrete Decks, Insulated

**Deck Description:** 2500 psi structural concrete or concrete plank

**System Type A(4):** All layers of insulation adhered to deck with approved asphalt or adhesive.

**All General and System limitations apply.**

One or more layers of any of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam II, Paratherm W, H-Shield, Paratherm H Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Securock, Dens Deck DuraGuard Minimum ¼" thick</b>	N/A	N/A

**Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered with Insta-Stik/Para-Stik adhesive applied in continuous ¾" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.**

**Base Sheet:** Paradiene 20 SA base membrane is self-adhered to the insulation layer.

**Ply Sheet:** None.

**Membrane:** Paradiene 30 TG, 30 FRTG, 30 CRFRTG, 30 HTFRTG, Parafor 30 TG, Parafor 50 TG, Parafor 50 LT TG, Veral Aluminum, Veral Copper, Veral Stainless Steel, or Veral Spectra surfacing membrane is torch adhered onto the base sheet.

**Note: Refer to manufacturer's specifications for specific application requirements.**

**Maximum Design Pressure:**  
 -255 psf (using SecuRock) (See General Limitation #9)  
 -405 psf (using Dens Deck DuraGuard) (See General Limitation #9)



## CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.
2. Veral may be applied in approved mopping asphalt at slopes ranging from ½":12" to 2½":12". Veral may be torched at any slope above ½":12".

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

## END OF THIS ACCEPTANCE



NOA No: 09-1216.01  
Expiration Date: 04/14/13  
Approval Date: 01/20/10  
Page 12 of 12