



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Custom Building Products
10400 Pioneer Blvd, Unit 3
Santa Fe Springs, CA 90670**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: RedGard, C-Cure Pro-Red, JAMO Waterproof Coating

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This replaces NOA #08-0416.01 and consists of pages 1 through 3.
The submitted documentation was reviewed by Alex Tigera.



**NOA No.: 10-0322.04
Expiration Date: 05/08/13
Approval Date: 04/21/10
Page 1 of 3**

ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub-Category: Cements- Coatings -Adhesives
Materials: Styrene-Butadiene CoPolymer

PRODUCT DESCRIPTION:

<u>Manufactured by Applicant</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
RedGard, C-Cure Pro-Red, JAMO Waterproof Coating	N/A	ASTM D 6083	Ready-to-use elastomeric, maintenance coating.

MANUFACTURING LOCATION:

1. Miami, FL.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Asphalt Technologies	CBP-001-02-01	ASTM D 6083	07/12/07

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. RedGard, C-Cure Pro-Red, JAMO Waterproof Coating shall not be applied in inclement weather conditions.
3. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.
4. All approved products listed herein shall be labeled in compliance with TAS 121.
5. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
6. This coating shall be allowed over concrete only.
7. RedGard, C-Cure Pro-Red, JAMO Waterproof Coating shall be used as a roof or exterior balcony maintenance coating in accordance with Chapter 15 of the Florida Building Code.
8. RedGard, C-Cure Pro-Red, JAMO Waterproof Coating is not approved for use as a repair or recover system.
9. RedGard, C-Cure Pro-Red, JAMO Waterproof Coating shall be covered with surfacing and shall not be exposed
10. **RedGard, C-Cure Pro-Red, JAMO Waterproof Coating is not approved as and shall not be used as a waterproofing system as required by the Florida Building Code section 1519.16.**



NOA No.: 10-0322.04
Expiration Date: 05/08/13
Approval Date: 04/21/10
Page 2 of 3

INSTALLATION:

1. Custom Building Products RedGard, C-Cure Pro-Red, JAMO Waterproof Coating shall be installed in accordance with manufacturer's Product Data Sheet.
2. Substrates: Concrete only.

PHYSICAL PROPERTIES OF COMPONENTS

Trade name: RedGard, C-Cure Pro-Red, JAMO Waterproof Coating

Application Rate: Apply material to achieve 93 mil wet (47 mil dry) film. For details on application methods and coverage see Installation Instructions on Product Data Sheet.

Description: A red, ready-to-use, elastomeric, maintenance coating.

Container Size: 1 gallon and 3.5 gallons. Note all cautions on container label.

BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or the Applicable Building Code in order to properly evaluate the installation of this system.

END OF THIS ACCEPTANCE



NOA No.: 10-0322.04
Expiration Date: 05/08/13
Approval Date: 04/21/10
Page 3 of 3