



BUILDING AND NEIGHBORHOOD COMPLIANCE DEPARTMENT (BNC)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/building/

NOTICE OF ACCEPTANCE (NOA)

GAF Materials Corporation
1361 Alps Road
Wayne, NJ. 07470

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County BNC - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BNC reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code. This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: VersaShield™ Fire Resistant Roof Deck Protection

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This revises NOA No. 07-0103.08 and consists of pages 1 through 3.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 10-0331.04
Expiration Date: 02/07/12
Approval Date: 06/16/11
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: Fiberglass

SCOPE:

This acceptance is for VersaShield™ Fire Resistant Roof Deck Protection by GAF Materials Corporation, as described in this Notice of Acceptance, for use with approved prepared roof assemblies. Designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensional</u>	<u>Test Specification</u>	<u>Product Description</u>
VersaShield™ Fire Resistant Roof Deck Protection	42" x 100' rolls	ASTM D 226 Type II	Non-Asphaltic fiberglass-based underlayment and/or fire barrier.

MANUFACTURING LOCATION:

1 Conover, NC

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials	GAF-270-02-02	ASTM D 226	10/06/11
PRI Asphalt Technologies, Inc.	ELK-063-02-01	TAS 100	09/27/01
Underwriters Laboratories Inc.	99NK45831	ASTM E 108	03/21/00
Underwriters Laboratories Inc.	10NK11990	Listing Classification	05/18/11
Underwriters Laboratories Inc.	R19254	ASTM D 226	09/13/01
PRI Asphalt Technologies, Inc.	ELK-069-02-01	TAS 100	03/04/02
	BRY-003-02-01	TAS 117(B)	03/19/02
	BRY-003-02-01	TAS 114 (H)	

INSTALLATION:

1. VersaShield™ Fire Resistant Roof Deck Protection shall be installed in strict compliance with applicable Building Code.
2. VersaShield™ Fire Resistant Roof Deck Protection shall be installed with a minimum 4-inch head lap in a single layer fashion.
3. VersaShield™ Fire Resistant Roof Deck Protection is a component used in roof assemblies. Roof assemblies are approved under specific assembly Notice of Acceptance.
4. VersaShield™ Fire Resistant Roof Deck Protection may be used with any approved roof covering Notice of Acceptance listing VersaShield™ Fire Resistant Roof Deck Protection as a component part of an assembly in the Notice of Acceptance. If VersaShield™ Fire Resistant Roof Deck Protection is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
5. VersaShield™ Fire Resistant Roof Deck Protection is a non-asphaltic underlayment that may be used as a fire barrier for prepared roof assemblies. For fire classification of specific roof assemblies using VersaShield™ Fire Resistant Roof Deck Protection refer to a current Approved Roofing Materials Directory for fire ratings of this product.

LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.

LABELING:

All packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and yellow line to identify the ASTM Standard designation; or logo and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

END OF THIS ACCEPTANCE



NOA No.: 10-0331.04
Expiration Date: 02/07/12
Approval Date: 06/16/11
Page 3 of 3