



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Elastikote LLC.
1480 Englewood Ave.
Akron, OH 44305-4203**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: ElastiKote® Series 1000 Coatings

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.
The submitted documentation was reviewed by Jorge L. Acebo



**NOA No.: 10-0419.03
Expiration Date: 09/22/15
Approval Date: 09/22/10
Page 1 of 3**

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Material: SEBS Elastomeric

SCOPE:

This approves “**ElastiKote® Series 1000 Coatings**” as a roof coating as manufactured by Elastikote LLC., as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code

PHYSICAL PROPERTIES OF COMPONENTS

Trade names: **ElastiKote® Series 1000 Coatings**

Thickness: See approved substrates below but in no case shall it be less than 20 dry mils.

Specifications: ASTM D 6083

Description: A SEBS elastomeric coating membrane of various colors applied over the substrates listed below at an application rate of;

- Spray Foam (SPF) Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Top Coat at a rate of 1.5 gal/100 ft². Minimum 21 dry mils.
- Galvanized Metal Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Top Coat at a rate of 1.5 gal/100 ft². Minimum 21 dry mils.
- TPO Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Top Coat at a rate of 1.5 gal/100 ft². Minimum 21 dry mils.
- PVC Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Top Coat at a rate of 1.5 gal/100 ft². Minimum 21 dry mils.
- EPDM Roofs: Apply Base Coat at a minimum rate of .75 gal/100 ft² and Middle Coat at a minimum rate of 1 gal/100 ft² and Top Coat at a rate of 1.25 gal/100 ft². Minimum 21 dry mils.
- Hypalon Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Top Coat at a rate of 1.5 gal/100 ft². Minimum 21 dry mils.
- KEE Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Top Coat at a rate of 1.5 gal/100 ft². Minimum 21 dry mils.
- SBS Granule Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Top Coat at a rate of 1.5 gal/100 ft². Minimum 21 dry mils.
- Smooth BUR Asphalt Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Top Coat at a rate of 1.5 gal/100 ft². Minimum 21 dry mils.
- Smooth BUR Coal Tar Pitch Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Top Coat at a rate of 1.5 gal/100 ft². Minimum 21 dry mils.
- Plywood*: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Top Coat at a rate of 1.5 gal/100 ft². Minimum 21 dry mils. **(see note below)**
- Concrete*: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Top Coat at a rate of 1.5 gal/100 ft². Minimum 21 dry mils. **(see note below)**

* **Note: Application over these substrates shall not be as a roof system or a waterproofing system see Limitation #1.**

Container Size: 5 and 55 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with specific Roof Assembly, Product Control Notice of Acceptance.



NOA No.: 10-0419.03
Expiration Date: 09/22/15
Approval Date: 09/22/10

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies, Inc.	ELKL-001-02-01	ASTM D 6083	05/10/10
Momentum Technologies, Inc	MTI-100300	TT-C-555B ASTM D 1653	08/16/10

MANUFACTURING LOCATION:

1. Smithville, OH

LIMITATIONS:

1. ElastiKote® Series 1000 Coatings is not approved as and shall not be used as a Roof or Waterproofing System as required by the Florida Building Code Chapter 15 HVHZ.
2. ElastiKote® Series 1000 Coatings shall only be used as a roof or exterior maintenance coating over the substrates specified herein in accordance with Chapter 15 of the Florida Building Code.
3. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
4. ElastiKote® Series 1000 Coatings shall not be applied in inclement weather conditions.
5. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
6. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.
7. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
8. ElastiKote® Series 1000 Coatings shall be applied in accordance with manufacturer's published application instructions. Applicable Florida Building Code and this Approval's requirements supersede all manufacturer's recommendations and installation guidelines if in conflict with minimum requirements of the Florida Building Code or this Product Approval.
9. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.
10. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE



NOA No.: 10-0419.03
Expiration Date: 09/22/15
Approval Date: 09/22/10
Page 3 of 3