



**BUILDING AND NEIGHBORHOOD COMPLIANCE DEPARTMENT (BNC)
BOARD AND CODE ADMINISTRATION DIVISION**

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/building

NOTICE OF ACCEPTANCE (NOA)

**West Development Group
300 Commerce Drive
LaGrange, OH 44050**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Section and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: WDG System 14 Spray Polyurethane Foam Systems over Concrete Deck

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 4.

The submitted documentation was reviewed by Jorge L. Acebo



**NOA No.: 10-0419.04
Expiration Date: 03/03/16
Approval Date: 03/03/11
Page 1 of 4**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Spray Applied Polyurethane Roof System
Materials: Polyurethane
Deck Type: Concrete
Maximum Design Pressure: -575 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
WDG 3009-03 Spray Polyurethane Foam	2.5 to 3.0 lb/ft ³ density	TAS 110	Polyurethane spray applied foam that utilizes an HFC blowing agent intended for roofing applications.
HSS 535 Solvent-Free Silicone Roof Coating	5 and 55 gallon containers	ASTM D6694	A one component, moisture-curing silicone rubber roof coating.
HSS 540 R2R™ Solvent-Free Silicone Roof Coating	5 and 55 gallon containers	ASTM D6694	A one component, moisture-curing silicone rubber roof coating.

TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>	<u>Manufacturer</u>
Any Miami-Dade County Approved Roof Coating	N/A	As Required by Miami-Dade PCA	Roof coating for application over polyurethane spray applied foam.	Generic. (with current PCA)

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Radco	RAD-4832	ASTM D1622	11/10/10
	RAD-4864	ASTM D1622	01/03/11
Momentum Technologies, Inc.	RX26H9A	TAS 110	12/28/09
	AX23G9B	ASTM D6694	03/22/10
	AX23G9A	ASTM D6694	03/22/10
Underwriters Laboratories Inc.	R19143	UL 790/ASTM E 108	08/05/09
Wingert Laboratories	MTI09-0998	TAS 114-D	12/03/10



APPROVED ASSEMBLIES:

Deck Type 3: Concrete

Deck Description: 2500 psi structural concrete or concrete plank

System Type A: Sprayed polyurethane foam applied directly to concrete deck and covered with an Approved Miami-Dade County roof coating.

All General and System Limitations apply.

Surface

Preparation:

Deck shall be primed if required; in accordance with West Development Group recommendations, and shall be free of loose dirt, grease, oil or other contaminants prior to priming or foam application. Remove loose dirt or debris by use of compressed air, vacuum or brooming. No washing shall be permitted. Oil, grease, release agents or other contaminants shall be removed with proper cleaning solutions.

Primers shall be applied if required; in accordance with their manufacturer's instructions. All primers must be thoroughly dry and cured prior to foam application.

All joint openings in concrete decks that exceed 1/4 inch shall be grouted or caulked.

Polyurethane Foam Application:

The polyurethane foam shall be applied uniformly over the entire surface at the specified thickness in compliance with the requirements set forth in Roofing Application Standard RAS 109 but in no case shall it be less than 1" thick. The sprayed polyurethane foam shall be feathered at the edges to produce a smooth transition.

**Protective Coating Application:
(Choose One)**

HSS 535 or HSS 540 R2R™ Solvent-Free Silicone Roof Coating shall be applied to achieve a minimum dry thickness of 15 mils.

Or

Apply a Miami-Dade County approved roof coating with a current NOA, that is compatible with this system and is applied in accordance with the guidelines listed in the products NOA.


Polyurethane foam surface shall be free of moisture, dust, debris, oils, tars, grease or other materials that will as recommended by West Development Group impair adhesion of the protective coverings. Any damage or defects to the polyurethane foam surface shall be repaired prior to the coating application. The coating shall be applied the same day as the foam when possible. If more than 72 hours elapse prior to the application of the coatings, the polyurethane foam shall be inspected for UV degradation.

Maximum Design Pressure:

-575 psf.



**TABLE 1
 AMBIENT HUMIDITY APPLICATION LIMITS
 SPRAYED POLYURETHANE FOAM**



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product
2. Spray polyurethane foam shall not be sprayed when ambient temperature is within 5 degrees of the dew point. Ambient humidity applications limits shall be as listed in Table 1 herein. Contractor shall monitor and record environmental conditions in the Job Log in compliance with RAS 109. Job Log shall be maintained at the job site and accessible to The Building Official.
3. Flashings and waterproof coverings for expansion joints shall be of compatible materials and in accordance with West Development Group published literature.
4. Miscellaneous materials such as adhesives, elastomeric caulking compounds, metal, vents and drains shall be a composite part of the roof system and shall be compatible with the foam and coating.
5. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and the wind load requirements of applicable building code.
6. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).

END OF THIS ACCEPTANCE

