



MIAMI-DADE COUNTY
BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
 (305) 375-2901 FAX (305) 372-6339

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/buildingcode

JB Garage Door, Inc.
12195 NW 98th Avenue
Hialeah Gardens, FL 33018

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Models 724/720 Steel Sectional Garage Door up to 12'-4" Wide.

APPROVAL DOCUMENT: Drawing No. **96-46**, titled "Steel Overhead Garage Door", dated 10/31/96, with last revision F dated 01/06/10, sheets 1 through 5 of 5, prepared by Al-Farooq Corporation, signed and sealed by Arshad Viqar, P.E., bearing the Miami-Dade County Product Control renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **renews NOA # 09-0212.09** and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**



[Handwritten Signature]
 06/28/10

NOA No. 10-0527.02
Expiration Date: October 16, 2015
Approval Date: July 21, 2010
 Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Drawing No. **96-46**, titled "Steel Overhead Garage Door", dated 10/31/96, with last revision F dated 01/06/10, sheets 1 through 5 of 5, prepared by Al-Farooq Corporation, signed and sealed by Arshad Viqar, P.E.

B. TESTS


1. Test Report on Tensile Test per ASTM E-8 of "Sectional Residential Door (skin)", prepared by Hurricane Engineering & Testing Inc, Report No. **HETI 08-T113**, dated 03/20/08, signed and sealed by Candido F. Font, P.E.
2. Test report on Uniform Static Air Pressure Test per FBC, TAS 202 & Forced Entry Resistance Test per SFBC, Section 3603.2 of Series 724 Garage Door, prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-05-1477**, dated 05/19/05, signed and sealed by Ivonne Ghia, P.E.
3. Test report on Large Missile Impact Test per FBC, TAS 201 and Cyclic Wind Pressure Test per FBC, TAS 203 of Series 724 Garage Door , prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-05-1457**, dated 05/27/05, signed and sealed by Ivonne Ghia, P.E.
"Submitted under NOA # 05-0922.01"

C. CALCULATIONS

1. Anchoring verification calculations prepared by Al-Farooq Corporation, complying with F.B.C 2007, dated 12/31/08, signed and sealed by Humayoun Farooq, P.E.
"Submitted under NOA # 09-0212.09"

D. QUALITY ASSURANCE

1. Miami Dade Building Code Compliance Office (BCCO)



06/28/10

Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 10-0527.02
Expiration Date: October 16, 2015
Approval Date: July 21, 2010

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. **07-1016.07**, issued to Insulfoam, LLC, for their Insulfoam Expanded Polystyrene Insulation, approved on 11/29/07 and expiring on 11/29/12.
2. Notice of Acceptance No. **07-1107.08**, issued to Dyplast Products, LLC, for their Expanded Polystyrene Block Type Insulation, approved on 04/26/07 and expiring on 08/27/08.
3. Notice of Acceptance No. **07-0301.10**, issued to Dyplast Products, LLC, for their Dyplast ISO-C1 Polyisocyanurate Insulation, approved on 06/07/07 and expiring on 01/11/12.

F. STATEMENTS

1. No change of product letter issued by JB Garage Doors, Inc, dated by 05/18/10, signed by Roseanne Berber.
2. Change of engineer letter issued by Al-Farooq Corporation, dated 01/08/10, signed and sealed by Arshad Viqar, P.E.
3. Statement letter of code conformance issued by Al-Farooq Corporation, dated 01/08/09, signed and sealed by Humayoun Farooq, P.E.
4. Statement letter of no financial interest issued by Al-Farooq Corporation, dated 01/08/09, signed and sealed by Humayoun Farooq, P.E.
"Submitted under NOA # 09-0212.09"




06/29/10

Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 10-0527.02

Expiration Date: October 16, 2015
Approval Date: July 21, 2010

no	date	description
B	11.4.98	OPT. INSULATION ADDED
C	06.01.05	GENERAL REV.
D	11.11.05	REV. PER BCCO COMMENTS
E	01.02.09	UPDATED FOR 2007 FBC
F	01.06.10	ENGR. NAME CHANGED

date:	10-31-96
scale:	NONE
dr. by:	HAMID
chk. by:	
drawing no.	96-46
sheet	1 of 5



INSIDE ELEVATION

THIS PRODUCT IS RATED FOR LARGE MISSILE IMPACT

END HINGES WITH PINS IN ROLLER SHAFTS

J.B. DOOR MODELS: 12'-4"W X 18'H MAX	
MODEL	DESCRIPTION
724	24 GA. ROLL FORMED STEEL DOOR
720	20 GA. ROLL FORMED STEEL DOOR

NOTE: MODEL 724 TESTED.

MAXIMUM DESIGN LOAD RATING = + 60.0 PSF
 (FOR SIZES SHOWN OR SMALLER) - 60.0 PSF

GENERAL NOTES

1. THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE 2007 EDITION INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).
2. ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS. ANCHOR EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.
3. ALL BOLTS, NUTS AND WASHERS SHALL BE ZINC PLATED CARBON STEEL.
4. ANCHORING OR LOADING CONDITIONS OTHER THAN THOSE SHOWN IN THESE DETAILS ARE NOT PART OF THIS APPROVAL.

Engr: ARSHAD VIQAR
 CIVIL
 FLA. PE # 38863
 C.A.N. 3538
Arizue
 JAN 08 2010

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No 10-0527.02
 Expiration Date 10/16/2015
 By *[Signature]*
 Miami Data Product Control
 Division

1-1/4" X 2-1/2" X 14 GA.
GALV. STEEL CONT. ANGLE
FASTENED TO WOOD JAMBS
W/ 5/16 X 1-5/8" LAG SCREWS
(FULLY THREADED)
HEX WASHER HEAD TYPE A
AT 3" FROM EACH END
AND 12" O.C. MAX.

OPTIONAL STOP MOULDING
BY DOOR INSTALLER

3 X 2 X .052" THK.
DIE FORMED STEEL END STILE
RIVETED TO SECTION SKIN
WITH (10) RIVETS

1/4-20 X 5/8" HEX HEAD
M.S. & LOCK NUT 4/ HINGE

STEEL STRUCTURE BY OTHERS
MUST SUPPORT THE LOADS IMPOSED
BY DOOR SYSTEM

(4) 1/4 X 5/8"
BOLTS WITH NUTS

1/4" X 5/8" S.M.S.
2/ HINGE

2-1/2" X 3-7/8" X 12 GA
GALV. STEEL TRACK PLATES @
12" O.C. SPOT WELDED TO 14
GA. ANGLE

FOR CONNECTION OF WOOD BUCK
TO MASONRY SEE NOTE ON SHEET 5
FOR CONNECTION DIRECTLY TO CONCRETE
SEE ALTERNATE DETAIL SHEET 5
CONNECTION TO METAL BUILDING TO BE
ENGINEERED ON JOB TO JOB BASIS.

ROLLER HINGE

1/8" DIA. COTTER PIN

2-3/4" X 2-1/4" X 14 GA.
GALV. STEEL CENTER HINGE

1.82" DIA. X .50" ROLLERS
W/ .43 DIA. X 7" STEM

1" X 2" X 14 GA. GALV. STEEL
TRACK FASTENED TO TRACK PLATES
W/ (2) 1/4-20 X 5/8" TRUSS HD.
SLOTTED M.S. & LOCK NUT

INTERIOR SIDE

SECTION B-B

Engr: ARSHAD VIQAR
CIVIL
FLA. PE # 38863
C.A.N. 3538

Arigyan
JAN 08 2010

PRODUCT RENEWED
as complying with the Florida
Building Code
Acceptance No. 10-0527-02
Expiration Date 10/16/2015
By *[Signature]*
Miami Dade Product Control
Division

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
GARAGE\96-46JB


STEEL OVERHEAD GARAGE DOOR
J.B. GARAGE DOORS INC.
12195 N.W. 98 TH. AVE.
HIALEAH GARDENS, FL. 33016
TEL. (305) 558 - 1658

revisions:		no	date	description
C	06.01.05			GENERAL REV.
D	11.11.05			REV. PER BCCO COMMENTS
E	01.02.09			UPDATED FOR 2007 FBC
F	01.06.10			ENGR. NAME CHANGED

date:	10-31-96
scale:	NONE
dr. by:	HAMID
chk. by:	


drawing no.
96-46

sheet 2 of 5




SECTION A-A

SEE SECTIONS AT RIGHT FOR LOCATION OF REINFORCING TRUSSES



PANEL SECTION REINFORCEMENT



SECTION D-D

Engr: ARSHAD VIQAR
 CIVIL
 FLA. PE # 38863
 C.A.N. 3538
Arqan
 JAN 08 2010

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No *10-0527-02*
 Expiration Date *10/11/2015*
 By *[Signature]*
 Miami Dade Product Control
 Division




af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 GARAGE 96-46JB

J.B. GARAGE DOORS INC.
 12195 N.W. 98 TH. AVE.
 HIALEAH GARDENS, FL. 33016
 TEL. (305) 558 - 1658

revisions:

no	date	description
C	06.01.05	GENERAL REV.
D	11.11.05	REV. PER BCCO COMMENTS
E	01.02.09	UPDATED FOR 2007 FBC
F	01.06.10	ENGR. NAME CHANGED

date: 10-31-96
 scale: NONE
 dr. by: HAMID
 chk. by:
 drawing no.
96-46
 sheet 3 of 5



DOOR TRACK AS VIEWED FROM CENTER OF OPENING

DOOR HEIGHT	NO. OF TRUSSES	SECTION HEIGHTS *								
		1ST	2ND	3RD	4TH	5TH	6TH	7TH	8TH	9TH
7'-0"	8	21"	21"	21"	21"	N/A	N/A	N/A	N/A	N/A
8'-0"	8	24"	24"	24"	24"	N/A	N/A	N/A	N/A	N/A
9'-0"	10	24"	21"	21"	21"	21"	N/A	N/A	N/A	N/A
10'-0"	10	24"	24"	24"	24"	24"	N/A	N/A	N/A	N/A
11'-0"	12	24"	24"	21"	21"	21"	21"	N/A	N/A	N/A
12'-0"	12	24"	24"	24"	24"	24"	24"	N/A	N/A	N/A
13'-0"	14	24"	24"	24"	21"	21"	21"	21"	N/A	N/A
14'-0"	14	24"	24"	24"	24"	24"	24"	24"	N/A	N/A
15'-0"	16	24"	24"	24"	24"	21"	21"	21"	21"	N/A
16'-0"	16	24"	24"	24"	24"	24"	24"	24"	24"	N/A
17'-0"	18	24"	24"	24"	24"	24"	21"	21"	21"	21"
18'-0"	18	24"	24"	24"	24"	24"	24"	24"	24"	24"

*-SECTIONS ARE NUMBERED STARTING AT THE BOTTOM

afc
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 GARAGE\96-46JB

STEEL OVERHEAD GARAGE DOOR
J.B. GARAGE DOORS INC.
 12195 N.W. 98 TH. AVE.
 HIALEAH GARDENS, FL. 33016
 TEL. (305) 558 - 1658

no	date	description
C	06.01.05	GENERAL REV.
D	11.11.05	REV. PER BCCO COMMENTS
E	01.02.09	UPDATED FOR 2007 FBC
F	01.06.10	ENGR. NAME CHANGED

date: 10-31-96	scale: NONE	dr. by: HAMID	chk. by:
----------------	-------------	---------------	----------

Engr. ARSHAD VIQAR
 CIVIL
 FLA. PE # 38863
 C.A.N. 3538


 JAN 08 2010

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No 10-0527.02
 Expiration Date 10/16/2015
 By
 Miami/Dade Product Control
 Division

drawing no.
96-46
 sheet 4 of 5

ANCHOR SPACING				
ANCHORS	STRUCTURE	EMBED	SPACING	EDGE DIST.
3/8" HLC SLEEVE BY 'HILTI'	CONC.	1-1/4"	8-1/2"	2"
3/8" HLC SLEEVE BY 'HILTI'	FILLED BLOCK	1-1/4"	8-1/2"	4"
3/8" DYNABOLT BY 'ITW'	CONC.	1-1/2"	8-1/2"	3"
1/2" DYNABOLT BY 'ITW'	FILLED BLOCK	1-7/8"	8-1/2"	4"
3/8" POWER-BOLT BY 'POWERS'	CONC.	2"	8-1/2"	1-7/8"
3/8" SLEEVE-ALL BY 'SIMPSONS'	CONC.	1-1/2"	8-1/2"	3"

CONCRETE f'c = 3000 PSI MIN.
 C-90 GROUT FILLED BLOCK f'm = 2000 PSI MIN.



TRACK INSTALLATION

WOOD FRAME BUILDINGS

STUD WALLS OR DOOR OPENING (NOT BY J.B. DOORS) SHALL BE FRAMED SOLID BY NOT LESS THAN (3) 2X6 PRESSURE TREATED GRADE 2 SYP OR BETTER WOOD STUDS.
 STUD WALLS TO BE CONT. FROM FOOTING TO TIE BEAM. ENGINEER OF RECORD TO VERIFY ADEQUACY OF THE SUPPORTING STRUCTURE.

WOOD BUCK CONNECTION TO MASONRY

TRACK SHALL BE SECURED WITH CONT. STEEL ANGLE TO PRESSURE TREATED 2X6 SYP WOOD JAMBS WHICH SHALL BE ANCHORED TO GROUTED REINFORCED MASONRY BLOCK WALL OR CONC. COLUMN WITH

1/4" ULTRACON BY 'ELCO' WITH SPACING OF 10" O.C. INTO BLOCK WALL, WITH 2-1/4" MIN. EMBED 9" O.C. INTO 3000 PSI CONCRETE, WITH 1-3/4" MIN. EMBED 2-1/2" MIN. EDGE DISTANCE


1/4" TAPPER BY 'POWERS' WITH SPACING OF 6" O.C. INTO BLOCK WALL, WITH 1-1/2" MIN. EMBED 7" O.C. INTO 3000 PSI CONCRETE, WITH 1-3/4" MIN. EMBED 3" MIN. EDGE DISTANCE

3/8" CONFLX BY 'ELCO' OR 3/8" LDT BY 'ITW' WITH SPACING OF 15" O.C. INTO 3000 PSI CONCRETE, WITH 2-1/2" MIN. EMBED 3" MIN. EDGE DISTANCE

3/8" HLC SLEEVE BY 'HILTI' WITH SPACING OF 9" O.C. INTO 3000 PSI CONCRETE, WITH 1-1/4" MIN. EMBED AND 2-1/2" MIN. EDGE DISTANCE

THE BLOCK WALL CELLS SHALL BE GROUT FILLED AND REINFORCED WITH FOUR # 5 BARS EXTENDING INTO FOOTING AND INTO TIE BEAMS ALL BARS SHALL BE CONTINUOUS FROM TIE BEAMS TO FOOTING.

PREPARATION OF JAMBS BY OTHERS



af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 GARAGE\96-46.JB

STEEL OVERHEAD GARAGE DOOR
J.B. GARAGE DOORS INC.
 12195 N.W. 98 TH. AVE.
 HIALEAH GARDENS, FL. 33016
 TEL. (305) 558 - 1658

no	date	by	description
C	06.01.05		GENERAL REV.
D	11.11.05		REV. PER BCCO COMMENTS
E	01.02.09		UPDATED FOR 2007 FBC
F	01.06.10		ENGR. NAME CHANGED

Engr: ARSHAD VIQAR
 CIVIL
 FLA. PE # 38863
 C.A.N. 3538
Arshad
 JAN 08 2010

PRODUCT RENEWED
 as complying with the Florida
 Building Code
 Acceptance No 10-0527-02
 Expiration Date 10/16/2015
 By *[Signature]*
 Miami Dade Product Control
 Division

date: 10-31-96
 scale: NONE
 dr. by: HAMID
 chk. by:
 drawing no.
96-46
 sheet 5 of 5