



BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

Seaman Corporation
1000 Venture Boulevard
Wooster, OH 44691

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: FiberTite Single Ply Roof Systems over Poured Gypsum Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA No. 05-0922.11 and consists of pages 1 through 7.
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 10-0719.05
Expiration Date: 01/05/12
Approval Date: 12/23/10
Page 1 of 7

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply
Material: KEE
Deck Type: Poured Gypsum
Maximum Design Pressure -45 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

| <u>Product</u> | <u>Dimensions</u> | <u>Test Specification</u> | <u>Product Description</u> |
|--|---------------------------------------|---------------------------|--|
| FiberTite, FiberTite XT, FiberTite LX, FiberTite SM, FiberTite Xtreme | various | TAS 114 | KEE, single ply membrane |
| FiberTite FB | 54" x 100' | TAS 114 | KEE, fleece-backed, single ply membrane |
| FTR Non-Reinforced | 0.060" x 54" x 24' | TAS 114 | KEE flashing accessory |
| FTR 101 | | proprietary | one part urethane sealant |
| FTR 201 | | proprietary | elastomeric (mastic) sealant |
| FTR 190 | | proprietary | two side "contact" bonding adhesive |
| FTR 290 | | proprietary | one side "substrate only" fleece back solvent based adhesive |
| FTR 390 | | proprietary | one side "substrate only" fleece back water based adhesive |
| FTR SL1 | | proprietary | one part "pourable" urethane sealant |
| FiberClad | 48" x 120" | n/a | polymeric coated G-90 galvanized steel or stainless steel |
| Tuff Trac | 5/32" x 36" x 40' 1/4" x 24" x 48" | n/a | vinyl walk way vinyl protection pad |



NOA No.: 10-0719.05
 Expiration Date: 01/05/12
 Approval Date: 12/23/10
 Page 2 of 7

APPROVED INSULATIONS:

TABLE 2

| Product Name | Product Description | Manufacturer (With Current NOA) |
|--------------------------|--|--|
| FTR-Value | Isocyanurate Insulation | Seaman Corp. |
| ACFoam Composite | Isocyanurate Insulation with perlite facer | Atlas Roofing Corp. |
| EnergyGuard Composite | Isocyanurate foam insulation with high density fiberboard or perlite insulation. | GAF Materials Corp. |
| Dens Deck | Silicon treated gypsum | G-P Products |
| Wood Fiberboard | Regular Wood Fiber insulation board. | Generic |
| Perlite Insulation Board | Perlite Insulation | Generic |
| ENRGY 3 | Isocyanurate Insulation | Johns Manville |
| Fesco Foam | Polyisocyanurate Insulation with perlite facer | Johns Manville |
| Multi-Max FA-3 | Polyisocyanurate foam insulation | Rmax, Inc. |
| Thermarroof Composite | Polyisocyanurate/perlite composite insulation. | Rmax, Inc. |

APPROVED FASTENERS:

TABLE 3

| Fastener Number | Product Name | Product Description | Dimensions | Manufacturer (With Current NOA) |
|------------------------|-------------------------------|---|-------------------|--|
| 1. | NTB Magnum | Fastener for cementitious and gypsum decks | Various | Olympic Mfg. Group |
| 2. | NTB Plate | Round Galvalume AZ55 stress plate | 3" round | Olympic Mfg. Group |
| 3. | NTB Metal Barbed Stress Plate | Round Galvalume AZ55 stress plate | 2" round | Olympic Mfg. Group |
| 4. | NTB Plastic Plate | Plastic plates for NTB 2" head fasteners. | 3" round | Olympic Mfg. Group |
| 5. | Powerlite Fastener | Insulation fastener for cementitious and gypsum decks | Various | Powers Fasteners Inc. |
| 6. | Powerlite Lap Plate | Round Galvalume AZ55 stress plate | 3" round | Powers Fasteners Inc. |



EVIDENCE SUBMITTED:

| <u>Test Agency/Identifier</u> | <u>Name</u> | <u>Report</u> | <u>Date</u> |
|---------------------------------|---------------------------------------|-------------------|-----------------------|
| Factory Mutual Research Corp. | FMRC 4470 | J.I. #1Z2A5.AM | 01/12/96 |
| Factory Mutual Research Corp. | Insulation Attachment Requiremetns | FM Approval Guide | Published Annually |
| Factory Mutual Research Corp. | FMRC 4470 | J.I. 1Z3A8.AM | 08/13.97 |
| Underwriters Laboratories | Fire Classifications | Listing R-10117 | Published Annually |
| Underwriters Laboratories | Fire Resistance Testing | 95NK20862 | 11/17/95 |
| Underwriters Laboratories | Fire Resistance Testing | 94NK40647 | 10/15/94 |
| Warnock Hersey | Fire Resistance Tests | 495-R-0735 | Published Annually |
| Exterior Research & Design, LLC | TAS 114 | 4015.10.96-1-R1 | 07/20/10 |
| Exterior Research & Design, LLC | TAS 114 | 4006.07.97-1-R1 | 07/15/10 |



APPROVED ASSEMBLIES

- Membrane Type:** Single Ply, KEE
- Deck Type 6I:** Poured Gypsum, Insulated
- Deck Description:** Poured Gypsum Concrete
- System Type D:** Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply.

| Insulation Layer | Insulation Fasteners (Table 3) | Fastener Density/ft² |
|--|---|--|
| FTR-Value, Multi-Max FA-3, ENRGY-3, ACFoam Composite, EnergyGuard Composite, Thermarof Composite, Fesco Foam Minimum 1.5" thick | N/A | N/A |
| Approved Wood Fiberboard Minimum ½" thick | N/A | N/A |
| Approved Perlite Minimum ¾" thick | N/A | N/A |

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

- Vapor Retarders:** (Optional) Any UL or FM approved vapor retarder applied to the roof deck or over a base layer of insulation.
- Barrier:** (Optional) ¼" or ½" DensDeck applied to the base or top insulation layer.
- Membrane:** FiberTite, XT, SM or Xtreme roof cover attached through the preliminary fastened insulation to the deck as specified below:
- Fastening:** Fasten with NTB fasteners with 2" diameter head or Powerlite fasteners and Powerlite Lap Plates stress plates 6" o.c. through the fastening tabs spaced 51" o.c.
- Maximum Design Pressure:** -45 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 6: Poured Gypsum, Non-Insulated
Deck Description: Poured Gypsum Concrete
System Type E: Membrane mechanically attached to deck.

All General and System Limitations apply.

Vapor Retarders: (Optional) Any UL or FM approved vapor retarder applied to the roof deck.
Barrier: (Optional) ¼" or ½" DensDeck applied to the deck.
Membrane: FiberTite, XT, SM or Xtreme roof cover attached to the deck following the fastening method specified below:
Fastening: Fasten with NTB fasteners with 2" diameter head or Powerlite fasteners and Powerlite Lap Plates stress plates 6" o.c. through the fastening tabs spaced 51" o.c.
Maximum Design Pressure: -45 psf (See General Limitation #9)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 10-0719.05
Expiration Date: 01/05/12
Approval Date: 12/23/10