



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Owens Corning
One Owens Corning Parkway
Toledo, OH 43659**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: WeatherGuard HP Shingles

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This renews and revises NOA # 05-0921.14 and consists of pages 1 through 5.
The submitted documentation was reviewed by Alex Tigera.



**NOA No.: 10-0817.10
Expiration Date: 01/04/16
Approval Date: 10/27/10
Page 1 of 5**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Asphalt Shingles
Materials Laminate
Deck Type: Wood

1. SCOPE:

This revises Owens Corning WeatherGuard HP as manufactured by Owens Corning described in Section 2 of this Notice of Acceptance.

2. PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
WeatherGuard HP	13-1/4" x 39-3/8"	TAS 110	A heavy weight, fiberglass reinforced laminate asphalt shingle. All shingles shall be labeled on the underside with the Miami-Dade seal.

3. EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Asphalt Technologies, Inc.	PRI00035	TAS 100	11/1/2000
Underwriters Laboratories, Inc.	R2453/00NK33081	Reference	10/26/2000
PRI Asphalt Technologies, Inc.	OCF-065-02-01	TAS 100	08/23/02
Underwriters Laboratories, Inc.	01NK52087	TAS 107	11/14/02

4. LIMITATIONS:

- 4.1 Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 4.2 Shall not be installed on roof mean heights in excess of 33 ft.

5. INSTALLATION:

- 5.1 Shingles shall be installed in compliance with Roofing Application Standard RAS 115.
- 5.2 Flashing shall be in accordance with Roofing Application Standard RAS 115
- 5.3 The manufacturer shall provide clearly written application instructions.
- 5.4 Exposure and course layout shall be in compliance with Detail 'A', attached.
- 5.5 Nailing shall be in compliance with Detail 'B', attached.

6. LABELING:

- 6.1 Shingles shall be labeled with the Miami-Dade Seal as seen below or the wording "Miami-Dade County Product Control Approved".



NOA No.: 10-0817.10
 Expiration Date: 01/04/16
 Approval Date: 10/27/10
 Page 2 of 5

7. BUILDING PERMIT REQUIREMENTS:

7.1 Application for building permit shall be accompanied by copies of the following:

7.1.1 This Notice of Acceptance.


7.1.2 Any other documents required by the Building Official or the applicable code in order to properly evaluate the installation of this system.

8. MANUFACTURING LOCATION:

8.1 Houston, TX



DETAIL A




OWENS CORNING WEATHERGUARD HP



NOA No.: 10-0817.10
Expiration Date: 01/04/16
Approval Date: 10/27/10
Page 4 of 5

DETAIL B

OWENSCORNING
WeatherGuard HP



OWENS CORNING WEATHERGUARD HP

END OF THIS ACCEPTANCE



NOA No.: 10-0817.10
Expiration Date: 01/04/16
Approval Date: 10/27/10
Page 5 of 5