MIAMI-DADE COUNTY
BUILDING AND NEIGHBORHOOD COMPLIANCE DEPARTMENT (BNC)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/building

NOTICE OF ACCEPTANCE (NOA)

BASF Corporation
1703 Crosspoint
Houston, TX 77054-3707

SCOPE:
This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Section and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Foam Systems over Concrete Deck

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 08-0820.10 and consists of pages 1 through 5.
The submitted documentation was reviewed by Jorge L. Acebo

MIAMI-DADE COUNTY APPROVED

NOA No.: 10-0824.08
Expiration Date: 01/07/13
Approval Date: 02/10/11

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Spray Applied Polyurethane Roof System
Materials:	Polyurethane
Dect Type	Concrete
Maximum Design Pressure	**-495 psf**

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

Product	Dimensions	Test Specifications	Product Description
FE 348-2.5 or Elastospray 81255	2.5 lb/ft^3 density	TAS 110	Polyurethane spray applied foam that utilizes an HFC blowing agent intended for roofing applications.
FE 348-2.7 or Elastospray 81275	2.8 lb/ft^3 density	TAS 110	Polyurethane spray applied foam that utilizes an HFC blowing agent intended for roofing applications.
FE 348-2.8 or Elastospray 81285	2.8 lb/ft^3 density	TAS 110	Polyurethane spray applied foam that utilizes an HFC blowing agent intended for roofing applications.
FE 348-3.0 or Elastospray 81305	3.0 lb/ft^3 density	TAS 110	Polyurethane spray applied foam that utilizes an HFC blowing agent intended for roofing applications.

TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS:

Product	Dimensions	Test Specifications	Product Description	Manufacturer
Any Miami-Dade County Approved Roof Coating	N/A	As Required by Miami-Dade PCA	Roof coating for application over polyurethane spray applied foam.	Generic. (with current PCA)

EVIDENCE SUBMITTED:

Test Agency	Test Identifier	Test Name/Report	Date
Radco	RAD-3551 RAD-4039	TAS 110 TAS 110	12/15/2004 05/02/2007
Stork Twin City Testing	30160 04-63383.0	ASTM E 96	11/18/2004
Underwriters Laboratories Inc.	R9865	UL 790/ ASTM E 108	10/17/2003 05/15/2007
Atlantic & Caribbean Roof Consulting, LLC	ACRC 04-005	TAS 114	11/02/2004
Factory Mutual	3016938 3028285 3015667	4470/4880 4470/4880 4470/4880	12/20/2004 07/27/2007 05/02/2005

APPROVED ASSEMBLIES:

Deck Type 3: Concrete

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(1): Sprayed polyurethane foam applied directly to concrete deck and covered with an Approved Miami-Dade County roof coating.

All General and System Limitations apply.

Surface Preparation: Deck shall be primed if required; in accordance with BASF Corporation recommendations, and shall be free of loose dirt, grease, oil or other contaminants prior to priming or foam application. Remove loose dirt or debris by use of compressed air, vacuum or brooming. No washing shall be permitted. Oil, grease, release agents or other contaminants shall be removed with proper cleaning solutions.

Primers shall be applied if required; in accordance with their manufacturer's instructions. All primers must be thoroughly dry and cured prior to foam application.

All joint openings in concrete decks that exceed 1/4 inch shall be grouted or caulked.

Polyurethane Foam Application: The polyurethane foam shall be applied uniformly over the entire surface at a minimum thickness of 1" and a maximum thickness of 6" in compliance with the requirements set forth Roofing Application Standard RAS 109. The sprayed polyurethane foam shall be feathered at the edges to produce a smooth transition.

Protective Coating Application: Shall apply a Miami-Dade County approved roof coating with a current NOA applied in accordance with the guidelines listed in the NOA.

Polyurethane foam surface shall be free of moisture, dust, debris, oils, tars, grease or other materials that will impair adhesion of the protective coverings. Any damage or defects to the polyurethane foam surface shall be repaired prior to the coating application. The coating shall be applied the same day as the foam when possible. If more than 72 hours elapse prior to the application of the coatings, the polyurethane foam shall be inspected for UV degradation.

Maximum Design Pressure: -495 psf.

Deck Type 3: Concrete

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(2): Sprayed polyurethane foam applied directly to primed concrete deck and covered with an Approved Miami-Dade County roof coating.

All General and System Limitations apply.

Surface Preparation: Deck shall be primed in accordance with BASF Corporation recommendations, and shall be free of loose dirt, grease, oil or other contaminants prior to priming or foam application. Remove loose dirt or debris by use of compressed air, vacuum or brooming. No washing shall be permitted. Oil, grease, release agents or other contaminants shall be removed with proper cleaning solutions.

Primers shall be applied in accordance with their manufacturer's instructions. All primers must be thoroughly dry and cured prior to foam application.

All joint openings in concrete decks that exceed 1/4 inch shall be grouted or caulked.

Polyurethane Foam Application: The polyurethane foam shall be applied uniformly over the entire surface at a minimum thickness of 1" and a maximum thickness of 6" in compliance with the requirements set forth Roofing Application Standard RAS 109. The sprayed polyurethane foam shall be feathered at the edges to produce a smooth transition.

Protective Coating Application: Shall apply a Miami-Dade County approved roof coating with a current NOA applied in accordance with the guidelines listed in the NOA.

Polyurethane foam surface shall be free of moisture, dust, debris, oils, tars, grease or other materials that will impair adhesion of the protective coverings. Any damage or defects to the polyurethane foam surface shall be repaired prior to the coating application. The coating shall be applied the same day as the foam when possible. If more than 72 hours elapse prior to the application of the coatings, the polyurethane foam shall be inspected for UV degradation.

Maximum Design Pressure: -187.5 psf.

TABLE 1
AMBIENT HUMIDITY APPLICATION LIMITS
SPRAYED POLYURETHANE FOAM

BASF Corporation
Air Temp/ Humidity/ Dew point Guideline



	45	67	40.5	50	70	45.5	55	72	50.5	60	75	55.5
Air	45	50	55	60	65	70	75	80	85	90	95	100
Hu	67	70	72	75	78	80	78	75	70	64	58	50
De	40.5	45.5	50.5	55.5	60.5	65.5	70	73.5	77	79.5	82	83

Dew point and relative humidity for given dry bulb temperature.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product
2. Spray polyurethane foam shall not be sprayed when ambient temperature is within 5 degrees of the dew point. Ambient humidity applications limits shall be as listed in Table 1 herein. Contractor shall monitor and record environmental conditions in the Job Log in compliance with RAS 109. Job Log shall be maintained at the job site and accessible to The Building Official.
3. Flashings and waterproof coverings for expansion joints shall be of compatible materials and in accordance with BASF Corporation published literature.
4. Miscellaneous materials such as adhesives, elastomeric caulking compounds, metal, vents and drains shall be a composite part of the roof system and shall be compatible with the foam and coating.
5. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and the wind load requirements of applicable building code.
6. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).

END OF THIS ACCEPTANCE