



MIAMI-DADE COUNTY
BUILDING AND NEIGHBORHOOD COMPLIANCE DEPARTMENT (BNC)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
 11805 SW 26 Street, Room 208
 Miami, Florida 33175-2474
 T (786) 315-2590 F (786) 315-2599

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/building

Florida's International Ceiling Corp.
4769 NW 72 Avenue
Miami, FL 33166

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Section and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code. This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: PVC Interior Ceiling

APPROVAL DOCUMENT: Drawing No. **AD11-03**, titled "PVC Ceiling Plank System" sheets 1 of 1, dated 02/09/11, prepared by MCY Engineering, Inc, signed and sealed by Yiping Wang, P.E., bearing the Miami-Dade County Product Control approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: None

LABELING: Each carton shall bear a permanent label with the following:

Vipal Plasticos
 Av Severo Dullius 1395
 Porto Alegre, CEP 90200-310, Brasil
 and the statement: "Miami-Dade County Product Control Approved".

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official. This NOA consists of this page 1 and evidence page E-1, as well as approval document mentioned above. The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**



[Handwritten Signature]
 02/17/11

NOA No. 10-1115.01
Expiration Date: March 10, 2016
Approval Date: March 10, 2011
 Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Drawing No. **AD11-03**, titled "PVC Ceiling Plank System" sheets 1 of 1, dated 02/09/11, prepared by MCY Engineering, Inc, signed and sealed by Yiping Wang, P.E.

B. TESTS

	<u>Laboratory Report</u>	<u>Test</u>	<u>Date</u>	<u>Signature</u>
1.	HETI-10-F501	ASTM D 635-06	06/24/10	Candido F. Font, P.E.
2.	HETI-10-F501	ASTM D1929-96	06/24/10	Candido F. Font, P.E.
3.	HETI-10-F501	ASTM D 2843-99	06/24/10	Candido F. Font, P.E.

C. CALCULATIONS:

1. None.

D. QUALITY ASSURANCE


1. Miami-Dade Building and Neighborhood Compliance Department (BNC)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS


1. Statement letter of code conformance to FBC 2007, issued by MCY Engineering Inc, dated 02/17/11, signed and sealed by Yiping Wang, P.E.
2. Statement letter of no financial interest, issued by MCY Engineering Inc, dated 02/17/11, signed and sealed by Yiping Wang, P.E.
2. Distributor agreement dated 09/16/10.



02/17/11

Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 10-1115.01

Expiration Date: March 10, 2016
Approval Date: March 10, 2011



TESTED SPECIMEN


NOTE: ALL CORNER CEILING PANEL & MOLDING JOINT SEALED WITH SILICONE

DESCRIPTION

POLYVINYL CHLORIDE (PVC) MEET THE REQUIREMENT OF SECTION 2612 OF THE FLORIDA BUILDING CODE.

USE:
THIS MATERIAL IS USE FOR INTERIOR ONLY. THIS IS A COMPONENT APPROVAL AND DOES NOT INCLUDE AN EVALUTION OF STRUCTURAL PERFORMANCE OF THIS COMPONENT.

DESIGNATION	TEST	PROPERTIES
Self-Ignition Temperature	ASTM D1929	850°F > 650° F
Rate of Burning	ASTM D635	< 1.0 in/min. C-1
Smoke Density	ASTM D2843	46.8% < 75%
Air Leakage Rate	ASTM E283	0.094 ft ³ /min-ft ²



SECTION A

Approved as complying with the Florida Building Code
 Date 03/10/2011
 NOA# 10-1115.01
 Miami Dade Product Control
 By *[Signature]*

YIPING WANG, P.E.
 FLORIDA REGISTRATION
 PE #55983
 C.A.N. 28677

MIAMI DADE COUNTY
FEB 09 2011

REVISIONS	
NO.	DATE DESCRIPTION

MCY ENGINEERING, INC.
 GLAZING CONSULTANTS

9110 SW SUNSET DRIVE P: 305.271.0117
 MIAMI, FL 33173 F: 786.573.5063
 www.MCYEngineering.com MCY.Engineering@Att.net

PVC CEILING PLANK SYSTEM

FLORIDA'S INTERNATIONAL CEILINGS, CORP.
 josefino@hotmail.com
 4769 NW 72 ND, MIAMI, FLORIDA 33166
 Tel: (305) 215-6888 Fax: (305) 463-7683

DATE	02-09-11
SCALE	NIS.
DRAWN	M.C.
PROJECT	10-031
DRAWING NO.	AD11-03
SHEET	1 OF 1