



BUILDING AND NEIGHBORHOOD COMPLIANCE DEPARTMENT (BNC)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/building/

NOTICE OF ACCEPTANCE (NOA)

CertainTeed Corporation
1400 Union Meeting Road
Blue Bell, PA 19422

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Section and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: CertainTeed Coatings and Cements

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This renews NOA # 08-0825.06 and consists of pages 1 through 6.
The submitted documentation was reviewed by Alex Tigera.



NOA No 10-1115.04
Expiration Date: 02/01/16
Approval Date: 02/24/11
Page 1 of 6

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Material: Asphalt

SCOPE:

This approves CertainTeed Coatings and Cements as described in this Notice of Acceptance. This product has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Underwriter Laboratories, Inc.	R13663	Fire Classification	1994
	R11333		1999
	R13663		2005
PRI Asphalt Technologies	GGI-025-02-01	Physical Properties	01/12/06
	GGI-020-02-01	ASTM Compliance	01/03/06
	GGI-022-02-01		01/11/06
	GGI-021-02-01		01/03/06
	GGI-027-02-01		01/03/06
	GGI-019-02-01		01/03/06
	GGI-005-02-01		10/19/05
	GGI-006-02-01		10/19/05
	GGI-017-02-01		10/14/05
	GGI-011-02-01		11/16/05
	GGI-024-02-01		01/12/06
	GGI-023-02-01		01/15/06
	GGI-018-02-01		12/21/05
GGI-004-02-01		10/19/05	
GGI-006-02-01		10/19/05	
GGI-007-02-01		10/19/05	

PHYSICAL PROPERTIES OF COMPONENTS:

Trade Name: FlintPatch

Thickness: See System Approvals Below.

Specifications: ASTM D 4586 Type I and ASTM D 3409

Description: Asbestos free, asphalt based trowelable rubberized flashing cement. Apply with a putty knife or trowel, filling all fissures, joints and gaps. Apply at an approximate rate of 1/8" thick; 1 gal/12 1/2 sq. ft. When used on a bonded or warranted roof system, follow instructions of that application system.

Container size: 1, 3, 5 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.



NOA No 10-1115.04
Expiration Date: 02/01/16
Approval Date: 02/24/11
Page 2 of 6

PHYSICAL PROPERTIES OF COMPONENTS: (CONTINUED)

Tradename: **FlintBond Brush**

Thickness: See System Approvals Below.

Description: An asbestos free, polymer modified, asphalt based, cold applied adhesive. For use with modified bitumen membranes, base and ply sheets. Applied with a notched squeegee, brush or roller forming a continuous film. Applied at the lap so that a continuous bead can be seen at the lap edges. Apply at an approximate rate of 1 gal./100-150 sq. ft..

Container Size: 1, 5, 55 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade Name: **FlintBond Trowel**

Thickness: See System Approvals Below.

Specifications: ASTM D 4586 Type I and ASTM D 3409

Description: Asbestos free, asphalt based trowelable rubberized flashing cement. Apply with a putty knife or trowel, filling all fissures, joints and gaps. Apply at an approximate rate of 1/8" thick; 1 gal/12 1/2 sq. ft. When used on a bonded or warranted roof system, follow instructions of that application system.

Container size: 1, 3, 5 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Tradename: **FlintCoat A 150**

Thickness: See System Approvals Below.

Specifications: ASTM D 2824 Type III

Description: A fibered aluminum roof coating used to protect underlying roofing materials and to reflect the sun's rays. Applied by spray or brush at an approximate rate of 1 gal/50 to 100 sq. ft..

Container Size: 1, 5, 55 gallons. Note all precautions on container.

System Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.



PHYSICAL PROPERTIES OF COMPONENTS: (CONTINUED)

Trade Name: **FlintCoat A 300**

Thickness: See System Approvals Below.

Specifications: ASTM D 2824 Type III and ASTM D 3805

Description: A reflective, aluminum roof coating with fibers which strengthen the protective film. Recommended for emulsion surfaced or mineral surfaced roofs. Apply evenly by spray or soft brush and avoid scraping into soft roof surfaces. Apply at an approximate rate of 1 gal/50 to 100 sq. ft..

Container Size: 1, 5, 50 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade Name: **FlintCoat A-NF**

Thickness: See System Approvals Below.

Specifications: ASTM D 2824 Type I

Description: A highly reflective, non-fibered aluminum roof paint. Specially designed to repel the sun's heat on emulsion surfaced or mineral surfaced roofs and sheet metal buildings and roofs. Apply by spray, roller or soft brush, spreading in both horizontal and vertical directions. Application rate varies depending upon surface. See manufacturer's specifications.

Container Size: 1, 5, 50 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: **FlintCoat E**

Thickness: See Systems Approvals Below.

Specifications: ASTM D 1227 Type IV

Description: An asphalt base clay-type emulsion coating containing mineral fibers. Non-flammable and specifically formulated to bond to damp or dry surfaces. For use as a protective surface coating over built-up ply sheets, mineral surfaced cap sheets and other asphalt roof surfaces. Apply one or more coats as required at approximately 1 to 3 gal/100 sq. ft.. Apply second coat at right angle to first coat.

Container Size: 1, 5, 55 gallons. Note all precautions on container..

Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.



PHYSICAL PROPERTIES OF COMPONENTS: (CONTINUED)

- Trade Name: **FlintPrime**
- Thickness: See System Approvals Below.
- Specifications: ASTM D 41
- Description: Asphalt primer used to seal newly laid concrete or cement decks prior to applying build-up roofing. Apply with brush or spray, working the material to a smooth and even consistency. Apply at an approximate rate of 1 gal/150 to 200 sq. ft. **Note: Do not thin. Do not apply to wet or damp surfaces.**
- Container Size: 1, 5, 55 gallons. Note all precautions on container.
- Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.
-
- Trade Names: **FlintCoat W**
- Thickness: Apply a Base Coat at a minimum rate of 1 ½ gal per square and a finish coat at 1 ½ gal per square.
- Specifications: ASTM D 6083
- Description: A reflective elastomeric coating membrane applied to, BUR membranes, Metal Roofs, EPDM membranes, Cement Tiles* (Flat or Barrel), Bonded Gravel Roofs, Polyurethane Foam Roofs, pitch pockets, granule surface cap sheets and Aged Roofs previously coated with asphalt.
- Container Size: 1, 5, 55 and 275 gallons
- Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.
*Tile system shall be in accordance with tile roof manufacturer's NOA and RAS 118, 119 or 120. The coating membrane shall be applied such that the tile head-laps are not filled or 'clogged' with coating material, so as to maintain an air-permeable tile roof system



LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. CertainTeed Coatings and Cements products shall not be applied in inclement weather conditions.
3. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
4. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.
5. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



6. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
7. CertainTeed Coatings and Cements products shall be applied in accordance with manufacturer's published application instructions.

END OF THIS ACCEPTANCE

