MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/building/

BUILDING AND NEIGHBORHOOD COMPLIANCE DEPARTMENT (BNC)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

GAF Materials Corporation
1361 Alps Road
Wayne, NJ. 07470

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County BNC - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BNC reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: GAF ProStart Starter Strip Shingles

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This revises NOA# 06-0406.10 and consists of pages 1 through 4.
The submitted documentation was reviewed by Alex Tigera.

MIAMI-DADE COUNTY APPROVED

ROOFING ASSEMBLY APPROVAL

Category:	Roofing
Sub-Category:	Asphalt Shingles
Materials	Laminate
Deck Type:	Wood

SCOPE:

This approves **GAF ProStart Starter Strip Shingles** manufactured by **GAF Materials Corporation** as described in this Notice of Acceptance, designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

PRODUCT DESCRIPTION

Product	Dimensions	Test Specifications	Product Description
GAF ProStart Starter Strip Shingles	13" x 38"	TAS 110	Prefabricated starter strip asphalt shingle.

MANUFACTURING LOCATION

1. Dallas, TX.
2. Mt. Vernon, IN.
3. Tuscaloosa, AL.

EVIDENCE SUBMITTED

Test Agency	Test Identifier	Test Name/Report	Date
PRI Asphalt Technologies, Inc.	ELK-34-02-01	TAS 100	05/16/00
Underwriters Laboratories, Inc.	01NK06632	ASTM D 3462	02/01/01
	94NK9632	TAS 107	03/29/00
	00NK32754	ASTM D 3462	08/11/00
	10CA07264	ASTM D 3462	05/27/10
	10NK11953	ASTM D 3462	10/29/10

LIMITATIONS

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Shall not be installed on roof mean heights in excess of 33 ft.
3. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

INSTALLATION

1. Starter Strip Shingles shall be installed in compliance with Roofing Application Standard RAS 115.
2. The manufacturer shall provide clearly written application instructions.

LABELING

Shingles shall be labeled with the Miami-Dade Logo or the wording "Miami-Dade County Product Control Approved".

BUILDING PERMIT REQUIREMENTS

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or the applicable code in order to properly evaluate the installation of this system.

GAF ProStart Starter Strip



BACK VIEW



TOP VIEW

END OF THIS ACCEPTANCE