MIAMI-DADE COUNTY
BUILDING AND NEIGHBORHOOD COMPLIANCE DEPARTMENT (BNC)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/building

NOTICE OF ACCEPTANCE (NOA)

Neogard div of Jones-Blair
2728 Empire Central
Dallas, TX 75235

SCOPE:
This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Section and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Elasta-Gard

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA No. 09-0630.10 and consists of pages 1 through 4.
The submitted documentation was reviewed by Jorge L. Acebo

MIAMI-DADE COUNTY APPROVED

NOA No.: 11-0124.02
Expiration Date: 04/13/16
Approval Date: 03/31/11

ROOFING COMPONENT APPROVAL

Category:	Roofing
Sub-Category:	Cements, Coatings, Adhesives
Material:	Elastomeric

SCOPE:

This approves "**Elasta-Gard**" as a maintenance roof coating system as manufactured by Neogard div of Jones-Blair, as described in this Notice of Acceptance. This product has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

EVIDENCE SUBMITTED:

Test Agency	Test Identifier	Test Name/Report	Date
PRI Asphalt Technologies, Inc.	NDJB-007-02-01	ASTM D 6083/TAS 114(H)	08/22/05
PRI Construction Materials Technologies, LLC	NDJB-007-02-01REV3	ASTM D 6083 ASTM C 794/ASTM D 903	06/11/09

MANUFACTURING LOCATION:

1. Dallas, TX

PHYSICAL PROPERTIES OF COMPONENTS:

Trade names:	**70611 PermaThane Top Coat** **70612 PermaThane Top Coat** **70613 PermaThane Top Coat**
Thickness:	See Description Below.
Specifications:	ASTM D 6083
Description:	A white, gray or tan single component aromatic solvent based polyurethane elastomeric coating membrane that is applied as specified within the application table over a base coat / primer as a top coat. The application rate shall be a minimum 1.5 gal/100ft^2 in order to achieve a minimum dry mil thickness of 16 mils for the top coat layer.
Container Size:	5 and 55 gallons. Note all precautions on container.
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly System's Product Control Notice of Acceptance where it exceeds standards of this NOA.

MAINTENANCE COATING APPLICATION:

Surface Preparation: Remove all lose gravel, dirt, dust and any foreign matter that may inhibit adhesion of coating by vacuuming, sweeping, power brooming or power washing. Repair all blisters and delaminating membranes.

Base Coat: Coat the clean and dry existing roof surface with the appropriate basecoat and/or primer as specified within the application table below.

Reinforcement Fabric: (Optional) Apply Garland Ulti-Mat reinforcement fabric with a thin coating of the base coat / primer product or the top coat product. Fabric shall be rolled in to ensure complete adhesion, making sure the roller is saturated so that the fibers are not pulled up. The fabric shall not contain wrinkles, buckles or fish mouths. Additional coatings of the top coat beyond what is specified below may be required to ensure the glass mat is fully embedded and not exposed.

Top Coat: Apply PermaThane Top Coat onto the appropriate basecoat and/or primer as specified within the application table below.

COATING APPLICATION TABLE:

Substrate	Base Coat / Primer Layer			Top Coat Layer		
	Product	Minimum Application Rate gal/100 ft^2	Base Coat / Primer Minimum Dry mil thickness	Product	Minimum Application Rate gal/100 ft^2	Total System Minimum Dry mil thickness
EPDM	7419 PermaGard Base Coat	.5	8	PermaThane Top Coat	1.5	24
EPDM	7419-HB PermaGard Base Coat	.5	8	PermaThane Top Coat	1.5	24
SBS Granule	7419 PermaGard Base Coat	.5	8	PermaThane Top Coat	1.5	24
SBS Granule	7419-HB PermaGard Base Coat	.5	8	PermaThane Top Coat	1.5	24
BUR Smooth	7780/7781 Epoxy Primer (first) and then 7419-HB PermaGard Base Coat	0.3 + .5	1.5 + 8	PermaThane Top Coat	1.5	25.5
TPO	7419 PermaGard Base Coat	.5	8	PermaThane Top Coat	1.5	24
TPO	7419-HB PermaGard Base Coat	.5	8	PermaThane Top Coat	1.5	24
PVC	7419 PermaGard Base Coat	.5	8	PermaThane Top Coat	1.5	24
PVC	Ureprime (33010/99951) Primer	0.25	4	PermaThane Top Coat	1.5	20
PVC	7419-HB PermaGard Base Coat	.5	8	PermaThane Top Coat	1.5	24
Hypalon	7419-HB PermaGard Base Coat	.5	8	PermaThane Top Coat	1.5	24
Galv. Steel	Ureprime (33010/99951) Primer	0.25	4	PermaThane Top Coat	1.5	20
Coated Steel	Ureprime (33010/99951) Primer	0.25	4	PermaThane Top Coat	1.5	20
Concrete	70620 PermaGard Base Coat	.5	8	PermaThane Top Coat	1.5	24

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.

2. **Elasta-Gard** roof coating system shall not be applied in inclement weather conditions.

3. **Elasta-Gard** roof coating system shall only be applied to Concrete, BUR, Steel, EPDM, PVC, Hypalon, TPO and SBS roofing as specified in the preceding application table.

4. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list the products listed herein as part of their roof assemblies Notice of Acceptance.

5. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.

6. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.

7. **Elasta-Gard** roof coating system shall be applied in accordance with manufacturer's published application instructions.

8. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

9. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.

MIAMI-DADE COUNTY APPROVED

END OF THIS ACCEPTANCE