

BUILDING AND NEIGHBORHOOD COMPLIANCE DEPARTMENT (BNC) BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

Johns Manville Corporation 717 17th Street Denver, CO 80202

Scope:

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION 11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/building

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County BNC - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BNC reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Johns Manville Modified Bitumen Roofing Systems Over Wood Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA No. 09-0902.04 and consists of pages 1 through 20. The submitted documentation was reviewed by Jorge L. Acebo.



NOA No: 11-0126.01 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 1 of 20

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Modified Bitumen
Material:	SBS
Deck Type:	Wood
Maximum Design Pressure	-60 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT: Table 1

<u>Product</u>	Dimensions	Test <u>Specification</u>	Product <u>Description</u>
DynaBase	54'-10" x 36"	ASTM D 6163	An SBS modified bitumen coated, fiber
D W11D		Type I Grade S	glass reinforced base sheet.
DynaWeld Base	39'-3/8" x 32'-10"	ASTM D 6163	An SBS modified bitumen coated, fiberglass
		Type I Grade S	reinforced base sheet for heat welded applications.
DynaFlex	3 x 25	ASTM D 6221	A flexible polyester/glass scrim reinforced,
-			granular-surfaced flashing sheet.
DynaGlas	39-3/8" x 32'-10"	ASTM D 6163	An SBS modified bitumen membrane
		Type I Grade G	surfaced with granules for application in hot
			asphalt.
DynaWeld Cap FR	39'-3/8" x 32'-10"	ASTM D 6163	A fire resistant SBS modified bitumen
		Type I Grade G	membrane surfaced with granules for heat weld applications.
DynaGlas 30 FR	39-3/8" x 32'-10"	ASTM D 6163	A fire resistant SBS modified bitumen
5		Type I Grade G	membrane surfaced with granules for
			application in hot asphalt.
DynaGlas FR	39-3/8" x 32'-10"	ASTM D 6163	A fire resistant SBS modified bitumen
		Type I Grade G	membrane surfaced with granules for
			application in hot asphalt.
DynaKap	39-3/8" x 32'-10"	ASTM D 6162	A fiberglass/polyester reinforced SBS
		Type I Grade G	modified bitumen membrane surfaced with granules for application in hot asphalt.
DynaKap FR	39-3/8" x 32'-10"	ASTM D 6162	A fire resistant, fiberglass/ polyester
2 Juni up 110	0,0,0,0,00	Type I Grade G	reinforced SBS modified bitumen
		51	membrane surfaced with granules for
			application in hot asphalt.
DynaLastic 180	39-3/8" x 32'-10"	ASTM D 6164	A 180 gram polyester reinforced SBS
		Type I Grade G	modified bitumen membrane surfaced with
			granules for application in hot asphalt.
DynaLastic 180 FR	39-3/8" x 32'-10"	ASTM D 6164	A 180 gram polyester mat reinforced,
		Type I Grade S	granular-surfaced, modified bitumen cap
DynaLastic 180S	37" x 36'-9"	ASTM D 6164	sheet for use in fire-rated systems. A 180 gram polyester mat reinforced,
DynaLastic 1005	J/ X JU - 7	Type I Grade S	modified bitumen cap sheet for use in fire-
		Type I Grude D	rated systems.



		Test	Product
<u>Product</u> DynaPly	<u>Dimensions</u> 39-3/8" x 32'-10"	Specification ASTM D 6162	Description A polyester reinforced SBS modified
Dynariy	<i>37-376 X 32 -10</i>	Type II Grade S	bitumen ply sheet for use in conventional
			and modified bitumen built-up roof systems.
DynaLastic 250	39-3/8" x 32'-10"	ASTM D 6164	A 250 gram polyester mat reinforced,
		Type II Grade G	granular-surfaced, modified bitumen cap
DynaLastic 250 FR	39-3/8" x 32'-10"	ASTM D 6164	sheet. A 250 gram polyester mat reinforced,
D ynallastie 200 T K	57 576 A 52 10	Type II Grade G	granular-surfaced, modified bitumen cap
			sheet for use in fire-rated systems.
DynaMax	39-3/8" x 32'-10"	ASTM D 6162	A fiberglass/polyester reinforced SBS
		Type III Grade G	modified bitumen membrane surfaced with
			granules for application in hot asphalt or heat weld.
DynaMax FR	39-3/8" x 32'-10"	ASTM D 6162	A fire resistant, fiberglass/ polyester
2 9 100 100 1 1 1 1	0,0,0,0,002,10		reinforced SBS modified bitumen
			membrane surfaced with granules for
			application in hot asphalt.
DynaClad	39-3/8" x 33'-6"	ASTM D 6298	A foil faced, glass reinforced, SBS modified
DynaBase XT	39-3/8" x 49'-2"	ASTM D 6163	membrane for application in hot asphalt. A heavyweight glass reinforced SBS
Dynabase X1	5)-5/6 X +) -2	Type I Grade S	Base/Ply sheet.
DynaGlas FR XT	39-3/8" x 32'-10"	ASTM D 6163	A heavyweight glass reinforced granular
		Type I Grade S	surfaced SBS Cap sheet.
GlasKap	36" x 36'	ASTM D 3909	A mineral surfaced, asphalt coated,
GlasKap CR	36" x 36'	ASTM D 3909	fiberglass cap sheet. A white mineral surfaced, white acrylic
Glaskap CK	50 X 50	ASTN D 3909	coated, fiberglass cap sheet.
Ventsulation Felt	36" x 36'	ASTM D 4897	Heavy duty fiber glass base sheet
		Type II	impregnated and coated on both sides with
			asphalt with or without fine mineral
			stabilizer. Surfaced on the bottom side with
			coarse mineral granules embedded in asphaltic coating.
GlasBase Plus	36" x 108'	ASTM D 4601	Type II asphalt impregnated and coated
			glass fiber base sheet for use in conventional
			and modified bitumen built-up roofing.
GlasPly IV	36" x 180'	ASTM D 2178	Type IV asphalt impregnated glass felt for
		Type IV	use in conventional and modified bitumen built-up roofing.
GlasPly Premier	36" x 180'	ASTM D 2178	Type VI asphalt impregnated glass felt for
		Type VI	use in conventional and modified bitumen
			built-up roofing.
PermaPly 28	36" x 106'	ASTM D 4601	Type II asphalt impregnated and coated
		Type II	glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
FesCant Plus Cant	various	ASTM C 728	Factory pre-fabricated cant strips and taper
Strips, and Taper	10 000		edge, manufactured from expanded perlite
Edge			insulation.



		Test	Product
<u>Product</u>	Dimensions	Specification	Description
MBR Flashing	N/A	Proprietary	A two component elastomeric, cold
Cement Base and			application adhesive, consisting of a
Activator			modified proprietary compound with an asphalt base.
MBR Bonding	N/A	proprietary	A two component urethane cold application
Adhesive	1 1/ 2 1	proprioury	adhesive.
Bestile Industrial	various	ASTM D 4586,	A trowel grade, cutback bitumen flashing
Roof Cement		type I	grade cement mixture including inorganic fibers and mineral stabilizers.
Flex-I-Drain	various	BOCA 76-61	Two piece flexible drain system composed
		SBCCI 89204	of a Noryl deck flange, a flexible neoprene
		UBC 3236	bellows and no hub connection. Available
			in various sizes and styles for most retro-fit
			applications.
PC/PET RetroDrain	various	N/A	Engineered resin copolymer fabricated drain
			for retrofit applications.
USII RetroDrain	various	N/A	One piece, aluminum fabricated drain for
			retrofit applications.
SuperDome	various	N/A	Cast aluminum, heavy-duty drain for retrofit
RetroDrain	1011 1 1 0		applications.
FP-10 Vents	10" deck flange,	N/A	One-way roof vent, designed for use in
	base diameter of 4"		various roof systems, for the release of
	and a height of 6"		pressure created by gases or moisture vapor
Expand-O-Guard	various	N/A	trapped within the roofing system.
Expand-O-Ouald	various	1N/A	Elastomeric expansion joint cover for vertical expansion and seismic joints.
			Manufactured from non-reinforced, form-
			supported elastomeric bellows with a
			bifurcated waterproof attachment to metal
			flanges.
Expand-O-Flash	various	N/A	Expansion joint covers manufactured from
•			non-reinforced, form-supported elastomeric
			bellows with a bifurcated waterproof
			attachment to metal flanges.
Presto-Lok Fascia and	various	TAS 114	A multi-piece fascia and flashing system for
Flashing System			built-up and modified bitumen roofing
			systems manufactured from aluminum or
1 -			steel.
DynaTred &	various	N/A	Preformed, skid-resistant boards.
DynaTred Plus Roof			
Walkway			



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ENERGY 3	Isocyanurate Insulation.	Johns Manville
Fesco Foam, DuraFoam	Isocyanurate Insulation with perlite facer	Johns Manville
Retro-Fit Board, DuraBoard	A high-density perlite roof insulation.	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
Invinsa Roof Board	High density polyisocyanurate board	Johns Manville
DensDeck, DensDeck Prime	Silicon treated gypsum	G-P Gypsum
SECUROCK Gypsum-Fiber Roof Board	Rigid, gypsum-based board stock	USG Corp.

APPROVED FASTENERS:

		TABLE 3		
Fastener	Product	Product		Manufacturer
Number	Name	Description	Dimensions	(With Current NOA)
1.	UltraFast Fastener	Insulation fastener for wood and steel.	Various	Johns Manville
2.	UltraFast ASAP	Pre-assembled Insulation fastener and plate	Various	Johns Manville
3.	UltraFast Metal Plate	Galvalume AZ55 steel plate	3" square & 3" round	Johns Manville
4.	UltraFast Plastic Plate	High Density Polyolefin round plate	3" round	Johns Manville
5.	OMG Fastener #12 & #14	Insulation fastener	Various	OMG, Inc.
6.	OMG Fastener ASAP	Pre-assembled Insulation fastener and plate	Various	OMG, Inc.
7.	OMG Polypropylene	Polypropylene plastic plate	3.25" round	OMG, Inc.
8.	OMG G-2	3.5" round galvalume AZ55 steel plate	3.5" round	OMG, Inc.
9.	OMG Standard	3" round galvalume AZ50 steel plate	3" round	OMG, Inc.



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Underwriters Laboratories, Inc.	R-10167 (N)	Fire Classification Listing	01.01.95
Factory Mutual Research	J.I. # 3001482	FM Class 4470	08/11/98
	J.I. # 3001629	FM Class 4470	09/10/98
	J.I. # 0Z8A9.AM J.I. # 3D4A4.AM	FM Class 4470	09/28/98
	3009499	FM Class 4470	04/04/01
	3007148	FM Class 4450	04/19/00
	3009499	FM Class 4470	04/04/01
	3011248	FM Class 4470	11/01/02
	3001457	FM Class 4470	04/04/02
	3014090	FM Class 4470	09/05/02
	3012974	FM Class 4450	06/03/02
	3026130	FM Class 4470	04/26/09
Exterior Research & Design	#4361-2.04.97-1	TAS 114	02/04/97
	#10390A-12.97-1	TAS 114	12/00/97
	10391.01.03	TAS 114	01/29/03
	00257.03.05-1	ASTM D 6162/63/64	03/17/05
Trinity ERD	J7670.06.08 J6990.12.07 J17040.11.09 J13700.05.10-1-R1 J13700.05.10-2	ASTM D6298 ASTM D3909 ASTM D6162/D6164 ASTM D6164 ASTM D5147/D6163 ASTM D5147/D6164	06/16/08 12/03/07 11/16/09 01/25/11 05/11/10
IRT, Inc.	#99004	TAS 114	03/00/99
Atlantic & Caribbean Roof	ACRC 03017	TAS 114	09/30/03
Consulting, LLC	ACRC 06-005	TAS 114	03/27/06
IRT-ARCON Inc	02-026 02-011	TAS 114	07/26/02 02/06/02



APPROVED ASSEMBLIES

Membrane Type:	SBS
Deck Type 1I:	Wood, Insulated
Deck Description:	$^{19}/_{32}$ " or greater plywood or wood plank, fastened with #8 screws.
System Type A(1):	Anchor sheet mechanically fastened; all layers of insulation fully adhered with approved asphalt.

All General and System limitations apply.

One or more layers of any of the following insulations: **Base Insulation Layer**

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 1.3" thick	N/A	N/A
Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Fesco Foam, DuraFoam Minimum 1.5" thick	N/A	N/A
Fesco Board Minimum ¾" thick	N/A	N/A
Retro-Fit Board, DuraBoard Minimum ½" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Anchor Sheet:	One ply of GlasPly Premier, PermaPly 28 or Ventsulation fastened to the deck as described below:
Fastening:	Anchor sheet shall be lapped 3" and fastened with 12 ga. annular ring shank nails and $1-5/8$ " diameter tin caps 9" o.c. in the lap and two rows staggered in the center of the sheet 9" o.c.
Base Sheet:	(Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus adhered to the insulated substrate in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Ply Sheet:	(Optional) One or more plies of GlasPly Premier, Glas Ply IV, DynaLastic 180S, DynaBase, DynaBase XT or DynaPly adhered to the a base sheet or perlite top layer with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Base heat welded.

Membrane:	One or more plies of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas, DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded. Or (Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Surfacing:	 (Optional) Install one of the following: 1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively. 2. GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Maximum Design Pressure:	-60 (See General Limitation #7).



Membrane Type:	SBS
Deck Type 1I:	Wood, Insulated
Deck Description:	$^{19}/_{32}$ " or greater plywood or wood plank, fastened with #12-3" Olympic STD screws @ 6" o.c.
System Type A(2):	Anchor sheet mechanically fastened; all layers of insulation fully adhered with approved asphalt.

All General and System limitations apply.

One or more layers of any of the following insulations: Base Insulation Layer

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3		-
Minimum 1.3" thick	N/A	N/A
Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Fesco Foam, DuraFoam		·
Minimum 1.5" thick	N/A	N/A
Fesco Board		
Minimum ³ / ₄ " thick	N/A	N/A
Retro-Fit Board, DuraBoard		
Minimum ¹ /2" thick	N/A	N/A

Inculation Factorian

Fastanan

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Anchor Sheet:	One ply of GlasPly Premier, PermaPly 28 or Ventsulation fastened to the deck as described below:
Fastening:	Anchor sheet shall be lapped 3" and fastened with Ultrafast screws and 3" plates, 8" o.c. at the lap and three rows staggered in the center of the sheet 8" o.c
Base Sheet:	(Optional if ply sheet used) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus adhered to the insulated substrate in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Ply Sheet:	(Optional if base sheet used) One or more plies of GlasPly Premier, Glas Ply IV, DynaLastic 180S, DynaBase, DynaBase XT or DynaPly adhered to the a base sheet or perlite top layer with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Base heat welded.



NOA No: 11-0126.01 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 9 of 20

Membrane:	One or more plies of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas, DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded. Or (Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Surfacing:	 (Optional) Install one of the following: 1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively. 2. GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Maximum Design Pressure:	-52.5 (See General Limitation #7).



Membrane Type:	SBS
Deck Type 1I:	Wood, Insulated
Deck Description:	$^{15}/_{32}$ " or greater plywood or wood plank
System Type A(3):	Anchor sheet mechanically fastened; all layers of insulation fully adhered with approved asphalt.

All General and System limitations apply.

One or more layers of any of the following insulations: **Base Insulation Layer**

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 1.3" thick	N/A	N/A
Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Fesco Foam, DuraFoam Minimum 1.5" thick	N/A	N/A
Fesco Board Minimum ¾" thick	N/A	N/A
Retro-Fit Board, DuraBoard Minimum ½" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Anchor Sheet:	Two plies of PermaPly 28, DynaBase, GlasBase Plus, or Ventsulation fastened to the deck as described below:
Fastening:	Anchor sheet shall be lapped 4" and fastened with approved roofing nails and tin caps 9" o.c. at the lap and two rows staggered in the center of the sheet 12" o.c.
Base Sheet:	(Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus adhered to the insulated substrate in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Ply Sheet:	(Optional) One or more plies of GlasPly Premier, Glas Ply IV, DynaLastic 180S, DynaBase, DynaBase XT or DynaPly adhered to the a base sheet or perlite top layer with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Base heat welded.

Membrane:	One or more plies of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas, DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded. Or (Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Surfacing:	 (Optional) Install one of the following: 1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively. 2. GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Maximum Design Pressure:	-52.5 (See General Limitation #7).



Membrane Type:	SBS
Deck Type 1I:	Wood, Insulated
Deck Description:	$^{19}/_{32}$ " or greater plywood over supports spaced 24" o.c. and attached with 10d nails spaced 4" o.c. at panel edges and 8d nails spaced 6" o.c. at center supports or wood plank
System Type B:	Base layer of insulation mechanically attached, top layer fully adhered with approved asphalt or adhesive.

All General and System limitations apply.

One or more layers of any of the following insulations: **Base Insulation Layer**

	(Table 3)	Density/ft ²
ENRGY 3		
Minimum 1.5" thick	1, 2, 5 or 6	1:1.3 ft ²

Insulation Fasteners

Fastener

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
DuraBoard		
Minimum ¹ /2" thick	N/A	N/A

Note: Top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or with MBR Bonding Adhesive with a notched squeegee at 2 gallons per square. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet:	(Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus adhered to the insulated substrate in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive with a notched squeegee at 1.5 to 2.0 gallons per square.
Ply Sheet:	(Optional) One or more plies of DynaBase, DynaBase XT, GlasBase Plus, PermaPly 28, GlasPly Premier, Glas Ply IV, DynaLastic 180S or DynaPly adhered to the a base sheet or insulation top layer with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive with a notched squeegee at 1.5 to 2.0 gallons per square or one ply DynaWeld Base heat welded to a base sheet.



NOA No: 11-0126.01 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 13 of 20

Membrane:	One or more plies of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas, DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive with a notched squeegee at 1.5 to 2.0 gallons per square or one ply DynaWeld Cap FR heat welded. Or (Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40
	lbs./sq. or with MBR Bonding Adhesive with a notched squeegee at 1.5 to 2.0 gallons per square.
Surfacing:	 (Optional) Install one of the following: 1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively. 2. GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Maximum Design Pressure:	-60 psf (See General Limitation #7).



Membrane Type:	SBS
Deck Type 1I:	Wood, Insulated
Deck Description:	$^{19}/_{32}$ " or greater plywood or wood plank, fastened with #12-3" Olympic STD screws @ 6" o.c.

System Type D: All layers of insulation and base sheet simultaneously mechanically fastened.

All General and System limitations apply.

One or more layers of any of the following insulations: **Insulation Layer**

	(Table 3)	Density/ft ²
ENRGY 3		
Minimum 1.3" thick	N/A	N/A
Fesco Foam, DuraFoam		
Minimum 1.5" thick	N/A	N/A
Fesco Board		
Minimum ³ / ₄ " thick	N/A	N/A
Retro-Fit Board, DuraBoard		
Minimum ¹ / ₂ " thick	N/A	N/A
DensDeck, DensDeck Prime, SECUROCK, Invinsa Roof Bo	ard	
Minimum ¹ /4" thick	N/A	N/A

Insulation Fasteners

Fastener

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

- Base Sheet: One ply of GlasPly Premier, PermaPly 28 or Ventsulation fastened to the deck as described below:
- Fastening : Fasten base sheet with UltraFast screws and 3" metal plates at 8" o.c. in the lap and three additional rows in the field at 8" o.c.
- Ply Sheet: (Optional) One or more plies of DynaBase, DynaBase XT, GlasBase Plus, PermaPly 28, GlasPly Premier, Glas Ply IV, DynaLastic 180S or DynaPly adhered to the a base sheet or perlite top layer with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq. or one ply DynaWeld Base heat welded.



NOA No: 11-0126.01 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 15 of 20

Membrane:	One or more plies of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas, DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq. or one ply DynaWeld Cap FR heat welded. Or (Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Surfacing:	 (Optional) Install one of the following: 1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively. 2. GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Maximum Design Pressure:	-52.5 psf (See General Limitation #7).



Membrane Type:	SBS	
Deck Type 1:	Wood, Non-insulated	
Deck Description:	$^{19}/_{32}$ " or greater plywood or wood plank decks	
System Type E(1):	Base sheet mechanically fastened.	
All General and System limitations apply.		
Base Sheet:	Two plies of PermaPly No. 28, DynaBase, GlasBase Plus or Ventsulation fastened to the deck as described below:	
Fastening:	Base sheet shall be lapped 4" and fastened with approved roofing nails and tin caps 9" o.c. in the lap and two rows staggered in the center of the sheet 12" o.c	
Ply Sheet:	(Optional) One or more plies of DynaBase, DynaBase XT, GlasBase Plus, PermaPly 28, GlasPly Premier, Glas Ply IV, DynaLastic 180S or DynaPly adhered to the a base sheet or perlite top layer with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq. or one ply DynaWeld Base heat welded.	
Membrane:	One or more plies of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas, DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq. or one ply DynaWeld Cap FR heat welded. Or (Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.	
Surfacing:	 (Optional) Install one of the following: 1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively. 2. GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. 	
Maximum Design Pressure:	-52.5 psf (See General Limitation #7).	



Membrane Type:	SBS
Deck Type 1:	Wood, Non-insulated
Deck Description:	$^{19}/_{32}$ " or greater plywood or wood plank, fastened with #12-3" Olympic STD screws @ 6" o.c.

System Type E(2): Base sheet mechanically fastened.

All General and System limitations apply.

Base Sheet:	One ply of GlasPly Premier, PermaPly 28 or Ventsulation fastened to the deck as described below:	
Fastening:	Base sheet shall be lapped 3" and fastened with UltraFast screws and 3" plates 8" o.c. in the lap and three rows staggered in the center of the sheet 8" o.c	
Ply Sheet:	(Optional) One or more plies of DynaBase, DynaBase XT, GlasBase Plus, PermaPly 28, GlasPly Premier, Glas Ply IV, DynaLastic 180S or DynaPly adhered to the a base sheet or perlite top layer with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq. or one ply DynaWeld Base heat welded.	
Membrane:	One or more plies of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq. or one ply DynaWeld Cap FR heat welded. Or (Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a f	
	mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.	
Surfacing:	 (Optional) Install one of the following: 1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively. 2. GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. 	
Maximum Design Pressure:	-52.5 psf (See General Limitation #7).	



Membrane Type:	SBS
Deck Type 1:	Wood, Non-insulated
Deck Description:	$^{19}/_{32}$ " or greater plywood or wood plank, fastened with #8 screws.
System Type E(3):	Base sheet mechanically fastened.
All General and Sys	stem limitations apply.
Base Sheet:	One ply of GlasPly Premier, PermaPly 28 or Ventsulation fastened to the deck as described below:
Fastening:	Base sheet shall be lapped 3" and fastened with 12 ga. annular ring shank nails and $1-5/8$ " diameter tin caps 9" o.c. in the lap and two rows staggered in the center of the sheet 9" o.c.
Ply Sheet:	(Optional) One or more plies of DynaBase, DynaBase XT, GlasBase Plus, PermaPly 28, GlasPly Premier, Glas Ply IV, DynaLastic 180S or DynaPly adhered to the a base sheet or perlite top layer with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq. or one ply DynaWeld Base heat welded.
Membrane:	One or more plies of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas, DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq. or one ply DynaWeld Cap FR heat welded. Or (Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
Surfacing:	(Optional) Install one of the following:

(Optional) Install one of the following:

- 1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.
- 2. GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Maximum Design	
Pressure:	-60 psf (See General Limitation #7).

WOOD DECK SYSTEM LIMITATIONS:

1 A slip sheet is required with Ply 4 and Ply 6 when used as a mechanically fastened base or anchor sheet.

GENERAL LIMITATIONS:

- 1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
- 3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
- 4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

- 5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
- 6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
- 7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant (When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)
- 8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
- The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). (When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)
- 10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No: 11-0126.01 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 20 of 20